

Rotating Equipment Engineering Manual

Document ID: APEL-MAN-301 | Owner: Process Engineering | Revision: 3.9

The pump families section contains subject-specific guidance.

Pump families

- Crude transfer
- Cooling water
- Recycle oil
- Product dispatch

Failure mechanisms

The failure mechanisms section contains subject-specific guidance.

Failure mechanisms

- Seal wear
- Bearing deterioration
- Misalignment
- Hydraulic instability
- Cavitation
- Casing corrosion

Condition monitoring

The condition monitoring section contains subject-specific guidance.

Condition monitoring

- Trend vibration with operating state.
- Compare bearing/seal temperatures with history.
- Link abnormal values to work orders.

P-102 engineering basis

The p-102 engineering basis section contains subject-specific guidance.

P-102 engineering basis

- Design pressure 50 bar.
- Approved operating maximum 40 bar.
- PSV set pressure 47.5 bar.
- Normal operating basis 35 bar.

Reliability learning

The reliability learning section contains subject-specific guidance.

Reliability learning

- Recurring seal defects should trigger alignment review.
- Repeated vibration after maintenance should prompt assembly verification.