

Name of Building: CUSU-maragondon H.S. Building
 Location: PINATEK MINTIN B
 Inspector: KRISTHA B. TALACAN

ACCESSIBILITY SURVEY CHECKLIST			
BASED ON BATAS PAMBANSA BILANG 344 (ACCESSIBILITY LAW)			
ACCESSIBILITY FEATURES	COMPLY		REMARKS
	YES	NO	
DOORS			
Door entrances should have an outside wing.	✓		
Door width is 0.80m (minimum).	✓		0.9 m
Door knob is lever type (pressure/force not more than 4kg).		✓	normal door knob (keyed door knob)
ENTRANCE			
Thresholds and sliding door tracks maximum height is 25mm.		✓	0.03 m
Clearance of entrance is 0.80m (minimum).	✓		2.22 m
CORRIDORS & HALLWAYS			
Corridor clear width is 1.20m (minimum).	✓		2.22 m
Corridor turning radius is 1.50 every 12 meters.	✓		
Headroom clearance is not below 2 meters.	✓		3.27m
Tactile strips for a change of direction/level.		✓	
SIGNAGE			
Signage height between 1.4-1.6m.		✓	none
Signage for warning (exterior).		✓	none
Signage for PWD ramp.		✓	none
Directional Signage for PWD Toilets		✓	none

WASHROOM AND TOILETS

Cubicle inside dimension 1.70m x 1.80m (minimum)	✓		1.75m (width) 1.8m (length)
Water closet 0.40 meter measured from the center of the toilet bowl to the face of adjacent wall.		✓	0.55m
One (1) movable grab bar and one (1) fixed to the adjacent wall.	✓		fixed grab bar only
Turning radius of 150m for easy passage of wheelchair.	✓		
Lavatory height is 0.80-0.85 m (minimum).		✓	0.71m
Faucet should have lever handle type.		✓	no faucet
Grab bar height at 0.75 - 0.80cm			
Distance of the middle of the grab bar to the middle of the water closet is 0.30cm.		✓	0.45m
Toilet bowls should be elevated to a range of 0.45 - 0.50 meter.		✓	0.37m
Non-skid flooring.	✓		
Door swings out.	✓		
ACCESSIBLE RAMPS (no ramp)			
Located at/near entrance			no ramp
Gradient (1:12 maximum)			no ramp
Handrails on both sides with the following:			none
Two (2) sets: 1-0.90 meter high and 1-0.7 meter high measured from ramp floor to top of handrail.			none
With 0.30 meter extensions at the start and end of handrails.			none
Handrail Diameter between 30mm-50mm			none

Clearance of 50mm if wall mounted.		✓	none
Maximum length is 6.00 meters		✓	none
Provision of 1.50 meters (minimum) landing between every 6 meters length of ramp		✓	none
Clear width of ramp is 1.20 meters		✓	none
PARKING			
Located nearest to accessible building entrance		✓	
Minimum Dimension: 3.70 meter (width) x 5 meter (length).		✓	
With Signage using the International Symbol of Access (White graphics with United Nations blue background).		✓	
ELEVATOR			
Can accommodate a minimum of two (2) wheelchairs.		✓	no elevator
The panel buttons shall feature Braille signs or otherwise embossed with familiar signs for those not educated in Braille		✓	no elevator
Equipped with handrails placed in both sides at 0.80 meters from the floor.		✓	none

RECOMMENDATIONS	
DOORS	
	- Door knob in all floor levels should be lever type handle.
CORRIDORS & HALLWAYS	
PARKING	
	- Provide a designated parking space/area.
SIGNAGE	
	- Provide a signage on walls and doors.
WASHROOM & TOILETS	
	- There should be a faucet with lever type handle.
ACCESSIBLE RAMPS	
	- Should provide an accessible ramps with two sets of handrails.
ELEVATOR	