

NAME OF BUILDING: BARANGAY HALL BUCAL 4A

LOCATION: BUCAL 4A

INSPECTOR: KRISHA B. TALACTAC

ACCESSIBILITY SURVEY CHECKLIST			
BASED ON BATAS PAMBANSA BILANG 344 (ACCESSIBILITY LAW)			
ACCESSIBILITY FEATURES	COMPLY		REMARKS
	YES	NO	
DOORS			
Door entrances should have an outside wing.		✓	Door swings in
Door width is 0.80m (minimum).	✓		0.9m
Door knob is lever type (pressure/force not more than 4kg).		✓	Keyed door knob used in all doors
ENTRANCE			
Thresholds and sliding door tracks maximum height is 25mm.		✓	0.015m
Clearance of entrance is 0.80m (minimum).	✓		2.10m
CORRIDORS & HALLWAYS			
Corridor clear width is 1.20m (minimum).	✓		2.70m
Corridor turning radius is 1.50 every 12 meters.	✓		2
Headroom clearance is not below 2 meters.	✓		2.25 m headroom
Tactile strips for a change of direction/level.		✓	
SIGNAGE			
Signage height between 1.4-1.6m.		✓	no ramps
Signage for warning (exterior).		✓	no ramps
Signage for PWD ramp.		✓	
Directional Signage for PWD Toilets		✓	

1.63 length

1.6 width

WASHROOM AND TOILETS

Cubicle inside dimension 1.70m x 1.80m (minimum)

✓

1.63m x 1.6m

Water closet 0.40 meter measured from the center of the toilet bowl to the face of adjacent wall.

✓

0.45m

One (1) movable grab bar and one (1) fixed to the adjacent wall.

✓

Turning radius of 150m for easy passage of wheelchair.

✓

Lavatory height is 0.80-0.85 m (minimum).

✓

0.76m

Faucet should have lever handle type.

✓

Grab bar height at 0.75 - 0.80cm

✓

Distance of the middle of the grab bar to the middle of the water closet is 0.30cm.

✓

Toilet bowls should be elevated to a range of 0.45 - 0.50 meter.

✓

0.4m

Non-skid flooring.

✓

Door swings out.

✓

door swings in

ACCESSIBLE RAMPS

(no accessible ramp)

Located at/near entrance

✓

no accessible ramps

Gradient (1:12 maximum)

✓

none

Handrails on both sides with the following:

✓

none

Two (2) sets: 1-0.90 meter high and 1-0.7 meter high measured from ramp floor to top of handrail.

✓

none

With 0.30 meter extensions at the start and end of handrails.

✓

none

Handrail Diameter between 30mm-50mm

✓

none

Clearance of 50mm if wall mounted.		✓	none
Maximum length is 6.00 meters		✓	none
Provision of 1.50 meters (minimum) landing between every 6 meters length of ramp		✓	none
Clear width of ramp is 1.20 meters		✓	none
PARKING			
Located nearest to accessible building entrance		✓	no parking
Minimum Dimension: 3.70 meter (width) x 5 meter (length).		✓	no parking
With Signage using the International Symbol of Access (White graphics with United Nations blue background).		✓	none
ELEVATOR			
Can accommodate a minimum of two (2) wheelchairs.		✓	no elevator
The panel buttons shall feature Braille signs or otherwise embossed with familiar signs for those not educated in Braille		✓	no elevator
Equipped with handrails placed in both sides at 0.80 meters from the floor.		✓	none

RECOMMENDATIONS	
DOORS	
<ul style="list-style-type: none"> - The door should have an outward swing. - All doors knobs in all floor level should be lever type handle. 	
CORRIDORS & HALLWAYS	
PARKING	
<ul style="list-style-type: none"> - Provide parking for PWD which is located to accessible building entrance 	
SIGNAGE	
<ul style="list-style-type: none"> - Provide signages on all doors and walls. 	
WASHROOM & TOILETS	
<ul style="list-style-type: none"> - The washroom and toilet dimension should be 1.7m x 1.8 (min) - Provide a moveable and fixed grab bar. 	
ACCESSIBLE RAMPS	
<ul style="list-style-type: none"> - Provide accessible ramps with a width of 1.2m (minimum) and provide two sets of handrails. 	
ELEVATOR	