

NAME OF BUILDING: MODIFIED SCHOOL BUILDING 6 - CCIS

LOCATION: GARITA A

INSPECTION: KRISTHA TALACTAC

ACCESSIBILITY SURVEY CHECKLIST			
BASED ON BATAS PAMBANSA BILANG 344 (ACCESSIBILITY LAW)			
ACCESSIBILITY FEATURES	COMPLY		REMARKS
	YES	NO	
DOORS			
Door entrances should have an outside wing.		✓	
Door width is 0.80m (minimum).	✓		0.99m
Door knob is lever type (pressure/force not more than 4kg).		✓	normal door knob
ENTRANCE			
Thresholds and sliding door tracks maximum height is 25mm.	✓		
Clearance of entrance is 0.80m (minimum).	✓		2.62m
CORRIDORS & HALLWAYS			
Corridor clear width is 1.20m (minimum).	✓		2.62m
Corridor turning radius is 1.50 every 12 meters.		✓	
Headroom clearance is not below 2 meters.	✓		2.14 m headroom
Tactile strips for a change of direction/level.		✓	
SIGNAGE			
Signage height between 1.4-1.6m.		✓	no ramps
Signage for warning (exterior).		✓	none
Signage for PWD ramp.		✓	none
Directional Signage for PWD Toilets		✓	none

WASHROOM AND TOILETS

Cubicle inside dimension 1.70m x 1.80m (minimum)	✓		1.80 m x 2.05 m
Water closet 0.40 meter measured from the center of the toilet bowl to the face of adjacent wall.		✓	0.5m.
One (1) movable grab bar and one (1) fixed to the adjacent wall.		✓	
Turning radius of 150m for easy passage of wheelchair.		✓	
Lavatory height is 0.80-0.85 m (minimum).	✓		0.85 m
Faucet should have lever handle type.	✓		
Grab bar height at 0.75 - 0.80cm		✓	
Distance of the middle of the grab bar to the middle of the water closet is 0.30cm.		✓	
Toilet bowls should be elevated to a range of 0.45 - 0.50 meter.		✓	0.37 m
Non-skid flooring.	✓		
Door swings out.		✓	door swings in

ACCESSIBLE RAMPS

Located at/near entrance		✓	no ramps
Gradient (1:12 maximum)		✓	none
Handrails on both sides with the following:		✓	none
Two (2) sets: 1-0.90 meter high and 1-0.7 meter high measured from ramp floor to top of handrail.		✓	none
With 0.30 meter extensions at the start and end of handrails.		✓	none
Handrail Diameter between 30mm-50mm		✓	none

Clearance of 50mm if wall mounted.		✓	none
Maximum length is 6.00 meters		✓	none
Provision of 1.50 meters (minimum) landing between every 6 meters length of ramp		✓	none
Clear width of ramp is 1.20 meters		✓	none
PARKING			
Located nearest to accessible building entrance		✓	no parking
Minimum Dimension: 3.70 meter (width) x 5 meter (length).		✓	no parking
With Signage using the International Symbol of Access (White graphics with United Nations blue background).		✓	none
ELEVATOR			
Can accommodate a minimum of two (2) wheelchairs.		✓	no elevator
The panel buttons shall feature Braille signs or otherwise embossed with familiar signs for those not educated in Braille		✓	no elevator
Equipped with handrails placed in both sides at 0.80 meters from the floor.		✓	none

RECOMMENDATIONS

DOORS

- The doors, swings outside should
- The door knob should have lever type handle.

CORRIDORS & HALLWAYS

PARKING

SIGNAGE

- Should provide signages on all walls and doors.

WASHROOM & TOILETS

- The door should open outward wing
- Provide moveable and fixed grab bar.

ACCESSIBLE RAMPS

ELEVATOR