

NAME OF BUILDING: MUNICIPAL CIRCUIT TRIAL COURT

LOCATION: GAKITHA A

INSPECTOR/STUDENT: KRISHN B. TALAGATA

ACCESSIBILITY SURVEY CHECKLIST			
BASED ON BATAS PAMBANSA BILANG 344 (ACCESSIBILITY LAW)			
ACCESSIBILITY FEATURES	COMPLY		REMARKS
	YES	NO	
<b>DOORS</b>			
Door entrances should have an outside wing.	✓		
Door width is 0.80m (minimum).	✓		
Door knob is lever type (pressure/force not more than 4kg).		✓	glass door
<b>ENTRANCE</b>			
Thresholds and sliding door tracks maximum height is 25mm.		✓	none
Clearance of entrance is 0.80m (minimum).	✓		
<b>CORRIDORS &amp; HALLWAYS</b>			
Corridor clear width is 1.20m (minimum).	✓		
Corridor turning radius is 1.50 every 12 meters.	✓		
Headroom clearance is not below 2 meters.	✓		2.5 m headmm
Tactile strips for a change of direction/level.		✓	
<b>SIGNAGE</b>			
Signage height between 1.4-1.6m.		✓	none
Signage for warning (exterior).		✓	none
Signage for PWD ramp.		✓	none
Directional Signage for PWD Toilets		✓	none

WASHROOM AND TOILETS			
Cubicle inside dimension 1.70m x 1.80m (minimum)		✓	1.9 x 1.3
Water closet 0.40 meter measured from the center of the toilet bowl to the face of adjacent wall.	✓		
One (1) movable grab bar and one (1) fixed to the adjacent wall.		✓	none
Turning radius of 150m for easy passage of wheelchair.		✓	
Lavatory height is 0.80-0.85 m (minimum).		✓	
Faucet should have lever handle type.		✓	
Grab bar height at 0.75 - 0.80cm		✓	none
Distance of the middle of the grab bar to the middle of the water closet is 0.30cm.		✓	no grab bar
Toilet bowls should be elevated to a range of 0.45 - 0.50 meter.		✓	
Non-skid flooring.	✓		
Door swings out.		✓	Door swings in
ACCESSIBLE RAMPS			
Located at/near entrance	✓		
Gradient (1:12 maximum)		✓	
Handrails on both sides with the following:	✓		
Two (2) sets: 1-0.90 meter high and 1-0.7 meter high measured from ramp floor to top of handrail.		✓	
With 0.30 meter extensions at the start and end of handrails.		✓	
Handrail Diameter between 30mm-50mm	✓		

Clearance of 50mm if wall mounted.		✓	none
Maximum length is 6.00 meters	✓		2.6 m
Provision of 1.50 meters (minimum) landing between every 6 meters length of ramp		✓	none
Clear width of ramp is 1.20 meters		✓	1.16 m
<b>PARKING</b>			
Located nearest to accessible building entrance	✓	✓	no parking
Minimum Dimension: 3.70 meter (width) x 5 meter (length).		✓	no parking
With Signage using the International Symbol of Access (White graphics with United Nations blue background).		✓	none
<b>ELEVATOR</b>			
Can accommodate a minimum of two (2) wheelchairs.		✓	no elevator
The panel buttons shall feature Braille signs or otherwise embossed with familiar signs for those not educated in Braille		✓	no elevator
Equipped with handrails placed in both sides at 0.80 meters from the floor.		✓	none

RECOMMENDATIONS	
<b>DOORS</b>	
<b>CORRIDORS &amp; HALLWAYS</b>	
<b>PARKING</b>	
	<ul style="list-style-type: none"> <li>- provide parking for PWD which is located nearest to the building entrance.</li> </ul>
<b>SIGNAGE</b>	
	<ul style="list-style-type: none"> <li>- should provide signages on walls and door.</li> </ul>
<b>WASHROOM &amp; TOILETS</b>	
	<ul style="list-style-type: none"> <li>- provide toilet for PWD having 1.7m x 1.8m (min.) dimension.</li> <li>- provide grab bar moveable and fixed.</li> <li>- The door should be outside swing.</li> </ul>
<b>ACCESSIBLE RAMPS</b>	
	<ul style="list-style-type: none"> <li>- The ramp should be 1.2m (min) width</li> </ul>
<b>ELEVATOR</b>	
	<ul style="list-style-type: none"> <li>- Provide an elevator that can accommodate a minimum of 2 wheelchairs.</li> </ul>