

Fire**risk**.io

Fire Risk Assessment Template

Comprehensive UK Fire Safety Assessment Form
Updated for 2026 Regulations

COMPLIANT WITH:

- ✓ Regulatory Reform (Fire Safety) Order 2005
- ✓ Fire Safety Act 2021
- ✓ Fire Safety (England) Regulations 2022
- ✓ BS 8674:2025 Competency Framework
- ✓ BS 9792:2025 Housing FRA Methodology
- ✓ Building Safety Act 2022 Requirements

Version 2026.1 | January 2026

24 Pages | Includes Fire Door Checklist, PEEP Template & Risk Rating Matrix

Professional Fire Risk Assessments from £79

firerisk.io | 020 3051 1294

500+ Google Reviews | 4.9★ Rating | Nationwide Coverage

How to Use This Template

Before You Begin

This template is designed to help you conduct a comprehensive fire risk assessment in accordance with UK legislation. Please read this page carefully before starting your assessment.

The 5 Steps of Fire Risk Assessment

Step 1: Identify Fire Hazards

Pages 5-7: Ignition sources, fuel sources, other hazards

Step 2: Identify People at Risk

Pages 8-9: Occupancy analysis, vulnerable persons, PEEPs

Step 3: Evaluate, Remove, Reduce

Pages 10-16: Fire safety measures evaluation

Step 4: Record, Plan, Train

Pages 17-19: Management, training, action plan

Step 5: Review Regularly

Page 20: Review schedule, declaration, sign-off

Assessor Competency Requirements (BS 8674:2025)

 **New for 2025:** BS 8674:2025 introduces a competency framework with three levels. You must match your competency level to the building's risk profile.

Level	Building Type	Who Can Assess
FOUNDATION	Small offices, shops, low-risk premises	Trained competent person with basic fire safety knowledge
INTERMEDIATE	Public venues, mid-rise residential, HMOs	Fire safety professional with intermediate qualifications
ADVANCED	Care homes, high-rise residential, complex buildings	Experienced fire risk assessor with advanced certification

When You MUST Use a Professional Assessor

A professional assessment is strongly recommended or legally required for:

- Higher-risk buildings under Building Safety Act 2022 (7+ storeys / 18m+)
- Care homes and residential care facilities (sleeping risk)
- Buildings with complex compartmentation or external wall concerns
- HMOs with 3+ storeys or complex layouts
- Premises where you lack confidence in your competence

What's New in This 2026 Template

- ☒ BS 8674:2025 competency level field
- ☒ Fire door inspection checklist (20 points)
- ☒ Fire door quarterly/annual register
- ☒ Compartmentation assessment section
- ☒ PEEP template (mandatory from April 2026)
- ☒ Risk rating matrix (5 levels)
- ☒ Building height category classification
- ☒ External wall construction field

Required Documents to Have Ready

Before starting your assessment, gather the following:

- Previous fire risk assessment (if any)
- Fire alarm test/maintenance records
- Emergency lighting test certificates
- Fire extinguisher service records
- Fire door inspection reports
- Staff fire training records
- Building plans/floor layouts

Section A: General Information

Important: Complete all fields in this section. This information identifies the responsible person under Article 3 of the Regulatory Reform (Fire Safety) Order 2005.

Responsible Person Details

Full Name of Responsible Person *	Position/Title
Company/Organisation Name	
Contact Telephone	Email Address

Premises Address

Premises Name (if applicable)	
Street Address *	
Town/City *	Postcode *

Assessor Details

Assessor Name *	Company (if external)
Qualifications/Certifications	
Assessor Competency Level (BS 8674:2025) *	
☐ FOUNDATION (Low-risk premises) ☐ INTERMEDIATE (Medium complexity) ☐ ADVANCED (Complex/high-rise)	

Assessment Details

Date of Assessment *	Assessment Reference Number
Type of Assessment *	
☐ Initial Assessment ☐ Annual Review ☐ Significant Change Review ☐ Post-Incident Review	
Date of Previous Assessment (if applicable)	

Section B: Premises Profile

Building Classification

Primary Use of Premises *

- ☐ Office/Commercial
- ☐ Retail/Shop
- ☐ HMO (House in Multiple Occupation)
- ☐ Block of Flats
- ☐ Care Home
- ☐ Restaurant/Food Premises
- ☐ Warehouse/Industrial
- ☐ Educational
- ☐ Other: _____

Building Height Category * (Building Safety Act 2022)

- ☐ Under 11m
- ☐ 11m - 18m
- ☐ Over 18m (7+ storeys)

Higher-Risk Building? Buildings over 18m (7+ storeys) with 2+ residential units are "higher-risk buildings" under the Building Safety Act 2022 and require registration with the Building Safety Regulator.

Physical Details

Number of Storeys

Total Floor Area (m²)

Year Built (approx)

Primary Construction Type

- ☐ Traditional brick/masonry
- ☐ Concrete frame
- ☐ Steel frame
- ☐ Timber frame
- ☐ Mixed construction

External Wall System (Fire Safety Act 2021 - now in FRA scope)

- ☐ Solid brick/masonry
- ☐ Render on masonry
- ☐ Rainscreen cladding
- ☐ ETICS/EWI system
- ☐ Curtain wall
- ☐ Unknown/requires survey

Has an External Wall Fire Risk Appraisal (FRAEW/EWS1) been completed?

- ☐ Yes - Satisfactory
- ☐ Yes - Remediation required
- ☐ No - Not required
- ☐ No - Required but not completed
- ☐ N/A (under 11m)

Occupancy Details

Maximum Occupancy

Number of Residential Units (if applicable)

Hours of Operation

- ☐ Daytime only (e.g., 9am-6pm)
- ☐ Extended hours
- ☐ 24-hour occupation
- ☐ Sleeping accommodation

⚠ Sleeping Risk: Premises with sleeping accommodation (residential, care homes, hotels) require enhanced fire safety measures and may require an assessor with Intermediate or Advanced competency level.

Section C: Fire Hazards - Ignition Sources

Step 1 of 5: Identify anything that could start a fire. Consider all potential sources of ignition and assess the risk level for each.

● Trivial ● Tolerable ● Moderate ● Substantial ● Intolerable

Electrical Installations & Equipment

Hazard Check	N/A	Yes	No	Risk Level
Are fixed electrical installations periodically inspected and tested (every 5 years)?	☐	☐	☐	
Are portable appliances subject to PAT testing where required?	☐	☐	☐	
Is the use of trailing leads and adaptors avoided/minimised?	☐	☐	☐	
Are socket outlets free from overloading?	☐	☐	☐	
Is electrical equipment in good condition (no damaged cables/plugs)?	☐	☐	☐	

Heating Systems & Portable Heaters

Hazard Check	N/A	Yes	No	Risk Level
Are fixed heating systems subject to regular maintenance?	☐	☐	☐	
Are portable heaters used safely and inspected periodically?	☐	☐	☐	
Are heaters positioned away from combustible materials?	☐	☐	☐	

Cooking Equipment

Hazard Check	N/A	Yes	No	Risk Level
Are adequate measures in place to prevent fires from cooking?	☐	☐	☐	
Are extraction filters and ductwork subject to regular cleaning?	☐	☐	☐	
Is cooking equipment isolated/turned off when not in use?	☐	☐	☐	

Smoking

Hazard Check	N/A	Yes	No	Risk Level
Are adequate measures in place to stop smoking on the premises?	☐	☐	☐	
Are 'No Smoking' signs displayed as required?	☐	☐	☐	
Are suitable arrangements in place for those who smoke outside?	☐	☐	☐	

Section C: Fire Hazards - Fuel Sources

Fuel Sources: Anything that will burn is fuel for a fire. Consider how materials are stored and whether they could contribute to fire spread.

Trivial

Tolerable

Moderate

Substantial

Intolerable

Arson Prevention

Hazard Check	N/A	Yes	No	Risk Level
Are premises adequately secured to prevent unauthorised access?	☐	☐	☐	
Are combustible materials stored away from building perimeter?	☐	☐	☐	
Are waste/refuse bins secured and located away from building?	☐	☐	☐	
Is external lighting adequate to deter intruders?	☐	☐	☐	

Housekeeping & Storage

Hazard Check	N/A	Yes	No	Risk Level
Is the standard of housekeeping adequate to avoid accumulation of combustible materials?	☐	☐	☐	
Are combustible materials stored away from ignition/heat sources?	☐	☐	☐	
Are escape routes kept clear of storage/combustibles?	☐	☐	☐	
Is waste removed regularly and not allowed to accumulate?	☐	☐	☐	

Dangerous Substances (DSEAR)

Hazard Check	N/A	Yes	No	Risk Level
Are any dangerous substances (flammable liquids/gases) present?	☐	☐	☐	
Are dangerous substances stored in appropriate containers/cabinets?	☐	☐	☐	
Are quantities of flammable substances kept to a minimum?	☐	☐	☐	
Is a separate DSEAR assessment required?	☐	☐	☐	

DSEAR: The Dangerous Substances and Explosive Atmospheres Regulations 2002 (DSEAR) require a separate risk assessment where dangerous substances are present. This FRA does not replace a DSEAR assessment.

Contractors & Hot Works

Hazard Check	N/A	Yes	No	Risk Level
Are contractors who work on premises competent and qualified?	☐	☐	☐	
Is a hot works permit system in place?	☐	☐	☐	
Are fire precautions in place during hot works (welding, grinding)?	☐	☐	☐	

Section C: Fire Hazards - Other Significant Hazards

Additional Hazards: Consider any other factors specific to your premises that could contribute to fire risk or affect the safety of occupants.

● Trivial ● Tolerable ● Moderate ● Substantial ● Intolerable

Building Services & Utilities

Hazard Check	N/A	Yes	No	Risk Level
Is the gas installation subject to annual safety check?	☐	☐	☐	
Are gas appliances serviced regularly by Gas Safe registered engineer?	☐	☐	☐	
Are oil installations inspected and maintained regularly?	☐	☐	☐	
Is solar/battery storage equipment installed and maintained correctly?	☐	☐	☐	

Lightning & External Fire Spread

Hazard Check	N/A	Yes	No	Risk Level
Is lightning protection in place where required?	☐	☐	☐	
Are there adequate fire breaks from neighbouring premises?	☐	☐	☐	
Is vegetation/overgrowth controlled around the building?	☐	☐	☐	

E-Bikes, E-Scooters & Lithium Batteries NEW 2026

Hazard Check	N/A	Yes	No	Risk Level
Are e-bikes/e-scooters stored on the premises?	☐	☐	☐	
Are e-bikes stored away from escape routes?	☐	☐	☐	
Is charging of lithium batteries controlled and supervised?	☐	☐	☐	
Are only manufacturer-approved chargers used?	☐	☐	☐	

Lithium Battery Warning: E-bike and e-scooter fires are increasing significantly. The London Fire Brigade attended 155 e-bike fires in 2023. Never charge unattended, use approved chargers only, and store away from escape routes.

Additional Hazards Identified

Hazard Description	Location	Risk Level

Section C Summary - Overall Fire Hazard Assessment

Overall Fire Hazard Risk Level for Premises

☐ TRIVIAL ☐ TOLERABLE ☐ MODERATE ☐ SUBSTANTIAL ☐ INTOLERABLE

Assessor Notes on Fire Hazards

Section D: People at Risk - Occupancy Analysis

Step 2 of 5: Identify everyone who may be at risk from fire. Consider all occupants including employees, residents, visitors, contractors, and anyone who may be particularly vulnerable.

Occupant Categories

Category	Number	Notes (locations, shifts, etc.)
Employees/Staff		
Residents (if applicable)		
Visitors/Customers		
Contractors		
Members of the Public		
Other (specify)		

Maximum Occupancy at Any One Time

Total Persons on Register (if residential)

Location-Based Occupancy

Floor/Area	Day	Night	Special Considerations
Basement			
Ground Floor			
First Floor			
Second Floor			
Third Floor +			

Persons at Increased Risk

Category	N/A	Yes	No	Number
Are there any lone workers on the premises?	☐	☐	☐	
Are there night workers/sleepers on premises?	☐	☐	☐	
Are there persons unfamiliar with the building (visitors, customers)?	☐	☐	☐	
Are there persons in remote/isolated areas ?	☐	☐	☐	
Are there persons in areas with high fire risk (kitchens, plant rooms)?	☐	☐	☐	

Operating Times & Access

Normal Operating Hours

From: To:

☐ 24-hour occupation

Days of Operation

☐ Mon ☐ Tue ☐ Wed ☐ Thu ☐ Fri ☐ Sat ☐ Sun

⚠ Sleeping Accommodation: If anyone sleeps on the premises (residential, care homes, hotels, on-call staff), additional fire safety measures are required. See Page 9 for vulnerable persons assessment.

Section D: Vulnerable Persons & PEEPs

PEEP Requirement - April 2026: The Fire Safety (England) Regulations 2022 require "Residential Personal Emergency Evacuation Plans" for residents who may need assistance evacuating. This comes into force on **6 April 2026**.

Vulnerable Persons Assessment

Vulnerability Category	N/A	Yes	No	Number
Mobility impairment (wheelchair users, walking difficulties)	☐	☐	☐	
Visual impairment (blind, partially sighted)	☐	☐	☐	
Hearing impairment (deaf, hard of hearing)	☐	☐	☐	
Cognitive impairment (dementia, learning disabilities)	☐	☐	☐	
Mental health conditions affecting evacuation response	☐	☐	☐	
Temporary impairment (pregnancy, injury, surgery recovery)	☐	☐	☐	
Children (under 18 years)	☐	☐	☐	
Elderly persons (65+ years)	☐	☐	☐	

Personal Emergency Evacuation Plans (PEEPs) **MANDATORY FROM APRIL 2026**

PEEP Requirement Check	N/A	Yes	No
Has the Responsible Person identified residents who may need assistance evacuating?	☐	☐	☐
Has information been requested from residents about their evacuation needs?	☐	☐	☐
Have PEEPs been prepared for those who require them?	☐	☐	☐
Are PEEPs reviewed and updated regularly (at least annually)?	☐	☐	☐
Are PEEPs shared with the Fire & Rescue Service (where required)?	☐	☐	☐
Is there a system to identify new residents who may need a PEEP?	☐	☐	☐

PEEP Register

Name/Unit	Location	Evacuation Need	PEEP Date	Review Due	Status

* Full PEEP forms should be completed for each individual - see Appendix C for PEEP template

Evacuation Aids & Equipment

Equipment Check	N/A	Yes	No
Are evacuation chairs provided where required?	☐	☐	☐
Are staff trained in evacuation chair use?	☐	☐	☐
Are refuges/protected lobbies available for those awaiting assistance?	☐	☐	☐
Is there two-way communication at refuges?	☐	☐	☐
Are visual alarm systems provided for hearing impaired persons?	☐	☐	☐
Are vibrating pager/pillow alerts provided for deaf persons who sleep?	☐	☐	☐

Evacuation Strategy: For premises with vulnerable persons, consider whether "stay put", "defend in place", "simultaneous evacuation", or "phased evacuation" is most appropriate. Document your chosen strategy and ensure all staff understand it.

Section E: Fire Safety Measures - Means of Escape

Step 3 of 5: Evaluate whether existing fire safety measures are adequate. If not, identify what further action is needed to reduce or remove the risk.

Trivial

Tolerable

Moderate

Substantial

Intolerable

Escape Routes

Check Item	N/A	Yes	No	Risk Level
Are there sufficient escape routes for the number of occupants?	☐	☐	☐	
Are escape routes kept clear and unobstructed at all times?	☐	☐	☐	
Are travel distances within acceptable limits?	☐	☐	☐	
Are escape routes adequately lit (including emergency lighting)?	☐	☐	☐	
Are floor surfaces in escape routes non-slip and even?	☐	☐	☐	

Staircases

Check Item	N/A	Yes	No	Risk Level
Are staircases adequate for the number of occupants?	☐	☐	☐	
Are staircases protected by fire-resisting construction?	☐	☐	☐	
Are handrails provided on both sides where necessary?	☐	☐	☐	
Are staircases kept free from storage?	☐	☐	☐	

Two Staircases Requirement (2026): New residential buildings 18m+ in height must have at least 2 staircases. Transitional period ends **30 September 2026**. Does this building require a second staircase?

☐ N/A (under 18m)

☐ Yes - Compliant

☐ Yes - Non-compliant (action required)

☐ Existing building - single staircase acceptable

Exit Doors

Check Item	N/A	Yes	No	Risk Level
Do all final exit doors open outwards (or slide where appropriate)?	☐	☐	☐	
Are exit doors easily and immediately openable without a key?	☐	☐	☐	
Are panic hardware/push bars fitted where required?	☐	☐	☐	
Are electronically locked doors on fail-safe release?	☐	☐	☐	
Are exit doors wide enough for the number of occupants using them?	☐	☐	☐	

Inner Rooms & Dead Ends

Check Item	N/A	Yes	No	Risk Level
Are inner rooms (rooms accessed through another room) avoided or mitigated?	☐	☐	☐	
Where inner rooms exist, is there adequate warning (vision panel, linked detector)?	☐	☐	☐	
Are dead-end corridors within acceptable limits (usually 18m max)?	☐	☐	☐	

Assembly Point

Location of Assembly Point(s)

Is the assembly point clearly signed and known to all occupants?

☐ Yes ☐ No

Section E: Fire Detection & Warning Systems

● Trivial ● Tolerable ● Moderate ● Substantial ● Intolerable

Fire Alarm System Type

Type of Fire Detection & Warning System (BS 5839-1:2025)

☐ L1 - Protection throughout (highest level)

☐ L2 - Protection of escape routes + high-risk rooms

☐ L3 - Protection of escape routes only

☐ L4 - Protection of circulation areas (minimum)

☐ L5 - Custom system as determined by FRA

☐ P1/P2 - Property protection system

☐ LD1/LD2/LD3 - Domestic system (BS 5839-6)

☐ Stand-alone smoke alarms only

☐ None

Fire Detection & Alarm

Check Item	N/A	Yes	No	Risk Level
Is fire detection coverage adequate for the premises?	☐	☐	☐	
Are appropriate detector types used (smoke, heat, multi-sensor)?	☐	☐	☐	
Are manual call points provided at exits and on escape routes?	☐	☐	☐	
Can the alarm be heard clearly throughout all occupied areas?	☐	☐	☐	
Is there visual alarm indication for hearing impaired persons?	☐	☐	☐	
Is there a control panel in a suitable location?	☐	☐	☐	

Testing & Maintenance

Check Item	N/A	Yes	No	Risk Level
Is the fire alarm tested weekly? (rotating call points)	☐	☐	☐	
Is there a service/maintenance contract in place?	☐	☐	☐	
Is the system serviced at least 6-monthly by competent engineer?	☐	☐	☐	
Are test records maintained and available?	☐	☐	☐	
Are false alarms monitored and addressed?	☐	☐	☐	

Alarm System Records

Date of Last Weekly Test

Date of Last Service

Maintenance Company

Next Service Due

Interlinked Alarms (HMOs & Residential)

Check Item	N/A	Yes	No
Are smoke alarms interlinked (all sound when one activates)?	☐	☐	☐
Are smoke alarms on every storey where there is a room used for living?	☐	☐	☐
Is there a heat alarm in every kitchen?	☐	☐	☐
Are carbon monoxide alarms fitted in rooms with fixed combustion appliances?	☐	☐	☐

BS 5839-6 (Dwellings):

Grade D1 (mains-powered, battery backup, interlinked) LD2 coverage is typically the minimum for HMOs. Higher grades may be required based on risk assessment.

Section E: Firefighting Equipment

● Trivial ● Tolerable ● Moderate ● Substantial ● Intolerable

Fire Extinguishers

Check Item	N/A	Yes	No	Risk Level
Are appropriate types of fire extinguishers provided?	☐	☐	☐	
Are extinguishers suitable for the risks present (Class A, B, C, electrical, cooking)?	☐	☐	☐	
Are there sufficient extinguishers for the floor area? (1 x 13A per 200m²)	☐	☐	☐	
Are extinguishers located on escape routes near exits?	☐	☐	☐	
Are extinguishers mounted at appropriate height (handle 1-1.5m)?	☐	☐	☐	
Are extinguisher locations clearly signed?	☐	☐	☐	

Fire Extinguisher Inventory

Type	Size	Location	Last Service	Next Due	Condition

Types: Water (red), Foam (cream), CO2 (black), Powder (blue), Wet Chemical (yellow)

Servicing & Maintenance

Check Item	N/A	Yes	No	Risk Level
Are extinguishers serviced annually by a competent person?	☐	☐	☐	
Are extended service intervals met (5 years for most types)?	☐	☐	☐	
Are CO2 extinguishers within 10-year test date?	☐	☐	☐	
Is there evidence of monthly visual checks?	☐	☐	☐	

Other Firefighting Equipment

Check Item	N/A	Yes	No	Risk Level
Is a fire blanket provided in cooking areas?	☐	☐	☐	
Are hose reels provided and operational (if fitted)?	☐	☐	☐	
Is there a sprinkler system (if required/fitted)?	☐	☐	☐	
Are dry/wet risers provided and maintained (if fitted)?	☐	☐	☐	
Is kitchen extraction suppression system installed (commercial kitchens)?	☐	☐	☐	

Service Provider Details

Fire Extinguisher Service Company

Contact Number

Date of Last Service

Next Service Due

Training Requirement: Staff should be trained in the selection and use of fire extinguishers. However, the primary action on discovering a fire should always be to raise the alarm and evacuate.

Section E: Emergency Lighting & Fire Safety Signage

● Trivial ● Tolerable ● Moderate ● Substantial ● Intolerable

Emergency Lighting (BS 5266-1)

Check Item	N/A	Yes	No	Risk Level
Is emergency lighting provided throughout escape routes?	☐	☐	☐	
Is emergency lighting provided at all exit doors?	☐	☐	☐	
Is emergency lighting provided at changes of direction/level?	☐	☐	☐	
Is emergency lighting provided at staircases?	☐	☐	☐	
Is emergency lighting provided at fire alarm call points?	☐	☐	☐	
Is emergency lighting provided at firefighting equipment locations?	☐	☐	☐	
Does the system provide minimum 1 hour duration (3 hours for sleeping risk)?	☐	☐	☐	

Emergency Lighting Testing

Check Item	N/A	Yes	No	Risk Level
Is emergency lighting tested monthly (flick test)?	☐	☐	☐	
Is a full duration test carried out annually?	☐	☐	☐	
Are test records maintained?	☐	☐	☐	
Are failed luminaires replaced promptly?	☐	☐	☐	

Date of Last Monthly Test

Date of Last Annual Full Duration Test

Fire Safety Signage (BS 5499 / ISO 7010)

Check Item	N/A	Yes	No	Risk Level
Are exit routes clearly indicated with directional signs?	☐	☐	☐	
Are final exits identified with "Fire Exit" signs?	☐	☐	☐	
Are "Push Bar to Open" signs provided where needed?	☐	☐	☐	
Are "Fire Door Keep Shut" signs on fire doors?	☐	☐	☐	
Are "Fire Door Keep Locked Shut" signs where appropriate?	☐	☐	☐	
Are fire action notices displayed prominently?	☐	☐	☐	
Are fire extinguisher location signs provided?	☐	☐	☐	
Are call point location signs provided?	☐	☐	☐	
Are "No Smoking" signs displayed as required?	☐	☐	☐	
Are signs in good condition and clearly visible?	☐	☐	☐	

Sign Standards: Signs must comply with BS 5499 / ISO 7010. Green = escape. Red = prohibition/firefighting.

Floor Plans / Evacuation Plans

Check Item	N/A	Yes	No
Are "You Are Here" evacuation plans displayed in complex premises?	☐	☐	☐
Do plans show escape routes, exits, and assembly points?	☐	☐	☐
Are plans up to date and accurately reflect the current layout?	☐	☐	☐

Section F: Fire Door Inspection Checklist MANDATORY

Fire Safety (England) Regulations 2022: Buildings with 2+ sets of domestic premises require:

- Quarterly checks of fire doors in communal areas
- Annual checks of flat entrance doors (best endeavours)

This checklist helps document compliance with these requirements.

20-Point Fire Door Inspection (Per Door)

Door Reference / Location

Date of Inspection

#	Inspection Item	Pass	Fail	N/A	Notes
1	Door leaf - Is the door leaf in good condition (no holes, damage, warping)?	☐	☐	☐	
2	Door frame - Is the frame securely fixed and in good condition?	☐	☐	☐	
3	Gaps (sides/top) - Are gaps 3mm or less (2-4mm tolerance)?	☐	☐	☐	
4	Gap (bottom) - Is gap 8mm or less (10mm max over threshold)?	☐	☐	☐	
5	Intumescent strips - Are strips intact and continuous around the door?	☐	☐	☐	
6	Smoke seals (cold smoke seals) - Are seals intact and undamaged?	☐	☐	☐	
7	Hinges - Are there 3 or more CE/UKCA marked hinges, securely fixed?	☐	☐	☐	
8	Self-closing device - Does the door close fully from any angle?	☐	☐	☐	
9	Latch operation - Does the latch engage into the strike plate?	☐	☐	☐	
10	Handle/lever - Is the handle secure and functional?	☐	☐	☐	
11	Lock - If fitted, is the lock CE/UKCA marked for fire doors?	☐	☐	☐	
12	Glazing - Is any glass fire-rated and properly sealed?	☐	☐	☐	
13	Glazing beads - Are glazing beads fire-rated and secure?	☐	☐	☐	
14	Letterplate - If fitted, is it fire-rated with intumescent liner?	☐	☐	☐	
15	Air transfer grilles - If fitted, are they intumescent?	☐	☐	☐	
16	Threshold strip/drop seal - Is threshold sealed appropriately?	☐	☐	☐	
17	Signage - "Fire Door Keep Shut" or "Keep Locked" sign in place?	☐	☐	☐	
18	Certification label - Is fire rating label/plug visible on door edge?	☐	☐	☐	
19	No wedges/obstructions - Is door free from illegal propping open?	☐	☐	☐	
20	Hold-open device - If fitted, is it linked to fire alarm and working?	☐	☐	☐	

Overall Result

☐ PASS ☐ FAIL

Fire Rating

☐ FD30 ☐ FD60

Inspector Initials

Tip: Photocopy this page or use Appendix B to document multiple doors. All communal fire doors should be checked quarterly; flat entrance doors annually (best endeavours).

Section F: Fire Door Register & Compliance Log

Regulation 10 Requirement: The responsible person must keep a record of fire door checks. Use this register to track all fire doors and demonstrate compliance with quarterly/annual inspection requirements.

Fire Door Inventory

Door Ref	Location	Rating	Type	Q1 Check	Q2 Check	Q3 Check	Q4 Check	Status

Type: C = Communal (quarterly), F = Flat entrance (annual), E = Equipment room, S = Stairwell
Rating: FD30 = 30 minutes fire resistance, FD60 = 60 minutes fire resistance

Flat Entrance Door Checks (Annual - Best Endeavours)

Flat/Unit	Rating	Last Check Date	Next Due	Access?	Notes/Actions Required	Status
				☐		
				☐		
				☐		
				☐		
				☐		
				☐		

"Best Endeavours" Explained: For flat entrance doors, Responsible Persons must make reasonable attempts to gain access for inspection. Document all contact attempts if a resident refuses or is unavailable. Provide fire safety information leaflets under the door if access is denied.

Fire Door Defects & Remedial Actions

Door Ref	Date Found	Defect Description	Priority	Action Taken	Completion

Priority: 1 = Immediate (door non-functional), 2 = Urgent (within 7 days), 3 = Standard (within 30 days)

Fire Door Summary

Total Fire Doors	Doors Passing	Doors Requiring Action

Section G: Compartmentation Assessment

Compartmentation: Fire-resisting construction that divides a building into compartments, preventing fire spread and allowing safe evacuation. This section assesses the integrity of compartment walls, floors, and any penetrations.

● Trivial ● Tolerable ● Moderate ● Substantial ● Intolerable

Compartment Walls & Floors

Check Item	N/A	Yes	No	Risk Level
Are compartment walls present between separate dwellings/units?	☐	☐	☐	
Do compartment walls appear intact with no visible breaches?	☐	☐	☐	
Are compartment floors providing adequate separation?	☐	☐	☐	
Are there separate compartments for high-risk areas (kitchens, plant rooms)?	☐	☐	☐	
Is staircase enclosed with fire-resisting construction?	☐	☐	☐	

Penetrations & Fire Stopping

Check Item	N/A	Yes	No	Risk Level
Are pipe penetrations through compartment walls/floors fire stopped?	☐	☐	☐	
Are cable penetrations adequately fire stopped?	☐	☐	☐	
Are duct penetrations fire dampered or fire stopped?	☐	☐	☐	
Is there evidence of recent penetrations being properly sealed?	☐	☐	☐	
Are fire stopping materials compatible and correctly installed?	☐	☐	☐	

Cavity Barriers & Roof Voids

Check Item	N/A	Yes	No	Risk Level
Are cavity barriers installed in roof/loft spaces at compartment lines?	☐	☐	☐	
Is there a continuous barrier between dwellings in roof voids?	☐	☐	☐	
Are cavity barriers present in external wall cavities (if applicable)?	☐	☐	☐	
Has a cavity barrier survey been conducted (for 11m+ buildings)?	☐	☐	☐	

Service Risers & Shafts

Check Item	N/A	Yes	No	Risk Level
Are service riser cupboards fitted with fire-resisting doors?	☐	☐	☐	
Are fire dampers fitted to ducts passing through compartment floors?	☐	☐	☐	
Are fire dampers subject to regular inspection and testing?	☐	☐	☐	
Are lift shafts adequately protected from fire spread?	☐	☐	☐	

⚠ **Specialist Survey:** A Type 4 Fire Risk Assessment includes destructive opening up of compartmentation. For buildings over 18m or where compartmentation concerns exist, consider commissioning a specialist compartmentation survey by a suitably qualified fire engineer.

Compartmentation Summary

Overall Compartmentation Condition

☐ SATISFACTORY ☐ MINOR DEFICIENCIES ☐ SIGNIFICANT CONCERNS ☐ SPECIALIST SURVEY REQUIRED

Notes on Compartmentation

Section H: Fire Safety Management

Step 4 of 5: Record your findings, plan appropriate action, inform and instruct relevant people, and provide training. Effective management systems are crucial for maintaining fire safety.

● Trivial ● Tolerable ● Moderate ● Substantial ● Intolerable

Responsible Person & Fire Safety Roles

Role	Name	Contact	Trained?
Responsible Person			☐
Deputy / Cover			☐
Chief Fire Warden			☐
Fire Warden 1			☐
Fire Warden 2			☐

Fire Safety Management Arrangements

Check Item	N/A	Yes	No	Risk Level
Is there a clear fire safety policy in place?	☐	☐	☐	
Are fire safety responsibilities clearly assigned?	☐	☐	☐	
Is there a documented emergency evacuation plan?	☐	☐	☐	
Are emergency procedures displayed and accessible?	☐	☐	☐	
Is there a system for reporting fire safety defects?	☐	☐	☐	
Are defects addressed promptly when reported?	☐	☐	☐	

Resident Fire Safety Information MANDATORY

Regulation 10 Requirement: For buildings with 2+ residential units, the Responsible Person must provide fire safety instructions to residents on what to do in case of fire.

Check Item	N/A	Yes	No
Has fire safety information been provided to all residents?	☐	☐	☐
Does information explain the evacuation strategy (stay put/simultaneous)?	☐	☐	☐
Does information explain the importance of fire doors?	☐	☐	☐
Is information provided to new residents at move-in?	☐	☐	☐
Is information displayed in common areas?	☐	☐	☐

Fire Safety Maintenance Schedule

Item	Frequency	Last Done	Next Due	By Whom
Fire alarm test	Weekly			
Fire alarm service	6-monthly			
Emergency lighting test	Monthly			
Emergency lighting full test	Annually			
Fire extinguisher service	Annually			
Fire doors (communal)	Quarterly			
Fire doors (flat entrance)	Annually			
Fire risk assessment review	Annually			

Section H: Training & Fire Drills

● Trivial
 ● Tolerable
 ● Moderate
 ● Substantial
 ● Intolerable

Staff Fire Safety Training

Check Item	N/A	Yes	No	Risk Level
Do all staff receive fire safety induction on starting?	☐	☐	☐	
Do staff know the location of fire exits and assembly points?	☐	☐	☐	
Do staff know how to raise the alarm?	☐	☐	☐	
Do staff know the action to take on discovering a fire?	☐	☐	☐	
Do staff know the action to take on hearing the fire alarm?	☐	☐	☐	
Have designated staff been trained in fire extinguisher use?	☐	☐	☐	
Is refresher training provided annually or when circumstances change?	☐	☐	☐	
Are training records maintained?	☐	☐	☐	

Fire Warden / Marshal Training

Check Item	N/A	Yes	No
Are sufficient fire wardens appointed for the building?	☐	☐	☐
Have fire wardens received specific training?	☐	☐	☐
Do wardens know their sweep routes and responsibilities?	☐	☐	☐
Are wardens trained in evacuation chair use (if applicable)?	☐	☐	☐
Are wardens identifiable (e.g., hi-vis tabards)?	☐	☐	☐

Fire Drills & Evacuation Practice

Check Item	N/A	Yes	No	Risk Level
Are fire drills carried out at least annually (6-monthly for higher risk)?	☐	☐	☐	
Are drill results recorded and reviewed?	☐	☐	☐	
Are evacuation times monitored and acceptable?	☐	☐	☐	
Are lessons learned from drills acted upon?	☐	☐	☐	

Fire Drill Record

Date	Time	Evacuation Time	Persons	Issues Identified	Result

Staff Training Register

Staff Name	Role	Induction	Last Refresher	Next Due	Warden?
					☐
					☐
					☐
					☐
					☐

Training Frequency: All staff should receive fire safety induction on day one. Refresher training should be provided annually, or more frequently for higher-risk premises. Fire wardens typically need more detailed training, including practical evacuation and equipment use.

Section I: Action Plan

Priority: P1 Immediate | P2 7 days | P3 30 days | P4 90 days | P5 Advisory

Significant Findings & Recommended Actions

#	Location	Deficiency / Finding	Recommended Action	P	Target	Resp.	Done	RAG
1								
2								
3								
4								
5								
6								
7								
8								
9								
10								
11								
12								

Action Plan (continued)

#	Location	Deficiency / Finding	Recommended Action	P	Target	Resp.	Done	RAG
13								
14								
15								
16								
17								
18								
19								
20								
21								
22								
23								
24								
25								

P1 Actions	P2 Actions	P3 Actions	Total Actions

Note: 25 action rows provided (vs GOV.UK's 10). Continue on additional sheets if required. All P1 and P2 actions should be addressed before the next review.

Section J: Review Schedule & Declaration

Step 5 of 5: Review at least annually, or sooner if there are significant changes to premises, occupancy, or legislation.

Overall Fire Risk Rating

☐ TRIVIAL

☐ TOLERABLE

☐ MODERATE

☐ SUBSTANTIAL

☐ INTOLERABLE

Assessment Review History

Date	Assessor	Type	Rating	Key Changes	Actions

Type: I = Initial, A = Annual Review, S = Significant Change, P = Post-Incident

Next Review Schedule

Next Review Due *

Frequency

☐ Annually

☐ 6-monthly

☐ Other:

⚠ Review Earlier: After building works, change of use/occupants, fire incident, near miss, or legislation changes.

Assessor Declaration

I confirm competence to carry out this FRA per PAS 79-1/79-2:2020 methodology and UK fire safety legislation. The Responsible Person is responsible for implementing recommendations.

Assessor Name

Qualifications

Competency (BS 8674:2025)

☐ Foundation

☐ Intermediate

☐ Advanced

Signature

Date

Responsible Person Acknowledgement

I acknowledge receipt of this FRA and my duties under the RR(FS)O 2005. I will ensure recommendations are implemented within specified timescales.

Name

Position

Signature

Date

Appendix A: Floor Plan Template

Instructions: Sketch or attach a floor plan showing escape routes, exits, equipment, and assembly points. Photocopy for each floor.

Floor / Level

Drawing Reference

Date

Symbol Legend

 Escape route  Fire exit  Extinguisher  Call point  Fire door  Emergency light  Detector  Assembly point

Floor Plan Drawing Area

Notes

Travel Distances (measure and record)

From Location	To Nearest Exit	Distance (m)

Max travel: 18m (one direction), 45m (alternative routes). Reduced for higher risk.

Appendix B: Photo Documentation Grid

Instructions: Use this template to attach photographic evidence of fire safety issues, defects, or compliance items. Photos provide valuable evidence and help track remediation. Photocopy as needed.

Photo 1 Location: Description: Date:	Photo 2 Location: Description: Date:	Photo 3 Location: Description: Date:
Photo 4 Location: Description: Date:	Photo 5 Location: Description: Date:	Photo 6 Location: Description: Date:
Photo 7 Location: Description: Date:	Photo 8 Location: Description: Date:	Photo 9 Location: Description: Date:
Photo 10 Location: Description: Date:	Photo 11 Location: Description: Date:	Photo 12 Location: Description: Date:

Appendix C: Personal Emergency Evacuation Plan (PEEP)

PEEP Requirement: Under the Fire Safety (England) Regulations 2022, Responsible Persons must prepare Residential PEEPs for residents needing evacuation assistance. **Mandatory from 6 April 2026.**

Individual Details

Full Name *

Flat/Unit Number *

Floor Level

Contact Telephone

Emergency Contact (Name & Number)

Nature of Evacuation Need

☐ Mobility impairment - wheelchair user

☐ Mobility impairment - walking difficulties (stick, frame, crutches)

☐ Visual impairment - blind or partially sighted

☐ Hearing impairment - deaf or hard of hearing

☐ Cognitive impairment (dementia, learning disability)

☐ Mental health condition affecting evacuation response

☐ Respiratory condition (may need rest during evacuation)

☐ Temporary condition (pregnancy, injury, surgery)

☐ Other:

Additional Details of Impairment/Condition

Evacuation Method

How will this person evacuate? *

☐ Unaided - can evacuate independently (perhaps slowly)

☐ With verbal guidance only

☐ With physical assistance (one person)

☐ With physical assistance (two people)

☐ Using evacuation chair (staff operated)

☐ Requires refuge and Fire & Rescue Service assistance

☐ Stay put / defend in place (with monitoring)

Specific Evacuation Route (if different from standard)

Equipment & Assistance Required

- ☐ Evacuation chair required ☐ Visual alarm/beacon in dwelling ☐ Vibrating pillow/pager alarm ☐ Refuge intercom access
- ☐ Pre-notification to Fire Service (Premises Information Box) ☐ Buddy system arranged
- ☐ Other: _____

Designated Buddy / Assistant (Name & Flat)

Information for Fire & Rescue Service

Key information Fire Service should know

Has this PEEP been shared with the local Fire Service?

- ☐ Yes - Date shared: _____ ☐ No - Not required / building not in scope

Agreement & Review

I have been consulted in the preparation of this PEEP and agree to the evacuation arrangements outlined above.

Individual's Signature

Prepared By

Review Date

Date

Review: PEEPs should be reviewed annually, or sooner if the individual's circumstances change, or if there are changes to the building's fire safety arrangements.

Appendix D: Property Type Guidance Notes

Purpose: Different property types have specific fire safety requirements. Use these guidance notes to ensure your assessment addresses the unique risks for your premises type.

Houses in Multiple Occupation (HMOs)

Definition: A property occupied by 3+ people from 2+ households sharing facilities. Licensable HMOs: 5+ people, 2+ households.

Key Requirement	Details
Fire Detection	Interlinked smoke/heat alarms on every floor (BS 5839-6 Grade D1 minimum). Mains-powered with battery backup. Heat detector in kitchen.
Escape Routes	Protected escape route from each letting room to final exit. 30-minute fire doors to all letting rooms and kitchens. Inner room arrangements require alternative escape.
Fire Doors	FD30S doors to all letting rooms, kitchens, and rooms opening onto escape routes. Self-closers, intumescent strips, smoke seals required.
Emergency Lighting	Required in escape routes for licensable HMOs. Battery-backed or self-contained luminaires.
Fire Extinguishers	Not mandatory in small HMOs but recommended. Fire blanket in shared kitchen.
Licensing	Mandatory licence required for 5+ occupants from 2+ households. Check for Additional/Selective licensing schemes in your area.

⚠ Common HMO Issues: Fire doors wedged open, missing self-closers, insufficient detection in individual rooms, no escape windows from basement rooms, overloaded electrical circuits.

Care Homes & Residential Care

Risk Level: HIGH - Sleeping risk with vulnerable occupants who may have mobility, sensory, or cognitive impairments.

Key Requirement	Details
Fire Detection	L1 system (BS 5839-1) with detection in ALL areas including bedrooms, corridors, roof voids. Staff alerting devices. Integration with nurse call where appropriate.
Evacuation Strategy	Progressive horizontal evacuation (PHE) preferred. Move residents to adjacent fire compartment rather than full building evacuation. Requires adequate compartmentation.
Staff Ratios	Sufficient trained staff to evacuate all residents. Night staffing levels critical. Consider residents requiring 2:1 assistance.
PEEPs	Personal Emergency Evacuation Plan required for EVERY resident. Review on admission and when needs change. Update care plans accordingly.
Compartmentation	30/60-minute compartmentation between bed areas. Sub-compartmentation of corridors. Fire-stopping to service penetrations critical.
Equipment	Evacuation chairs, ski sheets, evacuation mattresses as needed. Staff trained in use. Equipment accessible and maintained.

CQC Requirement: Care Quality Commission expects robust fire safety arrangements. FRA must be conducted by competent person (BS 8674 Intermediate/Advanced level recommended for care homes).

Offices & Commercial Premises

Risk Level: Generally LOW to MODERATE - Awake occupants familiar with premises. Higher risk if public access or complex layouts.

Key Requirement	Details
Fire Detection	L3 system minimum (BS 5839-1) - detection in escape routes. L2 for higher risk areas. Manual call points at exits.
Means of Escape	Travel distances: 18m (one direction), 45m (alternative routes). More than 60 persons requires 2+ exits. Width calculations based on occupancy.
Fire Wardens	Appointed fire wardens for each floor/zone. Trained in evacuation procedures, fire extinguisher use, and sweep duties.
Fire Drills	Minimum 6-monthly drills. Record evacuation times. Target: full evacuation within 2.5-3 minutes for most offices.
Electrical Safety	PAT testing for portable appliances. Fixed wiring inspection (EICR) every 5 years. Avoid overloaded extension leads.
Hot Desking/Hybrid	Consider variable occupancy. Ensure fire safety information provided to all staff including part-time/hybrid workers.

Warehouses & Industrial Premises

Risk Level: MODERATE to HIGH - Large volumes of combustible stock, high ceilings, complex operations.

Key Requirement	Details
Fire Detection	P1/P2 system for property protection. Consider beam detectors or aspirating systems for high ceilings. Manual call points at exits and along escape routes.
Sprinklers	May be required for insurance or where fire load is high. ESFR (Early Suppression Fast Response) for high-rack storage.
Storage & Racking	Maintain aisle widths for escape. Racking stability. Separation of incompatible materials. No storage in escape routes.
Forklift/Vehicle	Charging areas away from escape routes. LPG forklift cylinder storage external. Electric vehicle charging fire risk.
DSEAR	If flammable/explosive atmospheres present (solvents, dusts, gases), DSEAR assessment required in addition to FRA.
Fire Service Access	Access for fire appliances. Hydrants/dry risers for larger premises. Premises information box with site plan.

Restaurants, Pubs & Food Premises

Risk Level: MODERATE to HIGH - Cooking fire hazards, public occupancy, often complex layouts with multiple floors.

Key Requirement	Details
Kitchen Extract	Ductwork cleaned minimum 6-monthly (more frequent for high-volume cooking). Fire dampers in duct. Interlock with gas supply.
Suppression	Ansul or similar wet chemical suppression system over cooking ranges. Regular inspection and testing.
Means of Escape	Consider maximum licensed occupancy. Alternative exits required. Keep exits clear during service.
Fire Blankets	Fire blanket within 2m of cooking appliances. Staff trained in use. Wet chemical extinguisher (Class F).
Deep Fat Fryers	Thermostat and high-limit cut-out. Never move when hot. Safe oil disposal procedures.
Outdoor Areas	Patio heaters positioned safely. No smoking near exits. Gas bottle storage external and secure.

When to Use a Professional Assessor:

- Sleeping accommodation (HMOs, care homes, hotels)
- Buildings over 11m in height
- Complex layouts or mixed-use buildings
- Licensed premises or premises requiring certification
- Following enforcement action or fire incident

Contact **Firerisk.io**: 020 3051 1294 | Professional FRAs from £79

Appendix E: Fire Safety Legislation Quick Reference 2026

Purpose: This reference summarises key UK fire safety legislation as of 2026. Laws change frequently - always check current requirements at [legislation.gov.uk](https://www.legislation.gov.uk).

Primary Legislation

Legislation	Date	Key Requirements
Regulatory Reform (Fire Safety) Order 2005	2005 (amended 2021/2022)	- Primary fire safety law for non-domestic premises in England & Wales - Requires fire risk assessment by "responsible person" - Must implement general fire precautions - Applies to workplaces, common parts of residential buildings, HMOs
Fire Safety Act 2021	In force May 2022	- Clarifies FSO applies to structure, external walls, and flat entrance doors - Brings external wall systems (cladding) into scope of FSO - Flat entrance doors now must be assessed for fire safety - Applies to multi-occupied residential buildings
Fire Safety (England) Regulations 2022	Phased 2023-2026	Reg 3: Wayfinding signage in buildings 11m+ Reg 4-5: Fire door quarterly checks (communal), annual (flat doors - best endeavours) Reg 6: Lift operation information for Fire Service Reg 7: Premises Information Boxes in buildings 18m+ Reg 10: Fire safety information to residents Reg 11: Residential PEEPs - IN FORCE 6 APRIL 2026
Building Safety Act 2022	In force April 2023	- Creates "Higher-Risk Buildings" regime (18m+ or 7+ storeys residential) - Mandatory Building Safety Manager and safety case - Resident engagement requirements - Golden thread of building information - Accountable Person duties

Key British Standards (2025/2026 Updates)

Standard	Title	Application
BS 8674:2025	Fire Risk Assessor Competency	NEW 2025: Defines 3 competency levels for fire risk assessors: Foundation: Simple, single-occupancy premises Intermediate: Most commercial premises, HMOs, small care homes Advanced: Complex premises, tall buildings, large care homes
BS 9792:2025	FRA for Housing	NEW 2025: Updated methodology specifically for housing fire risk assessments. Replaces housing guidance in PAS 79-2.
PAS 79-1:2020	FRA for Commercial/Industrial	Fire risk assessment methodology for non-domestic premises. Guidance on scope, process, documentation, and competence.
PAS 79-2:2020	FRA for Housing	Fire risk assessment for housing including HMOs, purpose-built flats, sheltered housing. Being superseded by BS 9792:2025.
BS 5839-1:2024	Fire Detection - Non-Domestic	Design, installation, commissioning, and maintenance of fire detection and alarm systems. Defines L1-L5 and P1/P2 categories.
BS 5839-6:2019+A1:2020	Fire Detection - Dwellings	Fire detection for domestic premises and HMOs. Defines Grade A-F and LD1-LD3 categories. Interlinked alarm requirements.
BS 5266-1:2016	Emergency Lighting	Code of practice for emergency lighting. Testing requirements: monthly functional, annual full duration.
BS 9999:2017	Fire Safety in Buildings	Code of practice for fire safety in the design, management, and use of buildings. Alternative to Approved Document B.

Key Compliance Deadlines 2026

Deadline	Requirement	Who It Affects
6 April 2026	Residential PEEPs mandatory (Fire Safety Regulations, Reg 11)	Responsible Persons for residential buildings 11m+ must prepare PEEPs for residents who need evacuation assistance.
30 Sept 2026	Two staircases requirement (Approved Document B amendment)	New residential buildings 18m+ in height must have two staircases. Affects new-build planning applications.
Ongoing	Fire door quarterly checks	Buildings 11m+ must check communal fire doors quarterly. Already in force since Jan 2023.
Ongoing	Building Safety Regulator registration	Higher-risk buildings (18m+ or 7+ storeys) must register with BSR. Already in force since Oct 2023.

Penalties for Non-Compliance

Offence	Criminal Penalty	Civil Enforcement
Failure to carry out FRA	Unlimited fine	Enforcement Notice, Prohibition Notice
Failure to implement fire precautions	Unlimited fine and/or up to 2 years imprisonment	Alterations Notice, Enforcement Notice
Breach placing persons at serious risk	Unlimited fine and/or up to 2 years imprisonment	Prohibition Notice (immediate closure)
Causing death through gross negligence	Corporate manslaughter charges possible. Unlimited fine, imprisonment	-

Key Definitions

Responsible Person: The employer, or person in control of premises (owner, managing agent, landlord). Has duties under FSO Article 3. Competent Person: Person with sufficient training, experience, and knowledge to assist with fire safety measures. Now defined by BS 8674:2025 for FRAs. General Fire Precautions: Measures to reduce fire risk, protect escape routes, provide detection/warning, provide firefighting equipment, train staff.	Higher-Risk Building: Under BSA 2022: Residential building 18m+ or with 7+ storeys, containing at least 2 residential units. PEEP: Personal Emergency Evacuation Plan - individual plan for persons needing assistance to evacuate. Stay Put: Evacuation strategy for purpose-built flats where residents not directly affected by fire remain in their flat. Relies on compartmentation.
--	---

Official Resources

Fire Safety Order 2005 (as amended)	legislation.gov.uk/ukSI/2005/1541
Fire Safety Act 2021	legislation.gov.uk/ukpga/2021/24
Fire Safety (England) Regulations 2022	legislation.gov.uk/ukSI/2022/547
Building Safety Act 2022	legislation.gov.uk/ukpga/2022/30
GOV.UK Fire Safety Guidance	gov.uk/workplace-fire-safety-your-responsibilities
National Fire Chiefs Council	nationalfirechiefs.org.uk

Need Expert Help? Fire safety legislation is complex and constantly evolving. Firerisk.io certified assessors stay up-to-date with all regulatory changes. Call **020 3051 1294** for professional fire risk assessments from £79.