

MODBUS REGISTERS
Python Version 2.0 - 3/15/2023

XBEE SPI / MODBUS		UNADYN - DRYERS				CONAIR - DRYER
		FC	FD	FN	ADV	CD
READ	WRITE	XBEE SETUP				
40001	40001	Software Version				
40002	40002	SPI StationID				
40003	40003	SPI Baud Rate (1200, 2400, 4800, 9600, 19200)				
40004	40004	Model 0 (FC)	Model 1 (FD)	Model 2 (FN)	Model 3 (ADV)	Model 4 (CD)
40005	40005	RSSI				
40006	40006	Write Enable				
40007	40007	Board Temp				
40008	40008	Xbee Radio Voltage				
40009	40009	SPI CRC Error				
STANDARD SPI-IM DATA						
40010	40010	Process Setpoint				
40011	40011	Process Delta				
40012	40012	Process Temp				
40013	40013	Process Status				
40014	40014	Machine Status (0=Off / 1=On)				
40015	40015	Return Temp				
40016	40016	Dewpoint				
40017	40017	Dewpoint Trigger				
VENDOR / MODEL SPECIFIC DATA						
40018	40018	Regen Temp	Regen Temp	Regen Temp	Left Bed Heater	
40019	40019	Regen Outlet Temp	Regen Outlet Temp	Regen Outlet Temp	Left Bed Outlet	
40020	40020	Aux 1 Temp	Dryer Inlet Temp	Aux 1 Temp	Right Bed Heater	
40021	40021	Aux 2 Temp	Dryer Outlet Temp	Aux 2 Temp	Right Bed Outlet	
40022	40022		Process 2 Temp		Process 2 Temp	
40023	40023		Return 2 Temp		Return 2 Temp	
40024	40024		Inlet Temp			
40025	40025		Throat Temp			
40026	40026		Left Bed Temp			
40027	40027		Right Bed Temp			
40028	40028		Hopper 1 Temp			
40029	40029		Hopper 2 Temp			
40030	40030		Hopper 3 Temp			
40031	40031		Hopper 4 Temp			
40032	40032		Hopper 5 Temp			
40033	40033		Hopper6 Temp			
40034	40034		Process Dewpoint			
40035	40035		Return Dewpoint			
40036	40036		Process Airflow - CFM			
40037	40037		Process Airflow - FPM			
40038	40038		Pressure Sensor #1 - in. WC			
40039	40039		Pressure Sensor #2 - in. WC			
40040	40040		Pressure Sensor #3 - in. WC			
40041	40041		Analog Level Sensor			