








MAINTENANCE WORK INSTRUCTIONS

MAW154

Clean out filters on electrical panels

Rev: 0.2

Date 18/08/2025

| No. | INSTRUCTIONS | | KEY POINTS / CONTACTS |
|-----|---|--|--|
| 1. | Check out all humidifier filters. |  | <p>✚ ENSURE PERSONNAL PROTECTIVE EQUIPMENT (PPE) IS WORN: -</p> <ol style="list-style-type: none">1. HARD HAT2. STEEL CAP BOOTS3. EYE PROTCTION <p>ENSURE LOCK- OUTS AND SAFETY BLOCKS ARE USED AT ALL TIMES.</p> |
| 2. | Remove filter by lifting it up and out. If the filter is dirty, cut out new filters from material roll kept in the stores. |  |  |
| 3. | Lock out the filter and blow out any dust from components, Use a dusk mask. |  |  |

| | | | | |
|----------------|---------|--------------|-------|-------------|
| Controlled By: | QA DEPT | Approved By: | | Page 1 of 1 |
| Signature: | | Signature: | Date: | |

UNCONTROLLED WHEN PRINTED WITHOUT RED CONTROLLED STAMP & SIGNATURES