



VALUE INTEGRATOR






## MAINTENANCE WORK INSTRUCTIONS

MAW154

### Clean out filters on electrical panels

Rev: 0.0

Date 30/01/2009

No.	INSTRUCTIONS		KEY POINTS / CONTACTS
1.	Check out all humidifier filters.		<p>✚ ENSURE PERSONNAL PROTECTIVE EQUIPMENT (PPE) IS WORN: -</p> <ol style="list-style-type: none"> <li>1. HARD HAT</li> <li>2. STEEL CAP BOOTS</li> <li>3. EYE PROTCTION</li> </ol> <p><b>ENSURE LOCK- OUTS AND SAFETY BLOCKS ARE USED AT ALL TIMES.</b></p>
2.	<p>Remove filter by lifting it up and out.</p> <p>If the filter is dirty, cut out new filters from material roll kept in the stores.</p>		
3.	<p>Lock out the filter and blow out any dust from components,</p> <p>Use a dusk mask.</p>		

<b>Controlled By:</b>	<b>QA DEPT</b>	<b>Approved By:</b>		<b>Page 1 of 1</b>
<i>Signature:</i>		<i>Signature:</i>	<i>Date:</i>	

UNCONTROLLED WHEN PRINTED WITHOUT RED CONTROLLED STAMP & SIGNATURES