





No.	INSTRUCTIONS	KEY POINTS / CONTACTS
1.	<p>These checks are done on both electrical light panels for the two outside light circuits.</p> 	<p>+ ENSURE PERSONNAL PROTECTIVE EQUIPMENT (PPE) IS WORN: -</p> <ol style="list-style-type: none"> HARD HAT STEEL CAP BOOTS GLOVES <p>ENSURE LOCK- OUTS AND SAFETY BLOCKS ARE USED AT ALL TIMES.</p>
	<p>Insert the key and switch the switch to "exterior lights on. "</p> <p>Check all the lights in the circuit are working.</p> <p>Switch the switch back to "auto". The outside lights should stay on for a few seconds and then go off, indicating the day/night photo cell is working.</p> 	
	<p>The outside lights include the fluorescent lights under all the door awnings.</p> 	
	<p>Also included are the spot lights situated on the sides of the buildings.</p> 	

Controlled By:	QA DEPT	Approved By:		Page 1 of 1
<i>Signature:</i>	<i>Signature:</i>	<i>Date:</i>		