

SPC Analysis Report for Comp_Air_Totalized

Control Limits:

Center Line (CL): 7050.38

Upper Control Limit (UCL): 0.00

Lower Control Limit (LCL): 0.00

Process Capability:

Cp: 0.00

Cpk: -1.27

SPC Rules and Violations:

☐ Rule 1: Any point outside UCL/LCL

☐ Rule 2: 2 out of 3 consecutive points are on the same side and more than 2 standard deviations from the centerline

☐ Rule 3: 4 out of 5 consecutive points are on the same side and more than 1 standard deviation from the centerline

☐ Rule 4: 8 consecutive points are on the same side of the centerline