



## Residential New Building Permit Plan Review Comments

**Application:** PB25-12006

**Date Submitted:** 08/25/2025

**Status:** Issued

**Date Issued:** 09/24/2025

**Address:** 15949 DAUNTLESS COVE DR

**Parcel:** 101745

**Zoning:**

**Subdivision:** RIDGMAR ESTATES

**Lot/Block:** 12/1

**Description of Work:** Construction of new single-family residence  
3rd Party Plan Review & Inspections  
North Texas Inspection Services

**ADA TDLR:**

**Energy Code Compliant:**

**Applicant:** Stacie Hamby

**Owner:** PULTE HOME CORP OF TEXAS

8220 Clifford St

4800 REGENT BLVD STE 100

White Settlement, TX 76108

IRVING,, TX 75063-2439

8172467780

**Building Classification:**

| Occ Class | Const Type | Square Feet | Occ Load | Use Description    |
|-----------|------------|-------------|----------|--------------------|
| R-3       | VB         | 2425        | 12       | Living Area        |
| U         | VB         | 623         | 3        | Garage/Porch/Patio |

**Sprinkler Sys Req:**

**Comment:** Signs, Retaining Walls over 4', Fences, Dumpster Enclosures over 6', and Parkway Approaches and Sidewalks require separate permits and reviews.

**Required Corrections:**

**Building**

**Reviewer:** Stacie Hamby

**Email:** stacie@ntispros.com

**Phone:** (817) 246-7780

1.

Planning Development Department



## Residential New Building Permit Plan Review Comments

### Water

**Reviewer:** Shundalyn Evans

**Email:**

**Phone:**

1. 09/03/25 --CORRECTIONS REQUIRED-- Fees Due.

Water/sewer impact + reducer fees due. Contact Water Applications at 817-392-8250 or WaterApps@fortworthtexas.gov to provide proposed water meter and sewer information in addition to customer billing information.

### \*\*\*NOTE\*\*\*

It is the responsibility of the builder to uncover the water and sewer services. Water service must be exposed before meter can be set.

### Approval Table:

| Task Name                    | Task Status                  | Completed Date | Task Rev Name           |
|------------------------------|------------------------------|----------------|-------------------------|
| Application Submittal        | Routed for Electronic Review | 08/26/2025     | Jasmine Lujan           |
| Water Development Review     | Approved                     | 09/23/2025     | Elizabeth Armendariz    |
| Transportation Impact Review | Not Required                 | 08/27/2025     | Lamonica Smith          |
| Urban Forestry Review        | Approved                     | 09/05/2025     | Marilyn Hernandez Ayala |
| Zoning Review                | Approved                     | 09/05/2025     | Marilyn Hernandez Ayala |
| PARD Review                  | Not Required                 | 08/27/2025     | Germaine Joseph         |
| Building Plan Review         | Approved                     | 09/03/2025     | Jim West                |
| Issue Permit                 | Issued                       | 09/24/2025     | Patricia Martinez       |
| Inspections                  |                              |                |                         |
| Mechanical Plan Review       | Approved                     | 08/26/2025     | Jasmine Lujan           |
| Plumbing Plan Review         | Approved                     | 08/26/2025     | Jasmine Lujan           |
| Electrical Plan Review       | Approved                     | 08/26/2025     | Jasmine Lujan           |
| Plan Distribution            | Routed for Electronic Review | 09/23/2025     | Elizabeth Armendariz    |
| Plans Coordination           | Approved                     | 09/23/2025     | Marilyn Hernandez Ayala |
| TPW CFRA Review              | Not Required                 | 09/05/2025     | Robin Stevens           |

### General Comments and Additional Permit Information:

Planning Development Department



## Residential New Building Permit Plan Review Comments

**Reviewer: Marilyn Hernandez Ayala**  
**Email: Marilyn.HernandezAyala@fortworthtexas.gov**  
**Phone: 817-392-2827**

### 1 Zoning Plans Exam

Residential Zoning Review Notes PB25-12006 – 15949 DAUNTLESS COVE DR  
Planning and Development Department PLAN #: Thomaston 2473 E L  
Zoning Review Notes: All reviews are pending stakeout inspection  
Alpha Ranch MUD Development Agreement Co. 48650  
Permit data confirmed on: 09/05/2025  
By: Marilyn A. Hernandez Ayala [817-392-2827]

Scope of project: New SFR

Plan Review Contact: Jim West (North Texas)

HOLD NOTES: All items labeled "HOLD" must be addressed

SUMMARY: Permit meets minimum standards Y

Holds: \_\_\_\_

Zoning district: "MUD built to - A-5" Type of layout: Single Family Residence

Official Plat: Attached to plans lot/block number verified Y (Elizabeth Creek Alpha Ranch  
Blk 13 Lt 17) FP-24-054 Approved 11/1/2024

Building Square footage: R-3: 2425 U: 623

Slab SF: 2187

Lot Area: 6360

Lot coverage: 50% maximum, including all structures (Provided \_34%)

Height: 35' maximum (Provided \_23' 3¼")

Lot Width: 50' minimum at building line (Provided 53')

Front yard driveway coverage: 50% maximum, circular drives shall not exceed 65%  
maximum coverage (Provided \_34%\_)

Setback restrictions: (The front yard setback in residential districts shall be the greatest of:  
The platted building line; The setback for the applicable zoning district; or the setback of  
the nearest building on either side that is the closest to the street, up to a maximum  
setback of 50 feet, provided that said setback is not the result of a variance granted by the  
Board of Adjustment)

Front: 20' minimum (provided \_20' 3")

Houses on either side: \_L\_ Vacant\_ / \_R – 20'\_ per 3rd party site plan (verify on aerial  
photo)

Sides: 5' minimum (Provided 7' 1" \_ & \_7' 2" \_)

Planning Development Department



## Residential New Building Permit Plan Review Comments

Rear: 5' minimum (Provided 41' 3")

Note: As applicable, any fence located within an easement will require permission of the easement holder(s) to encroach.

### Parking spaces:

Ord. 21528 Single Family Home: Two spaces located behind the front building wall for dwelling units with three or fewer bedrooms, plus one space located behind the front building wall or in the driveway for each bedroom above three.

# Bedrooms: 4 Parking spaces required 3 provided 4.

Required parking spaces must be hard surface and dust free (asphalt or concrete). All maneuvering space must be located off of the public right of way.

A sidewalk is required for all frontages facing a street

<http://fortworthtexas.gov/planninganddevelopment/permits/streets/> .

Urban Forestry: UFC18-0293 (see attached).

One (1) Large Canopy and One (1) Medium Canopy Trees to be Planted per residential lot between

5,000 sq. ft. and 9,999 sq. ft.

Two (2) Large Canopy and One (1) Medium Canopy Trees to be Planted per residential lot between 10,000 sq. ft. and 14,999 sq. ft.

Also identified in Section 3.09 of the agreement (see below)

3.09 Landscape Requirements. At minimum, the following shall be installed on each residential lot prior to initial-occupancy:

- (1) 3-inch caliper tree planted in front of each house with a 2nd 3-inch caliper tree located anywhere on the lot per the homeowner/builder,
- Shrubs shall be provided in any size increments totaling 25 gallons on each residential lot, and
- The front and side yards of each residential lot shall be fully sodded.
- Freeze and rain sensors shall be installed in all irrigation systems in front and side yards.

       NOTES MAY BE PROVIDED ON THE SITE PLAN INDICATING THESE ITEMS WILL BE PROVIDED

(Check this line if the notes were provided on plans)

### Additional Comments:

Sec. 22-176. Curb cuts and laid-down curb permit procedures.

The location of ingress and egress driveways shall be subject to approval of the city traffic engineer under curb cut or laid-down curb permit procedures. Driveways shall not exceed sixty-five (65) per cent of the property frontage. There shall be a minimum of twenty (20) feet of curb along the street between driveways where there is more than one driveway on property under unified ownership or control and used as one premise. The decision of the city traffic engineer may be appealed to the city council. (Code 1964, § 26-102.3; Ord. No.

Planning Development Department

8288, § 1, 3-10-81)

**SINGLE FAMILY HOME: DWELLING UNIT:** A building, or any portion thereof, containing a complete set of independent living facilities for occupancy and use by one family, including permanent provisions for living, sleeping, eating, sanitation, and cooking within a kitchen for the exclusive use of the occupants whose intent is to inhabit the dwelling unit.

**COOKING EQUIPMENT:** A stove, range or other such appliances, which requires a 220V or gas connection that is used, designed, or intended to be used for the cook and preparing of food.

A sidewalk is required for all frontages facing a street  
<http://fortworthtexas.gov/planninganddevelopment/permits/streets/>

Planning Development Department

---

The City of Fort Worth \* 100 Fort Worth Trail \* Fort Worth, TX, 76102  
817-392-2222 \* Fax 817-392-8105