



## Residential New Building Permit Plan Review Comments

**Application:** PB25-11615

**Date Submitted:** 08/15/2025

**Status:** Issued

**Date Issued:** 09/05/2025

**Address:** 633 BUNCHBERRY ST

**Parcel:** 1578854

**Zoning:**

**Subdivision:** TRADITION

**Lot/Block:** 18/VVV

**Description of Work:** New Single Family Residence w/3rd Party Review and Inspections

**ADA TDLR:**

**Energy Code Compliant:**

**Applicant:** Adriana Perez

**Owner:** CITY OF FORT WORTH

100 E 15th St 100

100 FORT WORTH TRL

Fort Worth, TX 76102

FORT WORTH, TX 76102-6312

9722446925

**Building Classification:**

Occ Class	Const Type	Square Feet	Occ Load	Use Description
R-3	VB	2932		Living Space
U	VB	799		Utilities

**Sprinkler Sys Req:**

**Comment:** Signs, Retaining Walls over 4', Fences, Dumpster Enclosures over 6', and Parkway Approaches and Sidewalks require separate permits and reviews.

**Required Corrections:**

Planning Development Department



## Residential New Building Permit Plan Review Comments

### **Building**

**Reviewer: Adriana Perez**

**Email: Adriana.A.Perez@BureauVeritas.com**

**Phone: 682-227-7436**

**1. Bureau Veritas Zoning Notes:**

Address: 633 Bunchberry St

Lot coverage: 42.6% (not over 50%)

Height: 32'-0 3/8"

Lot width at build line over 50': 60'

Verified driveway does not exceed more than 50% of front yard: 30%

(Measured from front wall of house to front property line)

Provided front yard setback: 20'-3"

Provided side yard setback L: 5'-0 1/2" R: 5'-0 1/2"

Provided rear yard setback: 37'-10"

Number of bedrooms: 4

Parking spaces (9' x18') provided: 3 in Garage, 2 Driveway

(Requirements: 3 bdrms=2; 4 bdrms=3; 5 bdrms= 4; 6 bdrms=5)

Houses on either side: Left: 20'-3" Right: 20'-3"

Masonry Requirements:

(Masonry is considered brick, stone, cementitious fiber concrete products or stucco)

Over 50% on all sides? yes

Trees shown on plot plan: 2

### **Approval Table:**

Task Name	Task Status	Completed Date	Task Rev Name
Application Submittal	Routed for Electronic Review	08/18/2025	Sonia Rios
Water Development Review	Approved	08/22/2025	Elizabeth Armendariz
Transportation Impact Review	Not Required	08/23/2025	Lamonica Smith
Urban Forestry Review	Approved	08/25/2025	Jesus Olmos
Zoning Review	Approved	08/25/2025	Jesus Olmos
PARD Review	Not Required	08/18/2025	Germaine Joseph
Building Plan Review	Approved	09/04/2025	3PTY BUREAU VERITAS
Issue Permit	Issued	09/05/2025	Patricia Martinez
Inspections			
Mechanical Plan Review	Approved	08/25/2025	3PTY BUREAU VERITAS
Plumbing Plan Review	Approved	09/04/2025	3PTY BUREAU VERITAS

Planning Development Department



## Residential New Building Permit Plan Review Comments

Electrical Plan Review	Approved	09/04/2025	3PTY BUREAU VERITAS
Plan Distribution	Routed for Electronic Review	09/04/2025	Jesus Olmos
Plans Coordination	Approved	09/04/2025	Jesus Olmos
TPW CFRA Review	Not Required	08/27/2025	Robin Stevens

### General Comments and Additional Permit Information:

**Reviewer: Jesus Olmos**

**Email: Jesus.Olmos@fortworthtexas.gov**

**Phone:**

#### 1 Zoning Plans Exam

Residential Zoning Review Notes PB25-11615 – 633 BUNCHBERYY ST  
Planning and Development Department Plan #: D5026 TT L  
Zoning Review Notes: All reviews are pending stakeout inspection  
Tradition Development Agreement Contract  
Permit data confirmed on: 08/25/2025  
By: Jesus Olmos Jr. [817-392-7858]

Scope of project: New SFR Build to standards: "MUD to A-5"  
HOLD NOTES: All items labeled "HOLD" must be addressed  
Zoning district MUD built to: \_Y\_ A-5  
\_\_\_ A-7.5  
\_\_\_ A-10

Official Plat: attached to plans lot/block number verified Y (Tradition Blk\_VVV\_Lt\_18\_)  
FP-23-155 approved/filed 9/24/2024

Building Square footage: \_R3:\_2932 U:\_823  
Slab SF: 3147  
Lot Area SF: 7380

Lot coverage: including all structures \_43%\_ A-5 no more than 50%  
\_\_\_%\_ A-7.5 no more than 45%  
\_\_\_%\_ A-10 no more than 40%

Height: 35' maximum (Provided \_32' 0 3/8")

Lot Width: \_60'\_ A-5 minimum 50 ft. at building line  
\_\_\_' A-7.5 minimum 55 ft. at building line  
\_\_\_' A-10 minimum 60 ft. at building line

Front yard driveway coverage: 50% maximum (\_30%)

Setback restrictions: (The front yard setback in residential districts shall be the greatest of:  
The platted building line; The setback for the applicable zoning district; or the setback of

Planning Development Department



## Residential New Building Permit Plan Review Comments

the nearest building on either side that is the closest to the street, up to a maximum setback of 50 feet, provided that said setback is not the result of a variance granted by the Board of Adjustment)

Front: A-5 & A-7.5: 20' minimum (Provided 20' 3")

A-10: 25' minimum (Provided ')

Houses on either side: left: 20' 3" ft. right: 20' 3" ft. per 3rd party site plan (verify on aerial photo)

Sides: 5' minimum, 10' on corner lots (Provided 5' 0½" & 5' 0½")

Rear: A-5 & A-7.5 5' minimum (Provided 37' 10")

A-10 10' minimum (Provided ')

Note: As applicable, any fence located within an easement will require permission of the easement holder(s) to encroach.

### Parking spaces:

Ord. 21528 Single Family Home: Two spaces located behind the front building wall for dwelling units with three or fewer bedrooms, plus one space located behind the front building wall or in the driveway for each bedroom above three. # bedrooms: 4 # parking spaces required 3 provided 5

Required parking spaces must be hard surface and dust free (asphalt or concrete). All maneuvering space must be located off of the public right of way.

Urban Forestry: Section 6.302 per Section 6.507(d) is not applicable to this MUD. See MUD Agreement.

### Single Family Design Standards:

The same elevation shall not be permitted within an eight-lot pattern, on an adjacent lot or on a lot directly across the street. Provided and correct? Y

No attached garage facing a public or private street may project greater than eight (8) feet in front of the front wall of the house in all Single-Family Districts. Complies? Y

### Additional Comments:

Sec. 22-176. Curb cuts and laid-down curb permit procedures.

The location of ingress and egress driveways shall be subject to approval of the city traffic engineer under curb cut or laid-down curb permit procedures. Driveways shall not exceed sixty-five (65) per cent of the property frontage. There shall be a minimum of twenty (20) feet of curb along the street between driveways where there is more than one driveway on property under unified ownership or control and used as one premise. The decision of the city traffic engineer may be appealed to the city council. (Code 1964, § 26-102.3; Ord. No. 8288, § 1, 3-10-81)

SINGLE FAMILY HOME: DWELLING UNIT: A building, or any portion thereof, containing a complete set of independent living facilities for occupancy and use by one family, including permanent provisions for living, sleeping, eating, sanitation and cooking within a

Planning Development Department

kitchen for the exclusive use of the occupants whose intent is to inhabit the dwelling unit.

**COOKING EQUIPMENT:** A stove, range or other such appliances, which requires a 220V or gas connection that is used, designed, or intended to be used for the cook and preparing of food.

A sidewalk is required for all frontages facing a street

<http://fortworthtexas.gov/planninganddevelopment/permits/streets/>

Planning Development Department

---

The City of Fort Worth \* 100 Fort Worth Trail \* Fort Worth, TX, 76102  
817-392-2222 \* Fax 817-392-8105