



Residential New Building Permit Plan Review Comments

Application: PB25-16573

Date Submitted: 12/02/2025

Status: Issued

Date Issued: 12/10/2025

Address: 17149 OXBOROUGH DR

Parcel: 1662318

Zoning:

Subdivision:

Lot/Block: 3/0000

Description of Work: New Single Family Residence w/3rd Party Review and Inspections

ADA TDLR:

Energy Code Compliant:

Applicant: Adriana Perez

Owner: CITY OF FORT WORTH

100 E 15th St 630

100 FORT WORTH TRL

Fort Worth, TX 76102

FORT WORTH, TX 76102-6312

9722446925

Building Classification:

Occ Class	Const Type	Square Feet	Occ Load	Use Description
R-3	VB	3201	16	Living Space
U	VB	594	3	Utilities

Sprinkler Sys Req:

Comment: Signs, Retaining Walls over 4', Fences, Dumpster Enclosures over 6', and Parkway Approaches and Sidewalks require separate permits and reviews.

Required Corrections:

Planning Development Department



Residential New Building Permit Plan Review Comments

Building

Reviewer: Adriana Perez

Email: Adriana.A.Perez@BureauVeritas.com

Phone: 682-227-7436

1. Bureau Veritas Zoning Notes:

Address: 17149 Oxborough Dr

Lot coverage: 46.01% (not over 50%)

Height: 29'-10 3/8"

Lot width at build line over 50': 54.87'

Verified driveway does not exceed more than 50% of front
yard: 33.46%

(Measured from front wall of house to front property line)

Provided front yard setback: 20'-3"

Provided side yard setback L: 5'-5 1/2" R: 5'-7"

Provided rear yard setback: 24'-10 3/4"

Number of bedrooms: 4

Parking spaces (9' x18') provided: 2 in Garage, 2 Driveway

(Requirements: 3 bdrms=2; 4 bdrms=3; 5 bdrms= 4; 6 bdrms=5)

Houses on either side: Left: 20.5' Right: vacant

Masonry Requirements:

(Masonry is considered brick, stone, cementitious fiber concrete products or stucco)

Over 50% on all sides? yes

Trees shown on plot plan: 2

Approval Table:

Task Name	Task Status	Completed Date	Task Rev Name
Application Submittal	Routed for Electronic Review	12/03/2025	Joseph Sigmon
Water Development Review	Approved	12/10/2025	Ibeth Heatley
Transportation Impact Review	Not Required	12/05/2025	Lamonica Smith
Urban Forestry Review	Approved	12/03/2025	Scott Edwardson
Zoning Review	Approved	12/03/2025	Scott Edwardson
PARD Review	Not Required	12/03/2025	Germaine Joseph
Building Plan Review	Approved	12/03/2025	3PTY BUREAU VERITAS
Issue Permit	Issued	12/10/2025	Patricia Martinez
Inspections			
Mechanical Plan Review	Approved	12/03/2025	Joseph Sigmon
Plumbing Plan Review	Approved	12/03/2025	Joseph Sigmon

Planning Development Department



Residential New Building Permit Plan Review Comments

Electrical Plan Review	Approved	12/03/2025	Joseph Sigmon
Plan Distribution	Routed for Electronic Review	12/08/2025	Scott Edwardson
Plans Coordination	Approved	12/10/2025	Scott Edwardson

General Comments and Additional Permit Information:

Reviewer: Scott Edwardson
Email: Scott.Edwardson@fortworthtexas.gov
Phone: (817) 392-6288

2 Zoning Plans Exam

Residential Zoning Review Notes
Oxborough Dr.
Planning and Development Department
R

PB25-16573 | 17149

Plan# D4031 TT

Zoning Review Notes: All reviews are pending stakeout inspection
CFW Zoning Ordinance # 13896-19602

Permit data confirmed on: 12/3/2025
By: Scott Edwardson [(817)392-6288]

Scope of project: SFR

HOLD NOTES: All items labeled "HOLD" must be addressed

SUMMARY: Permit meets minimum standards Y
Holds: ____

Zoning district: "MUD to A-5" Type of layout: Single-Family Residence

Official Plat: Attached to plans Block OOOO / Lot 3 number verified Y
Tradition Phase 8A FP-24-124 – Filing Date: 09/05/2025

Building Square footage: R-3: 3201 U: 594
Slab SF: 2893
Lot Size: 6288
Lot coverage: 50% maximum, including all structures (Provided 46.01%)

Height: 35' maximum (Provided 29.86')

Lot Width: 50' minimum at building line (Provided 54.87')

Front yard driveway coverage: 50% maximum (Provided 33.46%)

Setback restrictions: (The front yard setback in residential districts shall be the greatest of:
The platted building line; The setback for the applicable zoning district; or the setback of

Planning Development Department



Residential New Building Permit Plan Review Comments

the nearest building on either side that is the closest to the street, up to a maximum setback of 50 feet, provided that said setback is not the result of a variance granted by the Board of Adjustment)

Front: 20' minimum (Provided 20.25')

Houses on either side: Left: Vacant/ Right: Vacant per 3rd party site plan (verify on aerial photo)

Sides: 5' minimum (Provided Left: 5.46' / Right: 5.58')

Rear: 5' minimum (Provided 24.90')

Note: As applicable, any fence located within an easement will require permission of the easement holder(s) to encroach.

Parking spaces:

Ord. 21528 Single Family Home: Two spaces located behind the front building wall for dwelling units with three or fewer bedrooms, plus one space located behind the front building wall or in the driveway for each bedroom above three.

Bedrooms: 4 Parking spaces required 3 provided 4

Required parking spaces must be hard surface and dust free (asphalt or concrete). All maneuvering space must be located off of the public right of way.

Urban Forestry: property is vested, infill or UFC: (Vesting letter or UFC # EXEMPT Article II Section 2.01 of the Development Agreement for the Tradition Municipal Utility District (MUD) states that Sections 6.300 and 6.301 (Landscaping and Buffers) of the Zoning Ordinance are applicable to the development within the MUD. Section 6.302, (Urban Forestry) is not applicable within the MUD.

An infill house shall be required to have a minimum 3" caliper front yard tree of choice, and one minimum 3" caliper street parkway tree as approved by the City Forester.

Single Family Design Standards:

The same elevation shall not be permitted within a six lot pattern, on an adjacent lot or on a lot directly across the street.

Exterior walls shall consist of a minimum of 50% masonry. Exposures to a minor arterial or wider street shall require 100% masonry construction except where such building face is obscured by a minimum six (6) foot masonry wall. "Masonry" shall include brick, stone, cementitious fiber concrete products or stucco. Similar products made from such materials and/or durable recycled material shall be allowed as approved by the Building Official.

No attached garage facing a public or private street may project greater than eight (8) feet in front of the front wall of the house in all Single-Family Districts.

Additional Comments:

Sec. 22-176. Curb cuts and laid-down curb permit procedures.

Planning Development Department

The location of ingress and egress driveways shall be subject to approval of the city traffic engineer under curb cut or laid-down curb permit procedures. Driveways shall not exceed sixty-five (65) per cent of the property frontage. There shall be a minimum of twenty (20) feet of curb along the street between driveways where there is more than one driveway on property under unified ownership or control and used as one premise. The decision of the city traffic engineer may be appealed to the city council. (Code 1964, § 26-102.3; Ord. No. 8288, § 1, 3-10-81)

SINGLE FAMILY HOME: DWELLING UNIT: A building, or any portion thereof, containing a complete set of independent living facilities for occupancy and use by one family, including permanent provisions for living, sleeping, eating, sanitation, and cooking within a kitchen for the exclusive use of the occupants whose intent is to inhabit the dwelling unit.

COOKING EQUIPMENT: A stove, range or other such appliances, which requires a 220V or gas connection that is used, designed, or intended to be used for the cook and preparing of food.

A sidewalk is required for all frontages facing a street
<http://fortworthtexas.gov/planninganddevelopment/permits/streets/>

Reviewer: Ibeth Heatley
Email: Ibeth.Heatley@fortworthtexas.gov
Phone:

1 WATER APPLICATIONS

*** IMPORTANT*** PLEASE READ WATER AND SEWER SERVICE LOCATION REQUIREMENTS ***

Sec 5.18.2.1 Meter boxes can only be installed in non-paved areas. Water service and meter box must be installed 1-foot offset from the property line in the parkway and have a 9-foot horizontal separation from the sewer service. The normal location for meter boxes is 2.5 feet behind the back of curb.

In no case shall the water meter box (and meter) be outside of the public right-of-way or water easement.

Sec 6.4.1.3 Wastewater service should avoid placement in driveways and have a 9-foot horizontal separation from the water service.

Service should be installed South or West of the proposed driveway location.

To prevent delays for a meter set, ensure the following criteria is met:

- Address must be clearly posted, i.e., visible and big enough to see
- No debris or material over the meter box
- Meter box must be in the ground to grade per city specification

Planning Development Department