



Residential New Building Permit Plan Review Comments

Application: PB25-10754

Date Submitted: 07/28/2025

Status: Finaled

Date Issued: 08/13/2025

Address: 1456 INDIAN MALLOW LN

Parcel: 1593607

Zoning:

Subdivision: TRADITION

Lot/Block: 15/PPP

Description of Work: New Single Family Residence w/3rd Party Review and Inspections

ADA TDLR:

Energy Code Compliant:

Applicant: Adriana Perez

Owner: CITY OF FORT WORTH

100 E 15th St 100

100 FORT WORTH TRL

Fort Worth, TX 76102

FORT WORTH, TX 76102-6312

9722446925

Building Classification:

| Occ Class | Const Type | Square Feet | Occ Load | Use Description |
|-----------|------------|-------------|----------|-----------------|
| R-3 | VB | 1858 | | Living Space |
| U | VB | 584 | | Utilities |

Sprinkler Sys Req:

Comment: Signs, Retaining Walls over 4', Fences, Dumpster Enclosures over 6', and Parkway Approaches and Sidewalks require separate permits and reviews.

Required Corrections:

Planning Development Department



Residential New Building Permit Plan Review Comments

Building

Reviewer: Adriana Perez

Email: Adriana.A.Perez@BureauVeritas.com

Phone: 682-227-7436

1. Bureau Veritas Zoning Notes:

Address: 1456 Indian Mallow Ln

Lot coverage: 43.39% (not over 50%)

Height: 21'-6 1/4"

Lot width at build line over 50': 50.50'

Verified driveway does not exceed more than 50% of front
yard: 35.64%

(Measured from front wall of house to front property line)

Provided front yard setback: 20'-3"

Provided side yard setback L: 5'-0" R: 5'-7"

Provided rear yard setback: 39'-3 1/2"

Number of bedrooms: 4

Parking spaces (9' x 18') provided: 2 in Garage, 2 Driveway

(Requirements: 3 bdrms=2; 4 bdrms=3; 5 bdrms= 4; 6 bdrms=5)

Houses on either side: Left: 20' Right: 20'

Masonry Requirements:

(Masonry is considered brick, stone, cementitious fiber concrete products or stucco)

Over 50% on all sides? yes

Trees shown on plot plan: 2

Approval Table:

| Task Name | Task Status | Completed Date | Task Rev Name |
|------------------------------|------------------------------|----------------|----------------------|
| Application Submittal | Routed for Electronic Review | 07/29/2025 | Jasmine Lujan |
| Water Development Review | Approved | 08/12/2025 | Elizabeth Armendariz |
| Transportation Impact Review | Not Required | 08/01/2025 | Lamonica Smith |
| Urban Forestry Review | Approved | 08/06/2025 | Gustavo Ramirez |
| Zoning Review | Approved | 08/06/2025 | Gustavo Ramirez |
| PARD Review | Not Required | 07/30/2025 | Germaine Joseph |
| Building Plan Review | Approved | 08/06/2025 | 3PTY BUREAU VERITAS |
| Issue Permit | Issued | 08/13/2025 | Patricia Martinez |
| Inspections | Finald | 11/14/2025 | Karleen Cortez |
| Closed | Close | 11/14/2025 | Karleen Cortez |
| Mechanical Plan Review | Approved | 08/06/2025 | 3PTY BUREAU VERITAS |

Planning Development Department



Residential New Building Permit Plan Review Comments

| | | | |
|------------------------|------------------------------|------------|----------------------|
| Plumbing Plan Review | Approved | 08/06/2025 | 3PTY BUREAU VERITAS |
| Electrical Plan Review | Approved | 08/06/2025 | 3PTY BUREAU VERITAS |
| Plan Distribution | Routed for Electronic Review | 08/12/2025 | Elizabeth Armendariz |
| Plans Coordination | Approved | 08/12/2025 | Gustavo Ramirez |
| TPW CFRA Review | Not Required | 08/07/2025 | Robin Stevens |

General Comments and Additional Permit Information:

Reviewer: Gustavo Ramirez
Email: Gustavo.Ramirez@fortworthtexas.gov
Phone:

1 Zoning Plans Exam

Residential Zoning Review Notes PB25-10754 – 1456 INDIAN MALLOW LN
Planning and Development Department Plan #: 1614 TD L
Zoning Review Notes: All reviews are pending stakeout inspection
Tradition Development Agreement Contract
Permit data confirmed on: 08/06/2025
By: Gustavo Ramirez [817-392-7849]

Scope of project: New SFR Build to standards: "MUD to A-5"

HOLD NOTES: All items labeled "HOLD" must be addressed

Zoning district MUD built to: _Y_A-5

___ A-7.5

___ A-10

Official Plat: attached to plans lot/block number verified Y (Tradition Block_PPP_Lot_15_)
FP-22-133 approved/filed 12/09/2024

Building Square footage: _R3:_1858 U:_584

Slab SF: 2520

Lot Area SF: 5807

Lot coverage: including all structures _43.39%_ A-5 no more than 50%

___%_ A-7.5 no more than 45%

___%_ A-10 no more than 40%

Height: 35' maximum (Provided _21.52')

Lot Width: _50.50'_ _A-5 minimum 50 ft. at building line

___' _A-7.5 minimum 55 ft. at building line

___' _A-10 minimum 60 ft. at building line

Front yard driveway coverage: 50% maximum (_35.64%)

Setback restrictions: (The front yard setback in residential districts shall be the greatest of:

Planning Development Department



Residential New Building Permit Plan Review Comments

The platted building line; The setback for the applicable zoning district; or the setback of the nearest building on either side that is the closest to the street, up to a maximum setback of 50 feet, provided that said setback is not the result of a variance granted by the Board of Adjustment)

Front: A-5 & A-7.5: 20' minimum (Provided 20.25')

A-10: 25' minimum (Provided)

Houses on either side: left: 20' ft. right: 20' ft. per 3rd party site plan (verify on aerial photo)

Sides: 5' minimum, 10' on corner lots (Provided 5' & 5.58')

Rear: A-5 & A-7.5 5' minimum (Provided 30.29')

A-10 10' minimum (Provided)

Note: As applicable, any fence located within an easement will require permission of the easement holder(s) to encroach.

Parking spaces:

Ord. 21528 Single Family Home: Two spaces located behind the front building wall for dwelling units with three or fewer bedrooms, plus one space located behind the front building wall or in the driveway for each bedroom above three. # bedrooms: 4 # parking spaces required 3 provided 4

Required parking spaces must be hard surface and dust free (asphalt or concrete). All maneuvering space must be located off of the public right of way.

Urban Forestry: Section 6.302 per Section 6.507(d) is not applicable to this MUD. See MUD Agreement.

Single Family Design Standards:

The same elevation shall not be permitted within an eight-lot pattern, on an adjacent lot or on a lot directly across the street. Provided and correct? Y

No attached garage facing a public or private street may project greater than eight (8) feet in front of the front wall of the house in all Single-Family Districts. Complies? Y

Additional Comments:

Sec. 22-176. Curb cuts and laid-down curb permit procedures.

The location of ingress and egress driveways shall be subject to approval of the city traffic engineer under curb cut or laid-down curb permit procedures. Driveways shall not exceed sixty-five (65) per cent of the property frontage. There shall be a minimum of twenty (20) feet of curb along the street between driveways where there is more than one driveway on property under unified ownership or control and used as one premise. The decision of the city traffic engineer may be appealed to the city council. (Code 1964, § 26-102.3; Ord. No. 8288, § 1, 3-10-81)

SINGLE FAMILY HOME: DWELLING UNIT: A building, or any portion thereof, containing a complete set of independent living facilities for occupancy and use by one family,

Planning Development Department

including permanent provisions for living, sleeping, eating, sanitation and cooking within a kitchen for the exclusive use of the occupants whose intent is to inhabit the dwelling unit.

COOKING EQUIPMENT: A stove, range or other such appliances, which requires a 220V or gas connection that is used, designed, or intended to be used for the cook and preparing of food.

A sidewalk is required for all frontages facing a street

<http://fortworthtexas.gov/planninganddevelopment/permits/streets/>

Reviewer: Elizabeth Armendariz

Email: WaterApps@FortWorthTexas.gov

Phone: 817-392-8250

2 WATER APPLICATIONS

*** IMPORTANT*** PLEASE READ WATER AND SEWER SERVICE LOCATION REQUIREMENTS ***

Sec 5.18.2.1 Meter boxes can only be installed in non-paved areas. Water service and meter box must be installed 1-foot offset from the property line in the parkway and have a 9-foot horizontal separation from the sewer service. The normal location for meter boxes is 2.5 feet behind the back of curb.

In no case shall the water meter box (and meter) be outside of the public right-of-way or water easement.

Sec 6.4.1.3 Wastewater service should avoid placement in driveways and have a 9-foot horizontal separation from the water service.

Service should be installed South or West of the proposed driveway location.

To prevent delays for a meter set, ensure the following criteria is met:

- Address must be clearly posted, i.e., visible and big enough to see
- No debris or material over the meter box
- Meter box must be in the ground to grade per city specification

Planning Development Department