



Residential New Building Permit Plan Review Comments

Application: PB25-12720

Date Submitted: 09/09/2025

Status: Issued

Date Issued: 09/26/2025

Address: 225 EC TALLY DR

Parcel: 1644871

Zoning:

Subdivision: LONE STAR AT LIBERTY TRAILS
PHASE 1

Lot/Block: 2/3

Description of Work: Construction of new single-family residence
3rd Party Plan Review & Inspections
North Texas Inspection Services

ADA TDLR:

Energy Code Compliant:

Applicant: Stacie Hamby

Owner: FORESTAR (USA) REAL ESTATE GRO

8220 Clifford St

2221 E LAMAR BLVD STE 790

White Settlement, TX 76108

ARLINGTON,, TX 76006

8172467780

Building Classification:

Occ Class	Const Type	Square Feet	Occ Load	Use Description
R-3	VB	2045	10	Living Area
U	VB	613	3	Garage/Porch/Patio

Sprinkler Sys Req:

Comment: Signs, Retaining Walls over 4', Fences, Dumpster Enclosures over 6', and Parkway Approaches and Sidewalks require separate permits and reviews.

Required Corrections:

Building

Reviewer: Stacie Hamby

Email: stacie@ntispros.com

Phone: (817) 246-7780

1.

Planning Development Department



Residential New Building Permit Plan Review Comments

Water

Reviewer: Shundalyn Evans

Email:

Phone:

1. 09/19/25 --CORRECTIONS REQUIRED-- Fees Due.

Water/sewer impact + reducer fees due. Contact Water Applications at 817-392-8250 or WaterApps@fortworthtexas.gov to provide proposed water meter and sewer information in addition to customer billing information.

*****NOTE*****

It is the responsibility of the builder to uncover the water and sewer services. Water service must be exposed before meter can be set.

Approval Table:

Task Name	Task Status	Completed Date	Task Rev Name
Application Submittal	Routed for Electronic Review	09/10/2025	Jasmine Lujan
Water Development Review	Approved	09/26/2025	Elizabeth Armendariz
Transportation Impact Review	Not Required	09/18/2025	Lamonica Smith
Urban Forestry Review	Approved	09/16/2025	Marilyn Hernandez Ayala
Zoning Review	Approved	09/17/2025	Marilyn Hernandez Ayala
PARD Review	Not Required	09/10/2025	Germaine Joseph
Building Plan Review	Approved	09/16/2025	Jim West
Issue Permit	Issued	09/26/2025	Camille Henderson
Inspections			
Mechanical Plan Review	Approved	09/10/2025	Jasmine Lujan
Plumbing Plan Review	Approved	09/10/2025	Jasmine Lujan
Electrical Plan Review	Approved	09/10/2025	Jasmine Lujan
Plan Distribution	Routed for Electronic Review	09/26/2025	Elizabeth Armendariz
Plans Coordination	Approved	09/26/2025	Marilyn Hernandez Ayala
TPW CFRA Review	Not Required	09/18/2025	Robin Stevens

General Comments and Additional Permit Information:

Planning Development Department



Residential New Building Permit Plan Review Comments

Reviewer: Marilyn Hernandez Ayala
Email: Marilyn.HernandezAyala@fortworthtexas.gov
Phone: 817-392-2827

1 Zoning Plans Exam

Residential Zoning Review Notes PB25-12720 – 225 EC TALLY DR
Planning and Development Department Plan: Lakeway (X40L) B L
Zoning Review Notes: All reviews are pending stakeout inspection
Development Agreement Contract
Permit data confirmed on: 09/17/2025
By: Marilyn A. Hernández Ayala [817-392-2827]

Scope of project: New SFR Build to standards: "MUD to A-5"

HOLD NOTES: All items labeled "HOLD" must be addressed

Zoning district MUD built to: _Y_A-5

__ A-7.5

__ A-10

Official Plat: attached to plans lot/block number verified Y (Tradition Blk_3_Lt_2_)

Lone Star at Liberty Trails Phase 1 FP-24-210 approved/filed 6/11/2025

Building Square footage: _R3:_2045 U:_613

Slab: 2,658

Lot Area: 9,799

Lot coverage: including all structures _27%_ A-5 no more than 50%

__%_ A-7.5 no more than 45%

__%_ A-10 no more than 40%

Height: 35' maximum (Provided _18' 3")

Lot Width: _51.03'_ A-5 minimum 50 ft. at building line

__'_ A-7.5 minimum 55 ft. at building line

__'_ A-10 minimum 60 ft. at building line

Front yard driveway coverage: 50% maximum (_35%)

Setback restrictions: (The front yard setback in residential districts shall be the greatest of:
The platted building line; The setback for the applicable zoning district; or the setback of
the nearest building on either side that is the closest to the street, up to a maximum
setback of 50 feet, provided that said setback is not the result of a variance granted by the
Board of Adjustment)

Front: A-5 & A-7.5: 20' minimum (Provided _20' 0")

A-10: 25' minimum (Provided __')

Houses on either side: left: Vacant_ ft. right: _Vacant_ ft. per 3rd party site plan (verify
on aerial photo)

Sides: 5' minimum, 10' on corner lots (Provided _5' 0" & 6' ½")

1. Rear: A-5 & A-7.5 5' minimum (Provided _53' 2½")

Planning Development Department



Residential New Building Permit Plan Review Comments

A-10 10' minimum (Provided __')

Note: As applicable, any fence located within an easement will require permission of the easement holder(s) to encroach.

Parking spaces:

Ord. 21528 Single Family Home: Two spaces located behind the front building wall for dwelling units with three or fewer bedrooms, plus one space located behind the front building wall or in the driveway for each bedroom above three. # bedrooms: 4 # parking spaces required 3 provided 4

Required parking spaces must be hard surface and dust free (asphalt or concrete). All maneuvering space must be located off of the public right of way.

Urban Forestry: (letter or UFC # provided Y – UFC23-0104 - Planting Requirements:

2 trees – 2 medium canopies be planted for residential lots with areas less than 5,000 sq. ft.

2 trees – 1 medium and 1 large canopies be planted for residential lots with areas between 5,000 sq. ft. and 10,000 sq. ft.

3 trees – 1 medium and 2 large canopies be planted for residential lots with areas greater than 10,000 sq. ft.

Single Family Design Standards:

The same elevation shall not be permitted within an eight-lot pattern, on an adjacent lot or on a lot directly across the street. Provided and correct? Y

No attached garage facing a public or private street may project greater than eight (8) feet in front of the front wall of the house in all Single-Family Districts. Complies? Y

Additional Comments:

Sec. 22-176. Curb cuts and laid-down curb permit procedures.

The location of ingress and egress driveways shall be subject to approval of the city traffic engineer under curb cut or laid-down curb permit procedures. Driveways shall not exceed sixty-five (65) per cent of the property frontage. There shall be a minimum of twenty (20) feet of curb along the street between driveways where there is more than one driveway on property under unified ownership or control and used as one premise. The decision of the city traffic engineer may be appealed to the city council. (Code 1964, § 26-102.3; Ord. No. 8288, § 1, 3-10-81)

SINGLE FAMILY HOME: DWELLING UNIT: A building, or any portion thereof, containing a complete set of independent living facilities for occupancy and use by one family, including permanent provisions for living, sleeping, eating, sanitation and cooking within a kitchen for the exclusive use of the occupants whose intent is to inhabit the dwelling unit.

COOKING EQUIPMENT: A stove, range or other such appliances, which requires a 220V or gas connection that is used, designed, or intended to be used for the cook and preparing of food.

Planning Development Department

A sidewalk is required for all frontages facing a street
<http://fortworthtexas.gov/planninganddevelopment/permits/streets/>

Planning Development Department

The City of Fort Worth * 100 Fort Worth Trail * Fort Worth, TX, 76102
817-392-2222 * Fax 817-392-8105