



Residential New Building Permit Plan Review Comments

Application: PB25-11893

Date Submitted: 08/21/2025

Status: Issued

Date Issued: 09/16/2025

Address: 11220 BOYNE AVE

Parcel: 1518625

Zoning: A-5

Subdivision: WELLINGTON

Lot/Block: 3/V

Description of Work: Construction of new single-family residence

3rd Party Plan Review & Inspections

North Texas Inspection Services

ADA TDLR:

Energy Code Compliant:

Applicant: Stacie Hamby

Owner: PULTE HOMES OF TEXAS LP

8220 Clifford St

9111 CYPRESS WATERS BLVD STE 100

White Settlement, TX 76108

COPPELL,, TX 75019

8172467780

Building Classification:

Occ Class	Const Type	Square Feet	Occ Load	Use Description
R-3	VB	2827	14	Living Area
U	VB	695	3	Garage/Porch/Patio

Sprinkler Sys Req:

Comment: Signs, Retaining Walls over 4', Fences, Dumpster Enclosures over 6', and Parkway Approaches and Sidewalks require separate permits and reviews.

Required Corrections:

Building

Reviewer: Stacie Hamby

Email: stacie@ntispros.com

Phone: (817) 246-7780

1.

Planning Development Department

The City of Fort Worth * 100 Fort Worth Trail * Fort Worth, TX, 76102
817-392-2222 * Fax 817-392-8105



Residential New Building Permit Plan Review Comments

Water

Reviewer: Shundaiyn Evans

Email:

Phone:

1. 08/28/25 --CORRECTIONS REQUIRED-- Fees Due.

Water/sewer impact + reducer fees due. Contact Water Applications at 817-392-8250 or WaterApps@fortworthtexas.gov to provide proposed water meter and sewer information in addition to customer billing information.

NOTE

It is the responsibility of the builder to uncover the water and sewer services. Water service must be exposed before meter can be set.

Approval Table:

Task Name	Task Status	Completed Date	Task Rev Name
Application Submittal	Routed for Electronic Review	08/22/2025	Latrica Jelks
Water Development Review	Approved	09/12/2025	Elizabeth Armendariz
Transportation Impact Review	Approved	08/27/2025	Lamonica Smith
Urban Forestry Review	Approved	08/29/2025	Marilyn Hernandez Ayala
Zoning Review	Approved	09/03/2025	Marilyn Hernandez Ayala
PARD Review	Not Required	08/22/2025	Germaine Joseph
Building Plan Review	Approved	08/29/2025	Jim West
Issue Permit	Issued	09/16/2025	Magali Romero
Inspections			
Mechanical Plan Review	Approved	08/22/2025	Latrica Jelks
Plumbing Plan Review	Approved	08/22/2025	Latrica Jelks
Electrical Plan Review	Approved	08/22/2025	Latrica Jelks
Plan Distribution	Routed for Electronic Review	09/12/2025	Elizabeth Armendariz
Plans Coordination	Approved	09/12/2025	Minden Ritz
TPW CFRA Review	Not Required	09/02/2025	Robin Stevens

General Comments and Additional Permit Information:

Planning Development Department

The City of Fort Worth * 100 Fort Worth Trail * Fort Worth, TX, 76102
817-392-2222 * Fax 817-392-8105



Residential New Building Permit Plan Review Comments

Reviewer: Marilyn Hernandez Ayala

Email: Marilyn.HernandezAyala@fortworthtexas.gov

Phone: 817-392-2827

1 Zoning Plans Exam

Residential Zoning Review Notes PB25-11893 – 11220 BOYNE AVE

Planning and Development Department PLAN #: Amherst 1862 B R

Zoning Review Notes: All reviews are pending stakeout inspection

CFW Zoning Ordinance # 13896-22519

Permit data confirmed on: 09/03/2025

By: Marilyn A. Hernández-Ayala [817-392-2827]

Scope of project: New SFR

HOLD NOTES: All items labeled "HOLD" must be addressed

SUMMARY: Permit meets minimum standards Y

Holds: _____

Zoning district: "PD1232 to A-5" Type of layout: Single Family Residence

Official Plat: Attached to plans lot/block number verified Y (_Wellington Blk V Lt 3)
FP-22-158 approved/filed 01/22/2024

Building Square footage: R-3: 2827 U: 695

Slab SF: 2,432

Lot Area: 6,000

Lot coverage: 50% maximum, including all structures (Provided 41%)

Height: 35' maximum (Provided _30' 6½")

Lot Width: 50' minimum at building line (Provided 50' 0")

Front yard driveway coverage: 50% maximum (Provided _36%_)

Setback restrictions: (The front yard setback in residential districts shall be the greatest of:
The platted building line; The setback for the applicable zoning district; or the setback of
the nearest building on either side that is the closest to the street, up to a maximum
setback of 50 feet, provided that said setback is not the result of a variance granted by the
Board of Adjustment)

Front: 20' minimum (provided _20' 3")

Houses on either side: __ L -_20' / _R -_20'_ per 3rd party site plan (verify aerial photo)

Sides: 5' minimum (Provided 5' 2" & 5' 1")

Rear: 5' minimum (Provided 33' 4")

Planning Development Department



Residential New Building Permit Plan Review Comments

Note: As applicable, any fence located within an easement will require permission of the easement holder(s) to encroach.

Parking spaces:

Ord. 21528 Single Family Home: Two spaces located behind the front building wall for dwelling units with three or fewer bedrooms, plus one space located behind the front building wall or in the driveway for each bedroom above three.

Bedrooms: 4 Parking spaces required 3 provided 4.

Required parking spaces must be hard surface and dust free (asphalt or concrete). All maneuvering space must be located off of the public right of way.

Urban Forestry: property is vested, infill, or has approved UFC permit: (letter or UFC # provided Y – UFC21-0268 Planting Requirements:

Two (2) trees be planted per residential lot areas between 5,000 sq. ft and 10,000 sq. ft
Three (3) trees be planted per residential lot areas between 10,000 sq. ft. 15,000 sq. ft. -
See attached site plan.)

An infill house shall be required to have a minimum 3" caliper front yard tree of choice, and one minimum 3" caliper street parkway tree as approved by the City Forester.

Single Family Design Standards:

The same elevation shall not be permitted within a six-lot pattern, on an adjacent lot or on a lot directly across the street.

No attached garage facing a public or private street may project greater than eight (8) feet in front of the front wall of the house in all Single-Family Districts.

Additional Comments:

Sec. 22-176. Curb cuts and laid-down curb permit procedures.

The location of ingress and egress driveways shall be subject to approval of the city traffic engineer under curb cut or laid-down curb permit procedures. Driveways shall not exceed sixty-five (65) per cent of the property frontage. There shall be a minimum of twenty (20) feet of curb along the street between driveways where there is more than one driveway on property under unified ownership or control and used as one premise. The decision of the city traffic engineer may be appealed to the city council. (Code 1964, § 26-102.3; Ord. No. 8288, § 1, 3-10-81)

SINGLE FAMILY HOME: DWELLING UNIT: A building, or any portion thereof, containing a complete set of independent living facilities for occupancy and use by one family, including permanent provisions for living, sleeping, eating, sanitation, and cooking within a kitchen for the exclusive use of the occupants whose intent is to habitat the dwelling unit.

COOKING EQUIPMENT: A stove, range or other such appliances, which requires a 220V or gas connection that is used, designed, or intended to be used for the cook and preparing of food.

Planning Development Department

The City of Fort Worth * 100 Fort Worth Trail * Fort Worth, TX, 76102
817-392-2222 * Fax 817-392-8105

A sidewalk is required for all frontages facing a street
<http://fortworthtexas.gov/planninganddevelopment/permits/streets/> .

Reviewer: Lamonica Smith
Email: Lamonica.Smith@fortworthtexas.gov
Phone:

2 ****Transportation Impact Fees****

2025 rate with no adequate facilities discount. Fees covered by CA-23-003.

Planning Development Department

The City of Fort Worth * 100 Fort Worth Trail * Fort Worth, TX, 76102
817-392-2222 * Fax 817-392-8105