



Residential New Building Permit Plan Review Comments

Application: PB25-16930

Date Submitted: 12/10/2025

Status: Plan Review

Date Issued:

Address: 7820 SWITCHWOOD LN

Parcel: 1556455

Zoning: PD

Subdivision: TAVOLO PARK PHASE 5

Lot/Block: 6/32

Description of Work: New Single Family Residence w/3rd Party Review and Inspections

ADA TDLR:

Energy Code Compliant:

Applicant: Adriana Perez

Owner: CND-TAVOLO LLC

100 E 15th St 630

1111 N POST OAK RD

Fort Worth, TX 76102

HOUSTON,, TX 77055

9722446925

Building Classification:

Occ Class	Const Type	Square Feet	Occ Load	Use Description
R-3	VB	2294		Living Space
U	VB	676		Utilities

Sprinkler Sys Req:

Comment: Signs, Retaining Walls over 4', Fences, Dumpster Enclosures over 6', and Parkway Approaches and Sidewalks require separate permits and reviews.

Required Corrections:

Planning Development Department



Residential New Building Permit Plan Review Comments

Building

Reviewer: Adriana Perez

Email: Adriana.A.Perez@BureauVeritas.com

Phone: 682-227-7436

1. Bureau Veritas Zoning Notes:

Address: 7820 Switchwood Ln

Lot coverage: 49.42% (not over 60%)

Height: 29'-9"

Lot width at build line over 50': 50'

Verified driveway does not exceed more than 50% of front yard: 36%

(Measured from front wall of house to front property line)

Provided front yard setback: 16'-2" w/ porch encroachment

Provided side yard setback L: 5' R: 5'

Provided rear yard setback: 26'-6 1/2"

Number of bedrooms: 3

Parking spaces (9' x 18') provided: 2 in Garage, 2 Driveway

(Requirements: 3 bdrms=2; 4 bdrms=3; 5 bdrms=4; 6 bdrms=5)

Houses on either side: Left: 20' Right: 20'-1"

Masonry Requirements:

(Masonry is considered brick, stone, cementitious fiber concrete products or stucco)

Over 50% on all sides? yes

Trees shown on plot plan: 2

Zoning

Reviewer: Gustavo Ramirez

Email: Gustavo.Ramirez@fortworthtexas.gov

Phone:

1. 12/10/25 CORRECTIONS REQUIRED - ENCROACHMENT

Please provide the encroachment agreement for the front yard setback.

Approval Table:

Task Name	Task Status	Completed Date	Task Rev Name
Application Submittal	Routed for Electronic Review	12/10/2025	Jasmine Lujan
Water Development Review			
Transportation Impact Review			
Urban Forestry Review	Approved	12/10/2025	Gustavo Ramirez

Planning Development Department



Residential New Building Permit Plan Review Comments

Zoning Review	Corrections Required	12/10/2025	Gustavo Ramirez
PARD Review	Not Required	12/10/2025	Germaine Joseph
Building Plan Review	Approved	12/10/2025	Gustavo Ramirez
Mechanical Plan Review	Approved	12/10/2025	Jasmine Lujan
Plumbing Plan Review	Approved	12/10/2025	Jasmine Lujan
Electrical Plan Review	Approved	12/10/2025	Jasmine Lujan
TPW CFRA Review			

General Comments and Additional Permit Information:

Reviewer: Gustavo Ramirez
Email: Gustavo.Ramirez@fortworthtexas.gov
Phone:

1 Zoning Plans Exam
Residential Zoning Review Notes PB25-16930 – 7820 SWITCHWOOD LN - Plan #:
T003 B R
Planning and Development Department
Zoning Review Notes: All reviews are pending stakeout inspection
CFW Zoning Ordinance # 13896-22519

Permit data confirmed on: 12/10/2025

By: Gustavo Ramirez [817-392-7849]

Scope of project: New SFR

HOLD NOTES: All items labeled "HOLD" must be addressed

SUMMARY: Permit meets minimum standards Y
Holds: ____

Zoning district: "PD1273 to A-5" Type of layout: Single Family Residence

Official Plat: Attached to plans lot/block number verified Y (TAVOLO PARK Block 32 Lot 6)
FP-23-156 approved/filed 7/2/2024

Building Square footage: R-3: 2294 U: 676
Slab SF: 2965
Lot Area SF: 6000

Lot coverage: 60% maximum, including all structures (Provided _49.42%)

Height: 35' maximum (Provided _29.75')

Planning Development Department



Residential New Building Permit Plan Review Comments

Lot Width: 50' minimum at building line (Provided 50')

Front yard driveway coverage: 50% maximum (Provided 36%)

Setback restrictions: (The front yard setback in residential districts shall be the greatest of: The platted building line; The setback for the applicable zoning district; or the setback of the nearest building on either side that is the closest to the street, up to a maximum setback of 50 feet, provided that said setback is not the result of a variance granted by the Board of Adjustment)

Front: 20' minimum (provided 16.17')

Houses on either side: L – 20' / R – 20.08' per 3rd party site plan (verify on photo)

Sides: 5' minimum (Provided Left: 5' & Right: 5.08')

Rear: 5' minimum (Provided 26.54')

Note: As applicable, any fence located within an easement will require permission of the easement holder(s) to encroach.

Parking spaces:

Ord. 21528 Single Family Home: Two spaces located behind the front building wall for dwelling units with three or fewer bedrooms, plus one space located behind the front building wall or in the driveway for each bedroom above three.

Bedrooms: 3 Parking spaces required (9'x18') 2 provided 4

Required parking spaces must be hard surface and dust free (asphalt or concrete). All maneuvering space must be located off of the public right of way.

Urban Forestry: property is vested, infill, or has approved UFC permit: (letter or UFC # provided Y – UFC23-0132 (Ph 2-6) Planting requirements: 1 to 2 large-canopy trees per residential lot as shown on attached site plan.)

An infill house shall be required to have a minimum 3" caliper front yard tree of choice, and one minimum 3" caliper street parkway tree as approved by the City Forester.

Single Family Design Standards:

The same elevation shall not be permitted within an eight lot pattern, on an adjacent lot or on a lot directly across the street.

No attached garage facing a public or private street may project greater than eight (8) feet in front of the front wall of the house in all Single-Family Districts.

Additional Comments:

Sec. 22-176. Curb cuts and laid-down curb permit procedures.

The location of ingress and egress driveways shall be subject to approval of the city traffic engineer under curb cut or laid-down curb permit procedures. Driveways shall not exceed sixty-five (65) per cent of the property frontage. There shall be a minimum of twenty (20)

Planning Development Department

feet of curb along the street between driveways where there is more than one driveway on property under unified ownership or control and used as one premise. The decision of the city traffic engineer may be appealed to the city council. (Code 1964, § 26-102.3; Ord. No. 8288, § 1, 3-10-81)

SINGLE FAMILY HOME: DWELLING UNIT: A building, or any portion thereof, containing a complete set of independent living facilities for occupancy and use by one family, including permanent provisions for living, sleeping, eating, sanitation, and cooking within a kitchen for the exclusive use of the occupants whose intent is to inhabit the dwelling unit.

COOKING EQUIPMENT: A stove, range or other such appliances, which requires a 220V or gas connection that is used, designed, or intended to be used for the cook and preparing of food.

A sidewalk is required for all frontages facing a street
<http://fortworthtexas.gov/planninganddevelopment/permits/streets/> .

Planning Development Department

The City of Fort Worth * 100 Fort Worth Trail * Fort Worth, TX, 76102
817-392-2222 * Fax 817-392-8105