



## Residential New Building Permit Plan Review Comments

**Application:** PB25-13288

**Date Submitted:** 09/22/2025

**Status:** Issued

**Date Issued:** 10/17/2025

**Address:** 7428 WAYWARD WIND DR

**Parcel:** 1592407

**Zoning:** A-5

**Subdivision:** TALON HILL ADDITION

**Lot/Block:** 6/H

**Description of Work:** Construction of new single-family residence  
3rd Party Plan Review & Inspections  
North Texas Inspection Services

**ADA TDLR:**

**Energy Code Compliant:**

**Applicant:** Stacie Hamby

**Owner:** BYD TALON FP LLC

8220 Clifford St

1105 GLADE RD STE 100

White Settlement, TX 76108

COLLEYVILLE,, TX 76034

8172467780

**Building Classification:**

Occ Class	Const Type	Square Feet	Occ Load	Use Description
R-3	VB	3219		Living Area
U	VB	735		Garage/Porch/Patio

**Sprinkler Sys Req:**

**Comment:** Signs, Retaining Walls over 4', Fences, Dumpster Enclosures over 6', and Parkway Approaches and Sidewalks require separate permits and reviews.

**Required Corrections:**

**Building**

**Reviewer:** Stacie Hamby

**Email:** stacie@ntispros.com

**Phone:** (817) 246-7780

1.

**Approval Table:**

Task Name	Task Status	Completed Date	Task Rev Name
Application Submittal	Routed for Electronic Review	09/23/2025	Jasmine Lujan
Water Development Review	Approved	10/17/2025	Shundalyn Evans

Planning Development Department



## Residential New Building Permit Plan Review Comments

Transportation Impact Review	Approved	10/01/2025	Lamonica Smith
Urban Forestry Review	Approved	09/25/2025	Jesus Olmos
Zoning Review	Approved	09/25/2025	Jesus Olmos
PARD Review	Not Required	09/24/2025	Germaine Joseph
Building Plan Review	Approved	09/25/2025	3PTY NORTH TEXAS
Issue Permit	Issued	10/17/2025	Camille Henderson
Inspections			
Mechanical Plan Review	Approved	09/23/2025	Jasmine Lujan
Plumbing Plan Review	Approved	09/23/2025	Jasmine Lujan
Electrical Plan Review	Approved	09/23/2025	Jasmine Lujan
Plan Distribution	Routed for Electronic Review	10/17/2025	Shundalyn Evans
Plans Coordination	Approved	10/17/2025	Jesus Olmos
TPW CFRA Review	Not Required	10/02/2025	Robin Stevens

### General Comments and Additional Permit Information:

**Reviewer:** Jesus Olmos  
**Email:** Jesus.Olmos@fortworthtexas.gov  
**Phone:**

#### 2 Zoning Plans Exam

Residential Zoning Review Notes PB25-13288 | 7428 WAYWARD WIND DR | Plan#  
Victoria TRN R  
Planning and Development Department  
Zoning Review Notes: All reviews are pending stakeout inspection  
CFW Zoning Ordinance # 13896-19602

Permit data confirmed on: 9/25/2025  
By: Jesus Olmos Jr. [817-392-7858]  
Scope of project: Single-Family Residence

Plan Review Contact: Jim West (North Texas)

HOLD NOTES: All items labeled "HOLD" must be addressed

SUMMARY: Permit meets minimum standards Y  
Holds: \_\_\_\_

Zoning district: "A-5" built to standard "A-5" Type of layout: Single-Family Residence

Planning Development Department



## Residential New Building Permit Plan Review Comments

Official Plat: Attached to plans lot 6 / block H number verified Y  
Talon Hill Addition - FP-24-076 - Filing date: 11/22/2024

Building Square footage: R-3: 3219 U: 735  
Slab SF: 2897  
Lot Area: 8680

Lot coverage: 50% maximum, including all structures (Provided 33%)

Height: 35' maximum (Provided 28' 8")

Lot Width: 50' minimum at building line (Provided 62')

Front yard driveway coverage: 50% maximum (Provided 29%)

Setback restrictions: (The front yard setback in residential districts shall be the greatest of: The platted building line; The setback for the applicable zoning district; or the setback of the nearest building on either side that is the closest to the street, up to a maximum setback of 50 feet, provided that said setback is not the result of a variance granted by the Board of Adjustment)

Front: 20' minimum (Provided \_ 20' 0")

Houses on either side: \_ 20' \_ / \_ 20' \_ per 3rd party site plan (verify on aerial photo)

Sides: 5' minimum (Provided Left \_ more than 11' 0" & Right 11' 1")

Rear: 5' minimum (Provided \_ 41' 1")

Note: As applicable, any fence located within an easement will require permission of the easement holder(s) to encroach.

### Parking spaces:

Ord. 21528 Single Family Home: Two spaces located behind the front building wall for dwelling units with three or fewer bedrooms, plus one space located behind the front building wall or in the driveway for each bedroom above three.

# Bedrooms: 4 Parking spaces required 3 provided 4

Required parking spaces must be hard surface and dust free (asphalt or concrete). All maneuvering space must be located off of the public right of way.

Urban Forestry: property is vested, infill or UFC: (UFC21-0254) Planting Requirements: 2 large-canopy trees per residential lot 5,000 – 9,999 sq. ft.; 3 large-canopy trees per residential lot 10,000 – 14,999 sq. ft.; 4 large-canopy trees per residential lot greater than 15,000 + sq. ft. - provided Y)

Planning Development Department

An infill house shall be required to have a minimum 3" caliper front yard tree of choice, and one minimum 3" caliper street parkway tree as approved by the City Forester.

**Single Family Design Standards:**

The same elevation shall not be permitted within a six-lot pattern, on an adjacent lot or on a lot directly across the street.

Exterior walls shall consist of a minimum of 50% masonry. Exposures to a minor arterial or wider street shall require 100% masonry construction except where such building face is obscured by a minimum six (6) foot masonry wall. "Masonry" shall include brick, stone, cementitious fiber concrete products or stucco. Similar products made from such materials and/or durable recycled material shall be allowed as approved by the Building Official.

No attached garage facing a public or private street may project greater than eight (8) feet in front of the front wall of the house in all Single-Family Districts.

**Additional Comments:**

Sec. 22-176. Curb cuts and laid-down curb permit procedures.

The location of ingress and egress driveways shall be subject to approval of the city traffic engineer under curb cut or laid-down curb permit procedures. Driveways shall not exceed sixty-five (65) per cent of the property frontage. There shall be a minimum of twenty (20) feet of curb along the street between driveways where there is more than one driveway on property under unified ownership or control and used as one premise. The decision of the city traffic engineer may be appealed to the city council. (Code 1964, § 26-102.3; Ord. No. 8288, § 1, 3-10-81)

**SINGLE FAMILY HOME: DWELLING UNIT:** A building, or any portion thereof, containing a complete set of independent living facilities for occupancy and use by one family, including permanent provisions for living, sleeping, eating, sanitation, and cooking within a kitchen for the exclusive use of the occupants whose intent is to inhabit the dwelling unit.

**COOKING EQUIPMENT:** A stove, range or other such appliances, which requires a 220V or gas connection that is used, designed, or intended to be used for the cook and preparing of food.

**Reviewer: Lamonica Smith**

**Email: [Lamonica.Smith@fortworthtexas.gov](mailto:Lamonica.Smith@fortworthtexas.gov)**

**Phone:**

1 \*\*\*\*Transportation Impact Fees\*\*\*\*

2025 rate with 50% adequate facilities discount.

Planning Development Department