



Residential New Building Permit Plan Review Comments

Application: PB25-11788

Date Submitted: 08/19/2025

Status: Issued

Date Issued: 10/24/2025

Address: 1015 STELLA ST lot 17 blo

Parcel: 112886

Zoning: A-5

Subdivision: UNION DEPOT ADDITION

Lot/Block: 17/15

Description of Work: build new house

ADA TDLR:

Energy Code Compliant:

Applicant: Terence Walker

Owner: SALVANT, BRIAN

3515 Sycamore School Rd 125/PMB128

610 E WEATHERFORD ST

fort worth, TX 76133

FORT WORTH,, TX 76102

6825184656

Building Classification:

Occ Class	Const Type	Square Feet	Occ Load	Use Description
R-3	VB	1464		habitable space
U	VB	287		porch and patio

Sprinkler Sys Req:

Comment: Signs, Retaining Walls over 4', Fences, Dumpster Enclosures over 6', and Parkway Approaches and Sidewalks require separate permits and reviews.

Required Corrections:

General

Reviewer: Deshia Hawkins

Email: Deshia.Hawkins@fortworthtexas.gov

Phone:

1. missing
Lot Drainage Diagram and Monotony check list

Planning Development Department



Residential New Building Permit Plan Review Comments

PARD

Reviewer: Germaine Joseph

Email: Germaine.Joseph@fortworthtexas.gov

Phone:

1. PARD/PDP: This development is within the boundaries of Park Planning District 4; the Neighborhood & Community Park Dedication Policy applies. There is a required \$1,393.58 due for each single-family residential unit or duplex on an undeveloped lot. On a lot with a teardown, there is a required \$1,393.58 due for each additional residential unit (duplex). Please upload the demolition/razing permit. Tear down and replace in-kind, no PARD-PDP fee is due. Call Development Services @ 817-392-2222, if you need assistance on making a payment. Call Lori Gordon @ 817-392-5743 for information regarding the fee and to what it is applied. All fees must be paid in full for single family residential or duplex, at or before building permit issue. No city permits will be issued until the PDP fees have been paid.

Approval Table:

Task Name	Task Status	Completed Date	Task Rev Name
Application Submittal	Routed for Electronic Review	08/27/2025	Deshia Hawkins
Water Development Review	Approved	10/16/2025	Elizabeth Armendariz
Historical Review	Approved	09/11/2025	Dexter Davis
NEZ Certification Review	Opt-Out	10/09/2025	Deshia Hawkins
Transportation Impact Review	Not Required	08/28/2025	Lamonica Smith
Urban Forestry Review	Approved	09/11/2025	Dexter Davis
Zoning Review	Approved	09/11/2025	Dexter Davis
PARD Review	Approved	08/27/2025	Germaine Joseph
Building Plan Review	Approved	09/18/2025	Jesus Olmos
Issue Permit	Issued	10/24/2025	Irene Echavarria
Inspections			
Mechanical Plan Review	Approved	09/18/2025	Jesus Olmos
Plumbing Plan Review	Approved	09/18/2025	Jesus Olmos
Electrical Plan Review	Approved	09/05/2025	Jesus Olmos
Plan Distribution	Routed for Electronic Review	10/16/2025	Elizabeth Armendariz
Plans Coordination	Approved	10/16/2025	Jesus Olmos
NEZ Design Guidelines Review	Not Required	10/15/2025	Rosalee Rivera

Planning Development Department



Residential New Building Permit Plan Review Comments

General Comments and Additional Permit Information:

Reviewer: Jesus Olmos

Email: Jesus.Olmos@fortworthtexas.gov

Phone:

2 ***** Residential Code Review Comments *****

City Plans Examiner: Jesus Olmos Jr.

Phone # (817) 392- 7858

jesus.olmos@fortworthtexas.gov

Date 09/05/2025

Development Services

Residential Review Notes

IRC 2021 / CFW ORD. # 25383

Permit #: PB25-11788

Terence Walker - 1015 Stella St.

Construction type: VB

Project Area:

Occupancy & Use: R-3 – 1464; U - 287

Scope of Work: One-Story Residence

Professional engineer certified foundation plans:

Professional engineer who certified structural plans:

Braced wall plans: Bill Graham PE#67899

WINDOWS

Max U-factor is 0.35

Max SHGC is 0.25

DOORS – U-factor

Uninsulated metal: 1.2

Insulated metal: 0.6

Wood: 0.5

Insulated, nonmetal edge, Max 45% glazing, any glazing double pane 0.35

INSULATION

R-13+5h or 20 insulation in exterior walls

R-38 insulation in the attic

R-19 insulation in the floor

** General Notes **

NOTE: The general notes listed below are an abbreviated version of the actual notes in

Planning Development Department



Residential New Building Permit Plan Review Comments

the 2021 IRC and CFW Amendment. The builder is responsible for compliance with the full applicable IRC section and/or CFW Amendment.

This Plan is void without City Plan Review Notes.

1. See attached examiner's notes and City handouts as applicable to this permit.
2. See attached site and construction plans as applicable to permit.
3. All work shall conform to City of Fort Worth building code, energy code and zoning requirements.
4. SEPARATE PERMITS ARE REQUIRED for Electrical, Mechanical and Plumbing work.
5. R302.6 Dwelling/garage fire separation.

SEPARATION MATERIAL

From the residence and attics: Not less than 1/2-inch gypsum board or equivalent applied to the garage side

From all habitable rooms above the garage: Not less than 5/8-inch Type X gypsum board or equivalent

6. R302.11 Fireblocking.

In combustible construction, fireblocking shall be provided to cut off all concealed draft openings (both vertical and horizontal) and to form an effective fire barrier between stories, and between a top story and the roof space.

7. BATHROOMS – R303.3 Bathrooms, water closet compartments and other similar rooms shall be provided with aggregate glazing area in windows of not less than 3 square feet, one-half of which must be operable. Artificial light and mechanical ventilation may be provided.

8. EMERGENCY ESCAPE – R310 – basements, habitable attics and each sleeping room shall have at least one operable emergency and rescue opening.

R310.2.1 – All emergency escape and rescue openings shall have a minimum net clear opening of 5.7 sq.ft. Openings on grade shall be a minimum of 5 sq.ft. net clear opening.

R310.2.1 – Minimum opening height is 24"

R310.2.1 – Minimum opening width is 20"

R310.1.1 – Emergency escape and rescue openings shall be operational from the inside of the room without the use of keys, tools or special knowledge.

9. MEANS OF EGRESS – R311

R311.6 – Minimum hallway width shall not be less than 36"

Planning Development Department



Residential New Building Permit Plan Review Comments

R311.2 – Each dwelling unit shall have not less than one exit door

10. SECTION R315 CARBON MONOXIDE ALARMS

R315.2.1 Carbon monoxide alarms and R315.3 Location. For new construction, an approved carbon monoxide alarm shall be installed outside of each separate sleeping area in the immediate vicinity of the bedrooms in dwelling units within which fuel-fired appliances are installed and in dwelling units that have attached garages.

11. WATER HEATERS: M2005.2 – Fuel fired water heaters shall not be installed in a room used as a storage closet.

12. CLOTHES DRYER EXHAUST: 2021 IRC M1502 – Dryer exhaust systems shall be independent of all other systems, and shall terminate on the outside of the building. Exhaust ducts shall be equipped with a backdraft damper.

Reviewer: Dexter Davis

Email: Dexter.Davis@fortworthtexas.gov

Phone: 817-392-5985

1 Zoning Plans Exam

Residential Zoning Review Notes

Planning and Development Department

Zoning Review Notes: All reviews are pending stakeout inspection

CFW Zoning Ordinance # 13896-19602

Permit data confirmed on: 9/11/25

By: Dexter Davis [817-392-5985] Dexter.Davis@fortworthtexas.gov

Permit number: PB25-11788

Address: 1015 Stella St

Legal address: UNION DEPOT ADDITION Block 15 Lot 17

Scope of project: New Single Family Home

HOLD NOTES: All items labeled "HOLD" must be addressed

SUMMARY: Permit meets minimum standards Y

Holds: ____

Zoning district: "A-5 (HC)" Type of layout: Single-Family Detached Residence

Official Plat: Union Depot addition Fort worth Texas

Building Square footage: R-3: 1730 U: Total= 1730 sq. ft.

Lot coverage: 50% maximum, including all structures (Provided 34.6%)

Height: 35' maximum (Provided 32'-9")

Planning Development Department



Residential New Building Permit Plan Review Comments

Lot Width: 50' minimum at building line (Provided 50')

Front yard driveway coverage: 50% maximum (Provided less than max)

Setback restrictions: (The front yard setback in residential districts shall be the greatest of: The platted building line; The setback for the applicable zoning district; or the setback of the nearest building on either side that is the closest to the street, up to a maximum setback of 50 feet, provided that said setback is not the result of a variance granted by the Board of Adjustment)

Front: (Provided 17.1')

Sides: 5' minimum (Provided 5'-left and 14' 8"-right)

Rear: 5' minimum (Provided 25' 7')

Note: As applicable, any fence located within an easement will require permission of the easement holder(s) to encroach.

Parking spaces:

Ord. 21528 Single Family Home: Two spaces located behind the front building wall for dwelling units with three or fewer bedrooms, plus one space located behind the front building wall or in the driveway for each bedroom above three.

Bedrooms: 3 Parking spaces required 2 provided 2

Required parking spaces must be hard surface and dust free (asphalt or concrete). All maneuvering space must be located off of the public right of way.

An infill house shall be required to have a minimum 3" caliper front yard tree of choice, and one minimum 3" caliper street parkway tree as approved by the City Forester.

Single Family Design Standards:

The same elevation shall not be permitted within a six lot pattern, on an adjacent lot or on a lot directly across the street.

Exterior walls shall consist of a minimum of 50% masonry. Exposures to a minor arterial or wider street shall require 100% masonry construction except where such building face is obscured by a minimum six (6) foot masonry wall. "Masonry" shall include brick, stone, cementitious fiber concrete products or stucco. Similar products made from such materials and/or durable recycled material shall be allowed as approved by the Building Official.

No attached garage facing a public or private street may project greater than eight (8) feet in front of the front wall of the house in all Single-Family Districts.

Planning Development Department

Additional Comments: Certificate of Appropriateness
Historic & Cultural Landmarks Commission
James Sobczak / The Plan Factory
1015 Stella Street

On March 27, 2024, the Historic & Cultural Landmarks Commission APPROVED a request for a Certificate of Appropriateness to construct a new residence located within the Terrell Heights Historic District.

All in accordance with the plans stamped 'APPROVED' on April 1, 2024.

FINDINGS IN ACCORDANCE WITH STANDARDS

Terrell Heights Historic District Guidelines: New Construction

Appropriate

The proposed structures reflect the contributing elements and patterns found within the neighborhood, the streetscape and the block where they will be located.

APPROVALS AND PERMITS

The Historic and Cultural Landmarks Commission or Historic Preservation Officer must approve work not included in this Certificate of Appropriateness prior to the issuance of a building permit. Approval of your case does not negate you from any other applicable requirements needed to obtain required permits. If necessary, you must obtain all required variances before a building permit will be issued.

APPEALS AND CERTIFICATE OF APPROPRIATENESS VALIDITY

An appeal to this decision may be submitted by written request to the City Secretary and the Historic Preservation Officer within 15 days of the date of this decision. Certificates of Appropriateness are valid for two years from the date of issuance.

FURTHER INFORMATION

Questions regarding this case may be forwarded to the Development Services Department at (817) 392-8000.

Sec. 22-176. Curb cuts and laid-down curb permit procedures.

The location of ingress and egress driveways shall be subject to approval of the city traffic engineer under curb cut or laid-down curb permit procedures. Driveways shall not exceed sixty-five (65) per cent of the property frontage. There shall be a minimum of twenty (20) feet of curb along the street between driveways where there is more than one driveway on property under unified ownership or control and used as one premise. The decision of the city traffic engineer may be appealed to the city council. (Code 1964, § 26-102.3; Ord. No. 8288, § 1, 3-10-81)

SINGLE FAMILY HOME: DWELLING UNIT: A building, or any portion thereof, containing a complete set of independent living facilities for occupancy and use by one family, including permanent provisions for living, sleeping, eating, sanitation, and cooking within a kitchen for the exclusive use of the occupants whose intent is to inhabit the dwelling unit.

COOKING EQUIPMENT: A stove, range or other such appliances, which requires a 220V or gas connection that is used, designed, or intended to be used for the cook and preparing of food.

Planning Development Department