



Residential New Building Permit Plan Review Comments

Application: PB25-15975

Date Submitted: 11/14/2025

Status: Plan Review

Date Issued:

Address: 2832 CLINTON AVE

Parcel: 58053

Zoning: A-5

Subdivision: ELLIS, M G ADDITION

Lot/Block: 17/58

Description of Work: New single residential home

ADA TDLR:

Energy Code Compliant:

Applicant:

Owner: WILLIAMS, ANN M

500 Hazelnut Court

2317 MARKET AVE

Saginaw, TX 76179

FORT WORTH,, TX 76164

Building Classification:

Occ Class	Const Type	Square Feet	Occ Load	Use Description
R-3	VB	1899		a/c space
U	VB	717		garage/patio/porch

Sprinkler Sys Req:

Comment: Signs, Retaining Walls over 4', Fences, Dumpster Enclosures over 6', and Parkway Approaches and Sidewalks require separate permits and reviews.

Required Corrections:

PARD

Reviewer: Germaine Joseph

Email: Germaine.Joseph@fortworthtexas.gov

Phone:

1. PARD/PDP: This development is within the boundaries of Park Planning District 4; the Neighborhood & Community Park Dedication Policy applies. There is a required \$1,393.58 due for each single-family residential unit or duplex on an undeveloped lot. On a lot with a teardown, there is a required \$1,393.58 due for each additional residential unit (duplex). Please upload the demolition/razing permit. Tear down and replace in-kind, no PARD-PDP fee is due. Call Development Services @ 817-392-2222, if you need assistance on making a payment. Call Lori Gordon @ 817-392-5743 for information regarding the fee and to what it is applied. All fees must be paid in full for single-family residential or duplex, at or before building permit issue. No city permits will be issued until the PDP fees have been paid. Starting Oct 1, 2025, customers who choose to pay by Credit Card or Debit Card will incur a service fee of 2.5%. There is no service fee to pay by check, ACH, cash, or money order.

Planning Development Department



Residential New Building Permit Plan Review Comments

Water

Reviewer: Ibeth Heatley

Email: Ibeth.Heatley@fortworthtexas.gov

Phone:

1. 12/9/25 -- CORRECTIONS REQUIRED -- Fees Due. Fees will be invoiced once all other holds are cleared.
11/26/25 -- CORRECTIONS REQUIRED -- Fees Due.

Water/sewer impact + reducer fees due. Contact Water Applications at 817-392-8250 or WaterApps@fortworthtexas.gov to provide proposed water meter and sewer information in addition to customer billing information.

Existing 3/4-inch service 5 feet north of the center lot

*****NOTE*****

It is the responsibility of the builder to uncover the water and sewer services. Water service must be exposed before meter can be set.

2. 12/9/25 - CORRECTIONS REQUIRED - Utility plan shows sewer service to connect in the front. Public sewer main is in the alley
11/26/25 - CORRECTIONS REQUIRED - - Provide a civil UTILITY SITE PLAN showing how the project will be connected to the City Water & Sewer. The plan must list types of services, sizes of service taps, and meters for the project. Be sure to note designations of Irrigation services & meter sizes - or the decline of irrigation service(s)
3. 12/9/25 -- CORRECTIONS REQUIRED -- Fees Due. Fees will be invoiced once all other holds are cleared.
10/01/25 -- CORRECTIONS REQUIRED -- Fees Due.

Water/sewer tap fees due. Contact Water Applications at 817-392-8250 or WaterApps@fortworthtexas.gov to provide proposed water meter and sewer information in addition to customer billing information.

*****NOTE*****

It is the responsibility of the builder to uncover the water and sewer services. Water service must be exposed before meter can be set.

4. 12/9/25 CORRECTIONS REQUIRED - Need customer billing information:
 1. Customer Name (for the account)
 2. Customer's Mailing Address
 3. Customer's Tax ID Number
 4. Contact Name (if different from customer name)
 5. Customer's Phone number
 6. Customer's Email address

Please provide customer billing information to WaterApps@FortWorthTexas.Gov and be sure to add the permit number and address in the subject title.

Planning Development Department



Residential New Building Permit Plan Review Comments

Approval Table:

Task Name	Task Status	Completed Date	Task Rev Name
Application Submittal	Routed for Electronic Review	11/17/2025	Taryn Wilson
Water Development Review	Corrections Required	12/09/2025	Michelle Canright
NEZ Certification Review	Opt-Out	11/17/2025	Taryn Wilson
Transportation Impact Review	Not Required	11/23/2025	Lamonica Smith
Urban Forestry Review	Approved	11/25/2025	Rosalee Rivera
Zoning Review	Approved	11/25/2025	Rosalee Rivera
PARD Review	Approved	11/17/2025	Germaine Joseph
Building Plan Review	Approved	11/18/2025	Minden Ritz
Mechanical Plan Review	Approved	11/18/2025	Minden Ritz
Plumbing Plan Review	Approved	11/18/2025	Minden Ritz
Electrical Plan Review	Approved	11/18/2025	Minden Ritz
Plan Distribution	Routed for Electronic Review	12/10/2025	Minden Ritz
Plans Coordination	Corrections Required	12/09/2025	Minden Ritz
NEZ Design Guidelines Review	Not Required	11/25/2025	Rosalee Rivera
Parkway Review	Approved	11/25/2025	Jeffrey Wolff

General Comments and Additional Permit Information:

Reviewer: Minden Ritz
Email: Minden.Ritz@fortworthtexas.gov
Phone:

3 ` ***** Residential Code Review Comments *****

City Plans Examiner: Minden Ritz
Phone # (817) 392- 2322
@fortworthtexas.gov
Date 11/18/2025
Development Services
Residential Review Notes
IRC 2021 / CFW ORD. # 25383

Permit #: PB25-15975
Address: 2832 Clinton Ave

Planning Development Department



Residential New Building Permit Plan Review Comments

Construction type: VB
Project Area: 2616
Occupancy & Use: R-3 – 1,899 U – 717

Scope of Work: New Single Family Residence

Professional engineer certified foundation plans: Matthew D. Vinson #98392
Professional engineer who certified structural plans: Matthew D. Vinson #98392
Braced wall plans: Matthew D. Vinson #98392

WINDOWS

Max U-factor is 0.35
Max SHGC is 0.25

DOORS – U-factor

Uninsulated metal: 1.2
Insulated metal: 0.6
Wood: 0.5
Insulated, nonmetal edge, Max 45% glazing, any glazing double pane 0.35

INSULATION

R-13+5h or 20 insulation in exterior walls
R-38 insulation in the attic
R-19 insulation in the floor

** General Notes **

NOTE: The general notes listed below are an abbreviated version of the actual notes in the 2021 IRC and CFW Amendment. The builder is responsible for compliance with the full applicable IRC section and/or CFW Amendment.

This Plan is void without City Plan Review Notes.

1. See attached examiner's notes and City handouts as applicable to this permit.
2. See attached site and construction plans as applicable to permit.
3. All work shall conform to City of Fort Worth building code, energy code and zoning requirements.
4. SEPARATE PERMITS ARE REQUIRED for Electrical, Mechanical and Plumbing work.
5. R302.6 Dwelling/garage fire separation.

SEPARATION MATERIAL

From the residence and attics: Not less than 1/2-inch gypsum board or equivalent applied to the garage side

Planning Development Department



Residential New Building Permit Plan Review Comments

From all habitable rooms above the garage: Not less than 5/8-inch Type X gypsum board or equivalent

6. R302.11 Fireblocking.

In combustible construction, fireblocking shall be provided to cut off all concealed draft openings (both vertical and horizontal) and to form an effective fire barrier between stories, and between a top story and the roof space.

7. BATHROOMS – R303.3 Bathrooms, water closet compartments and other similar rooms shall be provided with aggregate glazing area in windows of not less than 3 square feet, one-half of which must be openable. Artificial light and mechanical ventilation may be provided.

8. EMERGENCY ESCAPE – R310 – basements, habitable attics and each sleeping room shall have at least one operable emergency and rescue opening.

R310.2.1 – All emergency escape and rescue openings shall have a minimum net clear opening of 5.7 sq.ft. Openings on grade shall be a minimum of 5 sq.ft. net clear opening.

R310.2.1 – Minimum opening height is 24"

R310.2.1 – Minimum opening width is 20"

R310.1.1 – Emergency escape and rescue openings shall be operational from the inside of the room without the use of keys, tools or special knowledge.

9. MEANS OF EGRESS – R311

R311.6 – Minimum hallway width shall not be less than 36"

R311.2 – Each dwelling unit shall have not less than one exit door

10. SECTION R315 CARBON MONOXIDE ALARMS

R315.2.1 Carbon monoxide alarms and R315.3 Location. For new construction, an approved carbon monoxide alarm shall be installed outside of each separate sleeping area in the immediate vicinity of the bedrooms in dwelling units within which fuel-fired appliances are installed and in dwelling units that have attached garages.

11. WATER HEATERS: M2005.2 – Fuel fired water heaters shall not be installed in a room used as a storage closet.

12. CLOTHES DRYER EXHAUST: 2021 IRC M1502 – Dryer exhaust systems shall be independent of all other systems, and shall terminate on the outside of the building. Exhaust ducts shall be equipped with a backdraft damper.

13. M1502.4.5.1 SPECIFIED LENGTH – The maximum length of a clothes dryer exhaust duct shall not exceed 35 feet from the connection to the transition duct from the dryer to the outlet terminal.- The maximum length of the duct shall be reduced 2.5 feet for every 45 degree bend and 5 feet for each 90 degree bend.

Planning Development Department



Residential New Building Permit Plan Review Comments

1 & 2 FAMILY ELECTRICAL

14. RECEPTACLE OUTLETS – Receptacles shall be installed so that no point measured horizontally along the floor line in any wall space is more than 6 feet from a receptacle outlet (E3901.2.1).

15. COUNTERTOP RECEPTACLES - E3901.4.1 Wall countertop space. A receptacle outlet shall be installed at each wall countertop space 12 inches (305 mm) or wider. Receptacle outlets shall be installed so that no point along the wall line is more than 24 inches (610 mm), measured horizontally from a receptacle outlet in that space.

16. E3901.4.2 Island countertop spaces. At least one receptacle outlet shall be installed at each island countertop space.

17. E3901.4.3 Peninsular countertop space. At least one receptacle outlet shall be installed at each peninsular countertop.

18. E3901.4.4 Separate spaces. Countertop spaces separated by range tops, refrigerators, or sinks shall be considered as separate countertop spaces

19. GFI CIRCUITS –2023 NEC 210.8 Ground Fault Interrupter Circuits shall be installed in dwelling units in the following locations:

210.8 (A)(1) - Bathrooms

210.8 (A)(2) - Garages and accessory buildings that have a floor at or below grade level

210.8 (A)(3) - Outdoor receptacles

210.8 (A)(6) - Kitchens where receptacles are installed to serve the countertop surfaces

210.8 (A)(7) - Laundry, utility and wet bar sink – where the receptacles are installed within 6 ft. of the outside edge of the sink

19. 210.52 (G) At least one receptacle outlet, in addition to those for specific equipment, shall be installed in each basement, in each attached garage, and in each detached garage with electric power.

20. Arc-Fault Circuit Interrupter Protection 2023 NEC 210.12(A)

All 120 volt, single phase, 15 and 20 ampere branch circuits supplying outlets installed in dwelling unit family rooms, dining rooms, living rooms, parlors, libraries, dens, bedrooms, sunrooms, recreation rooms, closets, hallways or similar rooms or areas shall be protected by a listed arc-fault circuit interrupter, combination type, installed to provide protection of the branch circuit.

21. Heating, Air-Conditioning and Refrigeration Equipment Outlet – 2023 NEC 210.63
A 125-volt, single-phase, 15 or 20 ampere rated receptacle outlet shall be installed at an accessible location for the servicing of heating, air-conditioning and refrigeration equipment. The receptacle shall be located on the same level and within 25 feet of the heating, air-conditioning and refrigeration equipment.+

22. Luminaries in Clothes Closet: Luminary Types and location must comply with 2023

Planning Development Department



Residential New Building Permit Plan Review Comments

NEC 410.16

23. Electricity will not be released until Transportation & Public Works (TPW) has approved sidewalk and drive approach inspections

Reviewer: Ibeth Heatley
Email: Ibeth.Heatley@fortworthtexas.gov
Phone:

1 WATER APPLICATIONS

*** IMPORTANT*** PLEASE READ WATER AND SEWER SERVICE LOCATION REQUIREMENTS ***

Sec 5.18.2.1 Meter boxes can only be installed in non-paved areas. Water service and meter box must be installed 1-foot offset from the property line in the parkway and have a 9-foot horizontal separation from the sewer service. The normal location for meter boxes is 2.5 feet behind the back of curb.

In no case shall the water meter box (and meter) be outside of the public right-of-way or water easement.

Sec 6.4.1.3 Wastewater service should avoid placement in driveways and have a 9-foot horizontal separation from the water service.

Service should be installed South or West of the proposed driveway location.

To prevent delays for a meter set, ensure the following criteria is met:

- Address must be clearly posted, i.e., visible and big enough to see
- No debris or material over the meter box
- Meter box must be in the ground to grade per city specification

Reviewer: Rosalee Rivera
Email: Rosalee.Rivera@fortworthtexas.gov
Phone: 817-392-2222

2 Zoning Plan Review Performed On: 11/25/2025

By: Rosalee Rivera — rosalee.rivera@fortworthtexas.gov

Zoning Review Notes: All reviews are pending stakeout inspection

Permit #: PB25-15975

Related: Home at 2830 built by same builder // PB25-08328 - Finaled

Physical Address: 2832 Clinton Ave

Legal Description: ELLIS, M G ADDITION – Block 58 – Lot 17 – Per the NEZ opt out form

Plat: ELLIS, M G ADDITION – Filed 02/11/1890

Planning Development Department



Residential New Building Permit Plan Review Comments

Zoning district: A-5

Scope of project: Single Family Residence

HOLD NOTES: All items labeled "HOLD" must be addressed. Additional HOLDS may be placed upon review of revisions.

***Please do not upload revised combined plans until the permit is in (Awaiting Client Reply)

Overlays: N/A

Minimum Lot Size 5000 sq ft: Provided: 7000 sf.

Building Square Footage: 2616 sf.
Maximum Height 35': Provided: 26.9'
Lot Width: 50' minimum / Provided: 50'

Lot Coverage: 50% maximum; Provided: 37%

Front yard driveway coverage: 50% maximum; Provided: N/A // Side entry garage off of NW 29th

4.705(e)(7) ONE-FAMILY ("A-5") DISTRICT.
(Table)

(7) No parking for one- and two-family uses shall be permitted within the front yard, as measured between the front property line and the closest location on the structure, other than as provided on the driveway. Driveway coverage, including ribbon drives, shall not exceed 50% of the front yard, and any additional parking on the property shall be provided on the driveway. Circular drives shall not exceed 65% maximum coverage. Parking pads are permitted if they are attached to the primary driveway and constructed of the same material and shall be included in the calculation of driveway coverage.

Monotony: Custom home unique to the block

Trees: Provided tree location in front yard

Setback restrictions: (The front yard setback in residential districts shall be the greatest of: The platted building line; The setback for the applicable zoning district; or the setback of the nearest building on either side that is the closest to the street, up to a maximum setback of 50 feet, provided that said setback is not the result of a variance granted by the Board of Adjustment)

Established Setbacks Provided: 20'

Planning Development Department



Residential New Building Permit Plan Review Comments

Front: 20' minimum – Provided: 20'

Interior Side Yard: 5' minimum – Provided: 7'

Exterior Side Setback – Corner Lot – Provided 10'

Rear: 5' minimum – Provided: 30.4'

No. of bedrooms: 3

Parking spaces required: 2

Parking spaces provided: 2 – Side entry garage off of NW 29th ST

Additional Comments:

4.406(1)(e) TCU RESIDENTIAL ("TCU") OVERLAY DISTRICT.

(1) TCU residential overlay district. The TCU residential overlay district is designed as an overlay to the base zoning district. Property located within this zoning overlay must also be designated as being within one of the base zoning districts. Permitted uses must be allowed in both the base zoning district and the overlay district and must comply with height, yard, area and parking requirements of the base zoning district.

(e) Use restrictions. No more than three unrelated persons may occupy a single dwelling unit in the TCU residential overlay district unless the owner has registered as a nonconforming use by March 31, 2015. When counting the number of unrelated persons in a single dwelling unit, persons related by blood, marriage or adoption shall count as one unrelated person, provided all other persons shall each count as one unrelated person.

6.507.2 (c) ONE-FAMILY DWELLING UNIT DESIGN STANDARDS.

One-family dwellings must comply with the following standards.

Parking. Section 4.705.D.2 Single Family Home: (2) Parking. Two spaces located behind the front building wall for dwelling units with three or fewer bedrooms, plus one space located behind the front building wall or in the driveway for each bedroom above three. Required parking spaces must be hard surface and dust free (asphalt or concrete). All maneuvering space must be located off of the public right of way.

(a) Elevation. The intent of this subsection is to promote the health, safety, and general

Planning Development Department



Residential New Building Permit Plan Review Comments

welfare of the City of Fort Worth and its citizens through the adoption and enforcement of one-family dwelling unit design standards that limit the effects of repetition and uniformity by requiring substantive variation and diversity in front elevations within a certain lot pattern. The elevations for one-family dwelling units within a six (6) lot pattern must be sufficiently differentiated from each other and from any one-family dwelling unit that is two (2) lots removed on either side of the subject property on the same side of the street, as generally depicted below and otherwise set forth herein.

(c) Attached garages. No attached garage facing a public or private street may project greater than eight feet in front of the front wall of the house in all single-family districts.

(7) Garage/carport. No more than one garage and one carport or porte cochere shall be allowed per residential unit on a single residential lot, unless the additional garages or porte cocheres are an integral part of the main residential structure with the same roofline and driveway as the residential structure.

(8) Side and rear yard setbacks. The side and rear yard setback for detached garages located behind the rear wall of the house may be reduced to three feet. The side yard of an attached garage may be located within three feet of the property line when located a minimum of 18 feet back of the front wall of the house.

6.302(1) URBAN FORESTRY.

(1) One- and two-family residential land uses.

a. Minimum retained or planted canopy coverage shall be 40%.

(d) Infill house. An infill house shall be required to have one minimum three-inch caliper front yard tree of choice, and one minimum three-foot caliper street parkway tree as approved by the city forester. In all instances, a minimum of 40% canopy cover per lot must be achieved in accordance with § 6.302.

If your construction project includes alley access or paving in public right of way please email or call WPD@fortworthtexas.gov, 817-392-8428, so that the Water Department can determine if any public water or sewer mains will be paved over. Any identified public mains that the Water Department determines need to be replaced will be scheduled for rehab by the Water Dept. before paving activity can commence. This time line varies so it is critical that the assessment occurs as soon as possible to avoid delaying your project. Any paving over public water or sewer mains will require a review by the Water Department to identify conflicts or encroachments. Exhibits must be drawn to scale, show cross streets, lot boundaries, address and legal description, easements, dimensioning and profile.

Alley will need to be paved from the farthest property line to the nearest street or existing alley paving if it is to be used as access.

A parkway permit is required for all new construction projects for sidewalk(s), if not currently existing.

Planning Development Department

***** end ZONING PLANS EXAM COMMENTS*****

Planning Development Department

The City of Fort Worth * 100 Fort Worth Trail * Fort Worth, TX, 76102
817-392-2222 * Fax 817-392-8105