



## Residential New Building Permit Plan Review Comments

**Application:** PB25-13514

**Date Submitted:** 09/25/2025

**Status:** Issued

**Date Issued:** 12/01/2025

**Address:** 1005 E TUCKER ST

**Parcel:** 115622

**Zoning:** A-5

**Subdivision:** UNION DEPOT ADDITION

**Lot/Block:** 19/13

**Description of Work:** residential new construction of single family residence

**ADA TDLR:**

**Energy Code Compliant:**

**Applicant:**

**Owner:** GREATER HEIGHTS PROPERTIES AND  
MANAGEMENT LLC

3001 Holloran St  
Fort Worth, TX 76107

1212 VISTAWOOD DR  
MANFIELD, TX 76063

### Building Classification:

Occ Class	Const Type	Square Feet	Occ Load	Use Description
R-3	VB	1183		habitable space
U	VB	165		porch and patio

### Sprinkler Sys Req:

**Comment:** Signs, Retaining Walls over 4', Fences, Dumpster Enclosures over 6', and Parkway Approaches and Sidewalks require separate permits and reviews.

### Required Corrections:

#### **PARD**

**Reviewer:** Germaine Joseph

**Email:** Germaine.Joseph@fortworthtexas.gov

**Phone:**

1. PARD/PDP: This development is within the boundaries of Park Planning District 4; the Neighborhood & Community Park Dedication Policy applies. There is a required \$1,393.58 due for each single-family residential unit or duplex on an undeveloped lot. On a lot with a teardown, there is a required \$1,393.58 due for each additional residential unit (duplex). Please upload the demolition/razing permit. Tear down and replace in-kind, no PARD-PDP fee is due. Call Development Services @ 817-392-2222, if you need assistance on making a payment. Call Lori Gordon @ 817-392-5743 for information regarding the fee and to what it is applied. All fees must be paid in full for single family residential or duplex, at or before building permit issue. No city permits will be issued until the PDP fees have been paid.

Planning Development Department



## Residential New Building Permit Plan Review Comments

### Approval Table:

Task Name	Task Status	Completed Date	Task Rev Name
Application Submittal	Routed for Electronic Review	09/29/2025	April Smith
Water Development Review	Approved	11/25/2025	Michelle Canright
Historical Review	Approved	09/30/2025	Inkah Reviere
NEZ Certification Review	Opt-Out	09/29/2025	April Smith
Transportation Impact Review	Not Required	10/06/2025	Lamonica Smith
Urban Forestry Review	Approved	11/18/2025	Inkah Reviere
Zoning Review	Approved	11/18/2025	Inkah Reviere
PARD Review	Approved	09/29/2025	Germaine Joseph
Building Plan Review	Approved	10/13/2025	Jesus Olmos
Issue Permit	Issued	12/01/2025	Irene Echavarria
Inspections			
Mechanical Plan Review	Approved	11/18/2025	Jesus Olmos
Plumbing Plan Review	Approved	10/01/2025	Jesus Olmos
Electrical Plan Review	Approved	10/01/2025	Jesus Olmos
Plan Distribution	Routed for Electronic Review	11/24/2025	Minden Ritz
Plans Coordination	Approved	11/26/2025	Jesus Olmos
NEZ Design Guidelines Review	Not Required	09/30/2025	Inkah Reviere

### General Comments and Additional Permit Information:

**Reviewer: Jesus Olmos**

**Email: Jesus.Olmos@fortworthtexas.gov**

**Phone:**

1 \*\*\*\*\* Residential Code Review Comments \*\*\*\*\*

City Plans Examiner: Jesus Olmos Jr.

Phone # (817) 392-7858

Jesus.olmos@fortworthtexas.gov

Date 11/26/2025

Development Services

Residential Review Notes

IRC 2021 / CFW ORD. # 25383

Planning Development Department



## Residential New Building Permit Plan Review Comments

Permit #: PB25-13514

Construction type: VB

Project Area: lot size 3800sf

Occupancy & Use: R-3 – 1183 ; U - 165

Scope of Work: New One-Story Residence

Professional engineer certified foundation plans: Igor I. Teplitskiy # 94973

Professional engineer who certified structural plans: Igor I. Teplitskiy # 94973

Braced wall plans: Igor I. Teplitskiy # 94973

### WINDOWS

Max U-factor is 0.35

Max SHGC is 0.25

### DOORS – U-factor

Uninsulated metal: 1.2

Insulated metal: 0.6

Wood: 0.5

Insulated, nonmetal edge, Max 45% glazing, any glazing double pane 0.35

### INSULATION

R-13+5h or 20 insulation in exterior walls

R-38 insulation in the attic

R-19 insulation in the floor

\*\* General Notes \*\*

NOTE: The general notes listed below are an abbreviated version of the actual notes in the 2021 IRC and CFW Amendment. The builder is responsible for compliance with the full applicable IRC section and/or CFW Amendment.

This Plan is void without City Plan Review Notes.

1. See attached examiner's notes and City handouts as applicable to this permit.
2. See attached site and construction plans as applicable to permit.
3. All work shall conform to City of Fort Worth building code, energy code and zoning requirements.
4. SEPARATE PERMITS ARE REQUIRED for Electrical, Mechanical and Plumbing work.
5. R302.6 Dwelling/garage fire separation.

### SEPARATION MATERIAL

Planning Development Department



## Residential New Building Permit Plan Review Comments

From the residence and attics: Not less than 1/2-inch gypsum board or equivalent applied to the garage side

From all habitable rooms above the garage: Not less than 5/8-inch Type X gypsum board or equivalent

### 6. R302.11 Fireblocking.

In combustible construction, fireblocking shall be provided to cut off all concealed draft openings (both vertical and horizontal) and to form an effective fire barrier between stories, and between a top story and the roof space.

7. BATHROOMS – R303.3 Bathrooms, water closet compartments and other similar rooms shall be provided with aggregate glazing area in windows of not less than 3 square feet, one-half of which must be operable. Artificial light and mechanical ventilation may be provided.

8. EMERGENCY ESCAPE – R310 – basements, habitable attics and each sleeping room shall have at least one operable emergency and rescue opening.

R310.2.1 – All emergency escape and rescue openings shall have a minimum net clear opening of 5.7 sq.ft. Openings on grade shall be a minimum of 5 sq.ft. net clear opening.

R310.2.1 – Minimum opening height is 24"

R310.2.1 – Minimum opening width is 20"

R310.1.1 – Emergency escape and rescue openings shall be operational from the inside of the room without the use of keys, tools or special knowledge.

### 9. MEANS OF EGRESS – R311

R311.6 – Minimum hallway width shall not be less than 36"

R311.2 – Each dwelling unit shall have not less than one exit door

### 10. SECTION R315 CARBON MONOXIDE ALARMS

R315.2.1 Carbon monoxide alarms and R315.3 Location. For new construction, an approved carbon monoxide alarm shall be installed outside of each separate sleeping area in the immediate vicinity of the bedrooms in dwelling units within which fuel-fired appliances are installed and in dwelling units that have attached garages.

11. WATER HEATERS: M2005.2 – Fuel fired water heaters shall not be installed in a room used as a storage closet.

12. CLOTHES DRYER EXHAUST: 2021 IRC M1502 – Dryer exhaust systems shall be independent of all other systems, and shall terminate on the outside of the building. Exhaust ducts shall be equipped with a backdraft damper.

Planning Development Department



## Residential New Building Permit Plan Review Comments

**Reviewer: Michelle Canright**  
**Email: [Michelle.Canright@fortworthtexas.gov](mailto:Michelle.Canright@fortworthtexas.gov)**  
**Phone:**

### 2 WATER APPLICATIONS

\*\*\* IMPORTANT\*\*\* PLEASE READ WATER AND SEWER SERVICE LOCATION REQUIREMENTS \*\*\*

---

Sec 5.18.2.1 Meter boxes can only be installed in non-paved areas. Water service and meter box must be installed 1-foot offset from the property line in the parkway and have a 9-foot horizontal separation from the sewer service. The normal location for meter boxes is 2.5 feet behind the back of curb.

In no case shall the water meter box (and meter) be outside of the public right-of-way or water easement.

Sec 6.4.1.3 Wastewater service should avoid placement in driveways and have a 9-foot horizontal separation from the water service.

Service should be installed South or West of the proposed driveway location.

To avoid delays and additional meter installation fees, please ensure the following requirements are met:

- Address must be clearly posted
- No debris or material over the meter box
- Meter box must be in the ground to grade per city specification

---

**Reviewer: Inkah Reviere**  
**Email: [Inkah.Reviere@fortworthtexas.gov](mailto:Inkah.Reviere@fortworthtexas.gov)**  
**Phone: 817-392-6138**

### 3 Zoning Plans Exam Residential Zoning Review Notes

Planning and Development Department  
Zoning Review Notes: All reviews are pending stakeout inspection  
CFW Zoning Ordinance # 13896 / Historical Terrell Heights

Permit data confirmed on: September 30th 2025  
By: INKAH REVIERE [817-392-6138] [Inkah.Reviere@fortworthtexas.gov](mailto:Inkah.Reviere@fortworthtexas.gov)

Scope of project: New Single-Family Home

HOLD NOTES: All items labeled "HOLD" must be addressed

SUMMARY: permit meets minimum standards

Planning Development Department



## Residential New Building Permit Plan Review Comments

Zoning district: A-5 / HISTORICAL TERRELL HEIGHTS  
COA & HCLA: HCLC-25-182 APPROVED  
Address: 1005 E TUCKER STREET  
Official Plat: UNION DEPOT ADDITION BLK 13 LOT 19  
Total Lot Area Per Plat: 3,686 square feet  
Building Square footage: 1,183 (Slab: 1,183 SF) # bedrooms: 3  
Lot coverage: 50% maximum (Provided 32%)  
ELEVATION: CUSTOM HOME  
Lot Width: 50' minimum at building line (38')

Front yard driveway coverage: 50% maximum (74%)  
Height: 35' maximum (Provided 13.8716')  
Setback restrictions: (The front yard setback in residential districts shall be the greatest of: The platted building line; The setback for the applicable zoning district; or the setback of the nearest building on either side that is the closest to the street, up to a maximum setback of 50 feet, provided that said setback is not the result of a variance granted by the Board of Adjustment)  
Front: 20' minimum (Provided: 20')  
Sides: 5' minimum (10' minimum adjacent to a side street) (Provided 10' ON LEFT / 5' ON RIGHT)  
Rear: 5' minimum (Provided 21')

Houses on either side: LEFT: 22' LOT RIGHT: 10'

No attached garage facing a public or private street may project greater than eight (8) feet in front of the front wall of the house in all Single-Family Districts.

UFC #\_\_INFILL\_\_ MISSING ONE TREE

Parking spaces: 2 required PROVIDED 2 / TERRELL HEIGHTS DOES NOT PERMIT PARKING IN THE FRONT OF THE RESIDENCE.  
Ord. 21528 Single Family Home: Two spaces located behind the front building wall for dwelling units with three or fewer bedrooms, plus one space located behind the front building wall or in the driveway for each bedroom above three. # Parking spaces provided \_\_2\_\_ 2 IN DRIVE PAD BEHIND FRONT WALL

Required parking spaces must be hard surface and dust free (asphalt or concrete). All maneuvering space must be located off of the public right of way.

Urban Forestry: property is vested, infill, or has approved UFC permit letter or UFC # provided  
NOT COMPLIANT

An infill house shall be required to have a minimum 3" caliper front yard tree of choice, and one minimum 3" caliper street parkway tree as approved by the City Forester.

Single Family Design Standards:

The same elevation shall not be permitted within a six-lot pattern, on an adjacent lot or on a lot directly across the street. Provided and correct? IN COMPLIANCE

Exterior walls shall consist of a minimum of 50% masonry. Exposures to a minor arterial

Planning Development Department

or wider street shall require 100% masonry construction except where such building face is obscured by a minimum six (6) foot masonry wall. "Masonry" shall include brick, stone, cementitious fiber concrete products or stucco. Similar products made from such materials and/or durable recycled material shall be allowed as approved by the Building Official. Provided and correct? Y

Additional Comments:

SINGLE FAMILY HOME: DWELLING UNIT: A building, or any portion thereof, containing a complete set of independent living facilities for occupancy and use by one family, including permanent provisions for living, sleeping, eating, and sanitation and cooking within a kitchen for the exclusive use of the occupants whose intent is to inhabit the dwelling unit.

Sec. 22-176. Curb cuts and laid-down curb permit procedures.

The location of ingress and egress driveways shall be subject to approval of the city traffic engineer under curb cut or laid-down curb permit procedures. Driveways shall not exceed sixty-five (65) per cent of the property frontage. There shall be a minimum of twenty (20) feet of curb along the street between driveways where there is more than one driveway on property under unified ownership or control and used as one premise. The decision of the city traffic engineer may be appealed to the city council. (Code 1964, § 26-102.3; Ord. No. 8288, § 1, 3-10-81)

COOKING EQUIPMENT: A stove, range or other such appliances, which requires a 220V or gas connection that is used, designed, or intended to be used for the cook and preparing of food.