



Residential New Building Permit Plan Review Comments

Application: PB25-16540

Date Submitted: 12/02/2025

Status: Plan Review

Date Issued:

Address: 2204 WAYLON DR

Parcel: 1630226

Zoning: A-5

Subdivision:

Lot/Block: 17/

Description of Work: Construction of new single-family residence
3rd Party Plan Review & Inspections
North Texas Inspection Services

ADA TDLR:

Energy Code Compliant:

Applicant: Stacie Hamby

Owner: DR HORTON - TEXAA LTD

8220 Clifford St

6751 NORTH FWY

White Settlement, TX 76108

FORT WORTH,, TX 76131

8172467780

Building Classification:

Occ Class	Const Type	Square Feet	Occ Load	Use Description
R-3	VB	1201		Living Area
U	VB	463		Garage/Porch/Patio

Sprinkler Sys Req:

Comment: Signs, Retaining Walls over 4', Fences, Dumpster Enclosures over 6', and Parkway Approaches and Sidewalks require separate permits and reviews.

Required Corrections:

Building

Reviewer: Stacie Hamby

Email: stacie@ntispros.com

Phone: (817) 246-7780

1.

Approval Table:

Task Name	Task Status	Completed Date	Task Rev Name
Application Submittal	Routed for Electronic Review	12/03/2025	Christopher Gates
Water Development Review			

Planning Development Department



Residential New Building Permit Plan Review Comments

Transportation Impact Review	Approved	12/08/2025	Lamonica Smith
Urban Forestry Review	Approved	12/04/2025	Jesus Olmos
Zoning Review	Approved	12/04/2025	Jesus Olmos
PARD Review	Not Required	12/03/2025	Germaine Joseph
Building Plan Review	Approved	12/04/2025	3PTY NORTH TEXAS
Mechanical Plan Review	Approved	12/03/2025	Christopher Gates
Plumbing Plan Review	Approved	12/03/2025	Christopher Gates
Electrical Plan Review	Approved	12/03/2025	Christopher Gates

General Comments and Additional Permit Information:

Reviewer: Jesus Olmos

Email: Jesus.Olmos@fortworthtexas.gov

Phone:

2 Zoning Plans Exam

Residential Zoning Review Notes

PB25-16540 | 2204 Waylon Dr. | Plan# Ellis C L

Planning and Development Department

Zoning Review Notes: All reviews are pending stakeout inspection

CFW Zoning Ordinance # 13896-19602

Permit data confirmed on: 12/4/2025

By: Jesus Olmos Jr. [817-392-7858]

Scope of project: Single-Family Residence

HOLD NOTES: All items labeled "HOLD" must be addressed

SUMMARY: Permit meets minimum standards Y

Holds: ____

Zoning district: A-5 Built to "A-5" Type of layout: Single-Family Residence

Official Plat: Attached to plans lot 17 / block 1 number verified Y

Longhorn Estates, FP-24-070 file date: 5/30/2025

Building Square footage: R-3: 1201 U: 463

Slab SF: 1664

Lot Area SF: 6000

Lot coverage: 50% maximum, including all structures (Provided 28%)

Height: 35' maximum (Provided 17' 0")

Lot Width: 50' minimum at building line (Provided 50')

Front yard driveway coverage: 50% maximum (Provided 36%)

Setback restrictions: (The front yard setback in residential districts shall be the greatest of:

The platted building line; The setback for the applicable zoning district; or the setback of

Planning Development Department



Residential New Building Permit Plan Review Comments

the nearest building on either side that is the closest to the street, up to a maximum setback of 50 feet, provided that said setback is not the result of a variance granted by the Board of Adjustment)

Front: 20' minimum (Provided 20')

Houses on either side: Left: 20' / Right: 20' 11"

Sides: 5' minimum (Provided Left: 7' 2½" / Right: 7' 9½")

Rear: 5' minimum (Provided 47' 11½")

Note: As applicable, any fence located within an easement will require permission of the easement holder(s) to encroach.

Parking spaces:

Ord. 21528 Single Family Home: Two spaces located behind the front building wall for dwelling units with three or fewer bedrooms, plus one space located behind the front building wall or in the driveway for each bedroom above three.

Bedrooms: 3 Parking spaces required 2 provided 4

Required parking spaces must be hard surface and dust free (asphalt or concrete). All maneuvering space must be located off of the public right of way.

Urban Forestry: property is vested, infill or UFC: (UFC23-0168) (A) 2 Medium Canopy Trees greater than 10,000 sq. ft.; (B) 1-Large and 1 Medium-Canopy Trees greater than 10,000 sq. ft.; (C) 1 Medium and 2 Large Canopy Trees less than 10,000 Residential Lot - provided Y)

An infill house shall be required to have a minimum 3" caliper front yard tree of choice, and one minimum 3" caliper street parkway tree as approved by the City Forester.

Single Family Design Standards:

The same elevation shall not be permitted within a six-lot pattern, on an adjacent lot or on a lot directly across the street.

Exterior walls shall consist of a minimum of 50% masonry. Exposures to a minor arterial or wider street shall require 100% masonry construction except where such building face is obscured by a minimum six (6) foot masonry wall. "Masonry" shall include brick, stone, cementitious fiber concrete products or stucco. Similar products made from such materials and/or durable recycled material shall be allowed as approved by the Building Official.

No attached garage facing a public or private street may project greater than eight (8) feet in front of the front wall of the house in all Single-Family Districts.

Additional Comments:

Sec. 22-176. Curb cuts and laid-down curb permit procedures.

The location of ingress and egress driveways shall be subject to approval of the city traffic engineer under curb cut or laid-down curb permit procedures. Driveways shall not exceed sixty-five (65) per cent of the property frontage. There shall be a minimum of twenty (20) feet of curb along the street between driveways where there is more than one driveway on property under unified ownership or control and used as one premise. The decision of the city traffic engineer may be appealed to the city council. (Code 1964, § 26-102.3; Ord. No.

Planning Development Department

8288, § 1, 3-10-81)

SINGLE FAMILY HOME: DWELLING UNIT: A building, or any portion thereof, containing a complete set of independent living facilities for occupancy and use by one family, including permanent provisions for living, sleeping, eating, sanitation, and cooking within a kitchen for the exclusive use of the occupants whose intent is to inhabit the dwelling unit.

COOKING EQUIPMENT: A stove, range or other such appliances, which requires a 220V or gas connection that is used, designed, or intended to be used for the cook and preparing of food.

A sidewalk is required for all frontages facing a street
<http://fortworthtexas.gov/planninganddevelopment/permits/streets/>

Reviewer: Lamonica Smith
Email: Lamonica.Smith@fortworthtexas.gov
Phone:

1 ****Transportation Impact Fees****

2025 rate with no adequate facilities discount. Fees covered by CA-24-019.

Planning Development Department