



Residential New Building Permit Plan Review Comments

Application: PB25-11485

Date Submitted: 08/13/2025

Status: Issued

Date Issued: 09/08/2025

Address: 7444 HARRIER ST

Parcel: 1592452

Zoning: A-5

Subdivision: TALON HILL ADDITION

Lot/Block: 28/B

Description of Work: Construction of new single-family residence
3rd Party Plan Review & Inspections
North Texas Inspection Services

ADA TDLR:

Energy Code Compliant:

Applicant: Stacie Hamby

Owner: BYD TALON FP LLC

8220 Clifford St

1105 GLADE RD STE 100

White Settlement, TX 76108

COLLEYVILLE,, TX 76034

8172467780

Building Classification:

| Occ Class | Const Type | Square Feet | Occ Load | Use Description |
|-----------|------------|-------------|----------|--------------------|
| R-3 | VB | 3480 | | Living Area |
| U | VB | 574 | | Garage/Porch/Patio |

Sprinkler Sys Req:

Comment: Signs, Retaining Walls over 4', Fences, Dumpster Enclosures over 6', and Parkway Approaches and Sidewalks require separate permits and reviews.

Required Corrections:

Building

Reviewer: Stacie Hamby

Email: stacie@ntispros.com

Phone: (817) 246-7780

1.

Planning Development Department



Residential New Building Permit Plan Review Comments

Water

Reviewer: Shundalyn Evans

Email:

Phone:

1. 08/26/25 --CORRECTIONS REQUIRED-- Fees Due.

Water/sewer impact + reducer fees due ONCE SERVICE REPORT HAS BEEN APPROVED.
Contact Water Applications at 817-392-8250 or WaterApps@fortworthtexas.gov to provide
proposed water meter and sewer information.

*****NOTE*****

It is the responsibility of the builder to uncover the water and sewer services. Water service must
be exposed before meter can be set.

Approval Table:

| Task Name | Task Status | Completed Date | Task Rev Name |
|------------------------------|------------------------------|----------------|----------------------|
| Application Submittal | Routed for Electronic Review | 08/15/2025 | Sonia Rios |
| Water Development Review | Approved | 09/08/2025 | Elizabeth Armendariz |
| Transportation Impact Review | Approved | 08/20/2025 | Lamonica Smith |
| Urban Forestry Review | Approved | 08/22/2025 | Gustavo Ramirez |
| Zoning Review | Approved | 08/22/2025 | Gustavo Ramirez |
| PARD Review | Not Required | 08/18/2025 | Germaine Joseph |
| Building Plan Review | Approved | 08/22/2025 | 3PTY NORTH TEXAS |
| Issue Permit | Issued | 09/08/2025 | Brittania Rosborough |
| Inspections | | | |
| Mechanical Plan Review | Approved | 08/22/2025 | 3PTY NORTH TEXAS |
| Plumbing Plan Review | Approved | 08/22/2025 | 3PTY NORTH TEXAS |
| Electrical Plan Review | Approved | 08/22/2025 | 3PTY NORTH TEXAS |
| Plan Distribution | Routed for Electronic Review | 09/08/2025 | Elizabeth Armendariz |
| Plans Coordination | Approved | 09/08/2025 | Gustavo Ramirez |
| TPW CFRA Review | Not Required | 08/26/2025 | Robin Stevens |

General Comments and Additional Permit Information:

Planning Development Department



Residential New Building Permit Plan Review Comments

Reviewer: Gustavo Ramirez
Email: Gustavo.Ramirez@fortworthtexas.gov
Phone:

1 Zoning Plans Exam

Residential Zoning Review Notes PB25-11485 | 7444 HARRIER ST | Plan# LAWSON
TRN
Planning and Development Department
Zoning Review Notes: All reviews are pending stakeout inspection
CFW Zoning Ordinance # 13896-19602

Permit data confirmed on: 8/22/2025
By: Gustavo Ramirez [817-392-7849]
Scope of project: Single-Family Residence

Plan Review Contact: North Texas

HOLD NOTES: All items labeled "HOLD" must be addressed

SUMMARY: Permit meets minimum standards Y
Holds: ____

Zoning district: "A-5" built to standard "A-5" Type of layout: Single-Family Residence

Official Plat: Attached to plans lot 28 / block B number verified Y
Talon Hill Addition - FP-24-076 - Filing date: 11/22/2024

Building Square footage: R-3: 3480 U: 574
Slab SF: 3004
Lot Area SF: 15435

Lot coverage: 50% maximum, including all structures (Provided 20%)

Height: 35' maximum (Provided 26.92')

Lot Width: 50' minimum at building line (Provided 92.2')

Front yard driveway coverage: 50% maximum (Provided 20.51%)

Setback restrictions: (The front yard setback in residential districts shall be the greatest of:
The platted building line; The setback for the applicable zoning district; or the setback of
the nearest building on either side that is the closest to the street, up to a maximum
setback of 50 feet, provided that said setback is not the result of a variance granted by the
Board of Adjustment)

Front: 20' minimum (Provided 20')
Houses on either side: _ HOA LOT _ / _ VACANT _ per 3rd party site plan (verify on aerial
photo)

Planning Development Department



Residential New Building Permit Plan Review Comments

Sides: 5' minimum (Provided Left _ more than 24.17' & Right 17.92')

Rear: 5' minimum (Provided _77.65')

Note: As applicable, any fence located within an easement will require permission of the easement holder(s) to encroach.

Parking spaces:

Ord. 21528 Single Family Home: Two spaces located behind the front building wall for dwelling units with three or fewer bedrooms, plus one space located behind the front building wall or in the driveway for each bedroom above three.

Bedrooms: 4 Parking spaces required 3 provided 4

Required parking spaces must be hard surface and dust free (asphalt or concrete). All maneuvering space must be located off of the public right of way.

Urban Forestry: property is vested, infill or UFC: (UFC21-0254) Planting Requirements: 2 large-canopy trees per residential lot 5,000 – 9,999 sq. ft.; 3 large-canopy trees per residential lot 10,000 – 14,999 sq. ft.; 4 large-canopy trees per residential lot greater than 15,000 + sq. ft. - provided Y)

An infill house shall be required to have a minimum 3" caliper front yard tree of choice, and one minimum 3" caliper street parkway tree as approved by the City Forester.

Single Family Design Standards:

The same elevation shall not be permitted within a six-lot pattern, on an adjacent lot or on a lot directly across the street.

Exterior walls shall consist of a minimum of 50% masonry. Exposures to a minor arterial or wider street shall require 100% masonry construction except where such building face is obscured by a minimum six (6) foot masonry wall. "Masonry" shall include brick, stone, cementitious fiber concrete products or stucco. Similar products made from such materials and/or durable recycled material shall be allowed as approved by the Building Official.

No attached garage facing a public or private street may project greater than eight (8) feet in front of the front wall of the house in all Single-Family Districts.

Additional Comments:

Sec. 22-176. Curb cuts and laid-down curb permit procedures.

The location of ingress and egress driveways shall be subject to approval of the city traffic engineer under curb cut or laid-down curb permit procedures. Driveways shall not exceed sixty-five (65) per cent of the property frontage. There shall be a minimum of twenty (20)

Planning Development Department

feet of curb along the street between driveways where there is more than one driveway on property under unified ownership or control and used as one premise. The decision of the city traffic engineer may be appealed to the city council. (Code 1964, § 26-102.3; Ord. No. 8288, § 1, 3-10-81)

SINGLE FAMILY HOME: DWELLING UNIT: A building, or any portion thereof, containing a complete set of independent living facilities for occupancy and use by one family, including permanent provisions for living, sleeping, eating, sanitation, and cooking within a kitchen for the exclusive use of the occupants whose intent is to inhabit the dwelling unit.

COOKING EQUIPMENT: A stove, range or other such appliances, which requires a 220V or gas connection that is used, designed, or intended to be used for the cook and preparing of food.

A sidewalk is required for all frontages facing a street
<http://fortworthtexas.gov/planninganddevelopment/permits/streets/> .

Reviewer: Lamonica Smith
Email: Lamonica.Smith@fortworthtexas.gov
Phone:

2 ****Transportation Impact Fees****

2025 rate with 50% adequate facilities discount.

Planning Development Department