



Residential New Building Permit Plan Review Comments

Application: PB25-13143

Date Submitted: 09/18/2025

Status: Issued

Date Issued: 10/08/2025

Address: 820 GLEN GARDEN DR

Parcel: 173779

Zoning: A-5

Subdivision: RYAN SOUTHEAST ADDITION

Lot/Block: 14/56

Description of Work: NEW SFR/ 3RD PTY PLAN REVIEW AND INSPECTION/ ROSS INSPECTIONS

ADA TDLR:

Energy Code Compliant:

Applicant: Diana Carter

Owner: BARKSDALE, MAURICE LEE

10401 Prairie Heights Ct

2400 TABLE ROCK CT

Fort Worth, TX 76108

ARLINGTON,, TX 76006

6823092189

Building Classification:

Occ Class	Const Type	Square Feet	Occ Load	Use Description
R-3	VB	1698		
U	VB	164		

Sprinkler Sys Req:

Comment: Signs, Retaining Walls over 4', Fences, Dumpster Enclosures over 6', and Parkway Approaches and Sidewalks require separate permits and reviews.

Required Corrections:

PARD

Reviewer: Germaine Joseph

Email: Germaine.Joseph@fortworthtexas.gov

Phone:

1. PARD/PDP: This development is within the boundaries of Park Planning District 4; the Neighborhood & Community Park Dedication Policy applies. There is a required \$1,393.58 due for each single-family residential unit or duplex on an undeveloped lot. On a lot with a teardown, there is a required \$1,393.58 due for each additional residential unit (duplex). Please upload the demolition/razing permit. Tear down and replace in-kind, no PARD-PDP fee is due. Call Development Services @ 817-392-2222, if you need assistance on making a payment. Call Lori Gordon @ 817-392-5743 for information regarding the fee and to what it is applied. All fees must be paid in full for single family residential or duplex, at or before building permit issue. No city permits will be issued until the PDP fees have been paid.

Planning Development Department



Residential New Building Permit Plan Review Comments

Approval Table:

Task Name	Task Status	Completed Date	Task Rev Name
Application Submittal	Routed for Electronic Review	09/19/2025	Latrica Jelks
Water Development Review	Approved	10/07/2025	Elizabeth Armendariz
Historical Review	Approved	09/24/2025	Dexter Davis
NEZ Certification Review	Opt-Out	09/19/2025	Latrica Jelks
Transportation Impact Review	Not Required	09/22/2025	Lamonica Smith
Urban Forestry Review	Approved	09/24/2025	Dexter Davis
Zoning Review	Approved	09/24/2025	Dexter Davis
PARD Review	Approved	09/23/2025	Germaine Joseph
Building Plan Review	Approved	09/24/2025	3PTY ROSS INSPECTION SERVICES
Issue Permit	Issued	10/08/2025	Camille Henderson
Inspections			
Mechanical Plan Review	Approved	09/19/2025	Latrica Jelks
Plumbing Plan Review	Approved	09/19/2025	Latrica Jelks
Electrical Plan Review	Approved	09/19/2025	Latrica Jelks
Plan Distribution	Routed for Electronic Review	10/07/2025	Elizabeth Armendariz
Plans Coordination	Approved	10/07/2025	Inkah Reviere
NEZ Design Guidelines Review	Not Required	09/24/2025	Dexter Davis

General Comments and Additional Permit Information:

Reviewer: Dexter Davis
Email: Dexter.Davis@fortworthtexas.gov
Phone: 817-392-5985

1 Zoning Plans Exam
Residential Zoning Review Notes
Planning and Development Department
Zoning Review Notes: All reviews are pending stakeout inspection
CFW Zoning Ordinance # 13896-19602
Permit data confirmed on: 9/24/25
By: Dexter.Davis [817-392-5985]-Dexter.Davis@fortworthtexas.gov
Permit number: PB25-13143
Address: 820 Glen Garden Dr

Planning Development Department



Residential New Building Permit Plan Review Comments

Legal address: RYAN SOUTHEAST ADDITION Block 56 Lot 14

Scope of project: New Single Family Home

HOLD NOTES: All items labeled "HOLD" must be addressed

SUMMARY: Permit meets minimum standards Y

Zoning district: Morningside Neighborhood (HC) Type of layout: Single-Family Detached Residence

Official Plat: Ryan's Southeast Addition

Building Square footage: R-3: 1698 U: 164 Total= 1862 sq. ft.

Lot coverage: 50% maximum, including all structures (Provided 31%)

Height: 35' maximum (Provided 11')

Lot Width: 50' minimum at building line (Provided 50')

Front yard driveway coverage: 50% maximum (Provided less than max)

Setback restrictions: (The front yard setback in residential districts shall be the greatest of: The platted building line; The setback for the applicable zoning district; or the setback of the nearest building on either side that is the closest to the street, up to a maximum setback of 50 feet, provided that said setback is not the result of a variance granted by the Board of Adjustment)

Front: 20' minimum (Provided 25')

Sides: 5' minimum (Provided 5'-left and 13'-right)

Rear: 5' minimum (Provided 35'2")

Note: As applicable, any fence located within an easement will require permission of the easement holder(s) to encroach.

Parking spaces:

Ord. 21528 Single Family Home: Two spaces located behind the front building wall for dwelling units with three or fewer bedrooms, plus one space located behind the front building wall or in the driveway for each bedroom above three.

Bedrooms: 4 Parking spaces required 3 provided 4

Required parking spaces must be hard surface and dust free (asphalt or concrete). All maneuvering space must be located off of the public right of way.

Urban Forestry: property is vested, infill, or has approved UFC permit: (letter or UFC # provided Y/LETTER)

An infill house shall be required to have a minimum 3" caliper front yard tree of choice, and one minimum 3" caliper street parkway tree as approved by the City Forester.

Single Family Design Standards:

The same elevation shall not be permitted within a six lot pattern, on an adjacent lot or on a lot directly across the street.

Exterior walls shall consist of a minimum of 50% masonry. Exposures to a minor arterial or wider street shall require 100% masonry construction except where such building face is obscured by a minimum six (6) foot masonry wall. "Masonry" shall include brick, stone, cementitious fiber concrete products of

stucco. Similar products made from such materials and/or durable recycled material shall be allowed as approved by the Building Official.

No attached garage facing a public or private street may project greater than eight (8) feet in front of the front wall of the house in all Single-Family Districts.

Additional Comments: Certificate of Appropriateness Historic & Cultural Landmarks

Commission Luis Pena (UP DFW Properties LLC) / Jose Juarez (United Properties) 820

Planning Development Department



Residential New Building Permit Plan Review Comments

Glen Garden Drive On August 11, 2025, the Historic & Cultural Landmarks Commission (HCLC) APPROVED a request for a Certificate of Appropriateness to construct a single-story residence (1,862 sqft) at the above-referred address within the Morningside Historic District. All in accordance with the plans (HCLC-25-135) stamped 'APPROVED' on September 16, 2025, that addressed the conditions outlined by the HCLC at its August 11, 2025, meeting. FINDINGS IN ACCORDANCE WITH STANDARDS Historic Morningside District Guidelines: New Construction The proposed structure reflects the contributing elements and patterns found within the neighborhood, the streetscape, and the block where it will be located. Secretary of the Interior's Standards for the Treatment of Historic Properties: Standards 9 and 10 The proposed project is consistent with the Secretary of the Interior's Standards for new construction and will be compatible with its neighborhood. APPROVALS AND PERMITS The Historic and Cultural Landmarks Commission or Historic Preservation Officer must approve work not included in this Certificate of Appropriateness prior to the issuance of a building permit. Approval of your case does not negate you from any other applicable requirements needed to obtain required permits. If necessary, you must obtain all required variances before a building permit will be issued. APPEALS AND CERTIFICATE OF APPROPRIATENESS VALIDITY An appeal to this decision may be submitted by written request to the City Secretary and the Historic Preservation Officer within 15 days of the date of this decision. Certificates of Appropriateness are valid for two years from the date of issuance. FURTHER INFORMATION Questions regarding this case may be forwarded to the Development Services Department at (817) 392-8000

Sec. 22-176. Curb cuts and laid-down curb permit procedures.

The location of ingress and egress driveways shall be subject to approval of the city traffic engineer under curb cut or laid-down curb permit procedures. Driveways shall not exceed sixty-five (65) per cent of the property frontage. There shall be a minimum of twenty (20) feet of curb along the street between driveways where there is more than one driveway on property under unified ownership or control and used as one premise. The decision of the city traffic engineer may be appealed to the city council. (Code 1964, § 26-102.3; Ord. No. 8288, § 1, 3-10-81)

SINGLE FAMILY HOME: DWELLING UNIT: A building, or any portion thereof, containing a complete set of independent living facilities for occupancy and use by one family, including permanent provisions for living, sleeping, eating, sanitation, and cooking within a kitchen for the exclusive use of the occupants whose intent is to inhabit the dwelling unit.

COOKING EQUIPMENT: A stove, range or other such appliances, which requires a 220V or gas connection that is used, designed, or intended to be used for the cook and preparing of food.

Reviewer: Diana Carter

Email: Diana.Carter@fortworthtexas.gov

Phone: (817) 713-8619

2 BUILDING - SHALL COMPLY WITH THE CITY'S CURRENT ADOPTION OF THE 2021 IRC INCLUDING BUT NOT LIMITED TO:

-Address shall be posted and visible at all times from street. SEC.R319

-Steel lintels or engineer's design required for low eyebrow arches, refer to City of Fort Worth lintel

Planning Development Department



Residential New Building Permit Plan Review Comments

schedule. SEC606.9

-New construction and additions greater than 500 square feet must have engineered foundation plans

-5/8" gypsum board required for storage under stairs. SEC. R302.7

-Bedroom fire egress window/ door 5.7 SQFT minimum openable space (grade floor openings 5 sq ft) SEC. R310

-A flight of stairs shall not have a vertical rise greater than 147 in. between floor levels or landings
SEC. R311.7.3

-All staircases need to meet the requirements set forth in SEC. R311

-Attic access required with minimum dimension of 22" by 30" SEC.R807.1

-Garage/Dwelling separation shall comply with Table R302.6

-Doors separating garage and dwelling must comply with R302.5.1. (equipped with a self-closing device)

-Driveway approach (es) shall meet City of Fort Worth standard drawings and separate permit from

T&PW construction division required. Regardless of whether the approach and/or sidewalks will be

new or not T&PW will still need to be contacted for a site inspection

-Window sills located greater than 72" above the outside grade must be a minimum 24" above the finished floor level or have an approved child safety lock that comply with ASTM-F2090. R312.2.1.

-Lots shall be graded to drain away from foundations at a min. 6" in the first 10'. (slope must be 1:20) SEC R401.3

-Termite control: foundations must be exposed a minimum 6" for siding and 4" for brick veneer with brick ledge

-Doors between the garage and residence shall be equipped with solid wood doors not less than

1-3/8 inches (35 mm) in thickness, solid or honeycomb core steel doors not less than 1-3/8 inches

(35 mm) thick, or 20-minute fire-rated doors, equipped with a self-closing or automatic-closing

device per R302.5

ELECTRICAL - SHALL COMPLY WITH THE CITY'S CURRENT ADOPTION OF THE 2023 NEC INCLUDING

BUT NOT LIMITED TO:

-Receptacles serving kitchen islands and peninsulas can not be mounted below the countertop work

surface. Receptacles serving island and peninsulas countertops is optional, however if installed

must be installed accordance to the rules in Section 210.52(C)(3)

-Emergency disconnects required per 2023 NEC Article 230.85

-Surge protection devices (SPD) required for all services supplying dwellings units per

Planning Development Department



Residential New Building Permit Plan Review Comments

2023 NEC

Article 230.67. Minimum Type 1 or Type2

-Requires GFCI protection to include all kitchen 120 volt & 240 volt receptacles and service

receptacles in the attic NEC 210.8(E)

-Requires GFCI protection including all appliances such as ranges, wall ovens, counter mounted

cooktops and microwave ovens whether hardwired or cord and plug connected NEC

210.8(D)

-Requires GFCI protection to all receptacles in the laundry rooms including 240 volt dryer receptacles NEC 210.8

-Requires GFCI protection for all exterior outlets for 125 volt through 250 volt excluding AC condensers and hardwired lighting NEC 210.8(F)

-All receptacles installed in bathrooms, garages, outdoors, crawl spaces, basements, kitchen

countertops, within 6' of a sink, within 6' of a bathtub or shower stall, laundry areas and indoor

damp and wet locations. Exterior receptacles to be GFCI & weather protected 2023 NEC, Article

210.8 (A)

-Carbon monoxide detector locations required per SEC R315.3

-Smoke detector locations required per SEC.R314.3. Smoke detectors required hard-wired w/battery backup per SEC.R314.6

-Hydro massage bathtub, spa and hot tub locations must be GFCI protected 2023 NEC, Article

680.43(A)

-Service outlets required within 25 feet of mechanical equipment in the attic per 2023 NEC, Article

210.63

-Electrical panels labeled and marked for use per 2023 NEC, Article 408.58

-Branch circuits to AC condensing units shall be minimum of 10 AWG copper conductors. 2023 NEC,

Article 440.6 see FWEC Ordinance No. 18358-11-2008

-Receptacles shall be properly spaced per 2023 NEC Article 201.50

-Tamper resistance rec. req. per 2023 NEC 406.12

-At least one receptacle outlet shall be installed in each vehicle bay and not more than 5.5' above

floor per 2023 NEC 210.52 (G)(1)

MECHANICAL: SHALL COMPLY WITH THE CITY'S CURRENT ADOPTION OF THE 2021 IMC

INCLUDING BUT NOT LIMITED TO

-Attics containing appliances require one of three access entrances 1) permanent stair, 2)300 lb pull

down stair, 3) access door from an upper floor level. SEC M1305.1.3 amendments. - Mechanical

equipment in garage area must be 18" above finished floor. SEC.2408.2

-A level service space not less than 30" deep by 30" wide shall be placed on the service side of the

mechanical units placed in attics. SEC.M1305.1

Planning Development Department

-A 125-volt receptacle shall be located within 25' of mechanical equipment in the attic for service

and maintenance. SEC.E3901.12

PLUMBING: SHALL COMPLY WITH THE CITY'S CURRENT ADOPTION OF THE 2021 IPC INCLUDING

BUT NOT LIMITED TO

-Water heaters in garage required 18" above finish floor. SEC.G2408.2 (305.2)

-Water heater not allowed in attic-single family, duplex or multi-family. SEC. M1305.1.3

(EXCEPTION: Tankless water heaters)

-Vacuum breaker required on all hose bibs. SEC.P2903.8.5

-When water pressure exceeds 80 psi, pressure reducing valve is required.

SEC.P2903.3.1

-Full-open shut-off valves to be installed at the home and a second water shut-off valve near the

water meter per 2021 IPC 606.1

ENERGY: SHALL COMPLY WITH THE CITY'S CURRENT ADOPTION OF THE 2015 IECC INCLUDING BUT

NOT LIMITED TO:

-Energy shall comply with the compliance path as the proposed energy report submitted for the

building permit

-A fresh air intake system shall be installed on homes equipped with gas furnaces and the fresh air

intake system shall be filtered before air is entered the home through the supply duct plenum

-High efficiency furnaces (min 90%) shall be installed in sealed foamed attics and with the combustible air taken from the exterior of the home