



Residential New Building Permit Plan Review Comments

Application: PB25-12828

Date Submitted: 09/11/2025

Status: Issued

Date Issued: 10/15/2025

Address: 4120 JOSHUA SPRINGS CIR

Parcel: 1657135

Zoning: A-5

Subdivision:

Lot/Block: 16/5

Description of Work: new construction single family residence

ADA TDLR:

Energy Code Compliant:

Applicant:

Owner: ALVARADO, RAUL

9333 N. Normandale

4216 N CORAL SPRINGS DR

FT. Worth, TX 76116

FORT WORTH,, TX 76123 145

Building Classification:

Occ Class	Const Type	Square Feet	Occ Load	Use Description
R-3	VB	1142	6	Living
U	VB	347	2	Garage/Porch

Sprinkler Sys Req:

Comment: Signs, Retaining Walls over 4', Fences, Dumpster Enclosures over 6', and Parkway Approaches and Sidewalks require separate permits and reviews.

Required Corrections:

Water

Reviewer: Michelle Canright

Email: Michelle.Canright@fortworthtexas.gov

Phone:

1. 10/14/25 - CORRECTIONS REQUIRED - Fees Due. Water/sewer impact + reducer fees due. ONCE SERVICE REPORT HAS BEEN APPROVED.
09.25.25 - CORRECTIONS REQUIRED - Fees Due. Water/sewer impact + reducer fees due. ONCE SERVICE REPORT HAS BEEN APPROVED. Contact Water Applications at 817-392-8250 or WaterApps@fortworthtexas.gov to provide proposed water meter and sewer information.

Please provide billing information through third party standard process.

Planning Development Department



Residential New Building Permit Plan Review Comments

Zoning

Reviewer: Cynthia1 Flores-Frausto1

Email: Cynthia.Flores-Frausto@fortworthtexas.gov

Phone:

1. 9/18/2025 – Correction Required- Street Tree

Per ordinance 6.507(d) Infill house. An infill house shall be required to have one minimum three-inch caliper front yard tree of choice, and one minimum three-foot caliper street parkway tree as approved by the city forester. In all instances, a minimum of 40% canopy cover per lot must be achieved in accordance with § 6.302.

The site plan provided shows that there is one tree within the property lines and the other in the street. Street trees require an approval letter from the City Forester. Please provide the City Forester approval letter (contact info below if needed) or revise the site plan that shows 2 trees are within the property lines for this lot.

City Forester: Craig Fox – 817 392 5729 or craig.fox@fortworthtexas.gov

*Reminder that all revised files must be uploaded in a complete plan set for all submittals.

Additional holds may apply after revised files are received.

Approval Table:

Task Name	Task Status	Completed Date	Task Rev Name
Application Submittal	Routed for Electronic Review	09/16/2025	Deshia Hawkins
Water Development Review	Approved	10/15/2025	Cristina Casso
Transportation Impact Review	Approved	09/19/2025	Lamonica Smith
Urban Forestry Review	Approved	09/18/2025	Cynthia1 Flores-Frausto1
Zoning Review	Approved	10/09/2025	Cynthia1 Flores-Frausto1
PARD Review	Not Required	09/17/2025	Germaine Joseph
Building Plan Review	Approved	09/22/2025	Scott Edwardson
Issue Permit	Issued	10/15/2025	Tina Green
Inspections			
Mechanical Plan Review	Approved	09/22/2025	Scott Edwardson
Plumbing Plan Review	Approved	09/22/2025	Scott Edwardson
Electrical Plan Review	Approved	09/22/2025	Scott Edwardson
Plan Distribution	Routed for Electronic Review	10/15/2025	Cristina Casso
Plans Coordination	Approved	10/15/2025	Scott Edwardson
Parkway Review	Approved	09/18/2025	Jefferson Owens

Planning Development Department



Residential New Building Permit Plan Review Comments

General Comments and Additional Permit Information:

Reviewer: Scott Edwardson
Email: Scott.Edwardson@fortworthtexas.gov
Phone: (817) 392-6288

1 ***** Residential Code Review Comments *****

City Plans Examiner: Scott Edwardson
Phone # (817) 392-6288
Scott.Edwardson@fortworthtexas.gov
Date 09/22/2025
Development Services
Residential Review Notes
IRC 2021
Permit: PB25-12828
Address: 4120 Joshua Springs Cir.
Legal Desc: Garden Springs Phase IX Addition Block 5 Lot 16
Contact: James Burke
Construction type: VB
Project Area: 1489
Occupancy & Use: R-3 – 1142; U – 347
Zoning A-5
Lot Size: 4989.16
Lot Coverage: 29.84%
Scope of Work: New SFR

Professional engineer
Certified foundation plans Russell J. Whitworth P.E. 82117
Professional engineer who certified structural plans: N/R
Braced wall plans: Russell J. Whitworth P.E. 82117

WINDOWS

Max U-factor is 0.35
Max SHGC is 0.25

DOORS – U-factor

Uninsulated metal: 1.2
Insulated metal: 0.6
Wood: 0.5
Insulated, nonmetal edge, Max 45% glazing, any glazing double pane 0.35

INSULATION

R-13+5h or R-20 insulation in exterior walls
R-38 insulation in the attic
R-19 insulation in the floor

** General Notes **

NOTE: The general notes listed below are an abbreviated version of the actual notes in

Planning Development Department



Residential New Building Permit Plan Review Comments

the 2021 IRC and CFW Amendment. The builder is responsible for compliance with the full applicable IRC section and/or CFW Amendment.

This Plan is void without City Plan Review Notes.

1. See attached examiner's notes and City handouts as applicable to this permit.
2. See attached site and construction plans as applicable to permit.
3. All work shall conform to City of Fort Worth building code, energy code and zoning requirements.
4. SEPARATE PERMITS ARE REQUIRED for Electrical, Mechanical and Plumbing work.
5. R302.6 Dwelling/garage fire separation.

SEPARATION MATERIAL

From the residence and attics: Not less than 1/2-inch gypsum board or equivalent applied to the garage side from all habitable rooms above the garage: Not less than 5/8-inch Type X gypsum board or equivalent.

6. R302.11 Fireblocking.

In combustible construction, fireblocking shall be provided to cut off all concealed draft openings (both vertical and horizontal) and to form an effective fire barrier between stories, and between a top story and the roof space.

7. BATHROOMS – R303.3 Bathrooms, water closet compartments and other similar rooms shall be provided with aggregate glazing area in windows of not less than 3 square feet, one-half of which must be operable. Artificial light and mechanical ventilation may be provided.

8. EMERGENCY ESCAPE – R310 – basements, habitable attics and each sleeping room shall have at least one operable emergency and rescue opening.

R310.2.1 – All emergency escape and rescue openings shall have a minimum net clear opening of 5.7 sq.ft. Openings on grade shall be a minimum of 5 sq.ft. net clear opening.

R310.2.1 – Minimum opening height is 24"

R310.2.1 – Minimum opening width is 20"

R310.1.1 – Emergency escape and rescue openings shall be operational from the inside of the room without the use of keys, tools or special knowledge.

9. MEANS OF EGRESS – R311

R311.6 – Minimum hallway width shall not be less than 36"

R311.2 – Each dwelling unit shall have not less than one exit door

Planning Development Department



Residential New Building Permit Plan Review Comments

10. SECTION R315 CARBON MONOXIDE ALARMS

R315.2.1 Carbon monoxide alarms and R315.3 Location. For new construction, an approved carbon monoxide alarm shall be installed outside of each separate sleeping area in the immediate vicinity of the bedrooms in dwelling units within which fuel-fired appliances are installed and in dwelling units that have attached garages.

11. WATER HEATERS: M2005.2 – Fuel fired water heaters shall not be installed in a room used as a storage closet.

12. CLOTHES DRYER EXHAUST: 2021 IRC M1502 – Dryer exhaust systems shall be independent of all other systems, and shall terminate on the outside of the building. Exhaust ducts shall be equipped with a backdraft damper.

Reviewer: Lamonica Smith

Email: Lamonica.Smith@fortworthtexas.gov

Phone:

2 ****Transportation Impact Fees****

2025 rate with 50% adequate facilities discount.

Reviewer: Cynthia1 Flores-Frausto1

Email: Cynthia.Flores-Frausto@fortworthtexas.gov

Phone:

3 Zoning Plan Review Performed on: 10/9/2025

By: Cynthia Flores-Frausto – 817 392 7867 – Cynthia.Flores-Frausto@fortworthtexas.gov

Permit #: PB25-12828

Physical Address: 4120 Joshua Springs Cir.

Legal Description: Garden Springs Addition, Block 5, Lot 16

Scope of project: New single-family residence

HOLD NOTES: All items labeled "HOLD" must be addressed. Additional HOLDS may be placed upon review of revisions.

Zoning district: A-5- Type of layout: Single family

Building Square Footage: 1,489 SF

Height: 35' maximum – Provided: 17.59'

Lot Width: 50' minimum at building line = 50'

Lot Coverage: 50% maximum – Provided 29.8%

Front yard driveway coverage: 50% maximum - Provided 20%

Setback restrictions: (The front yard setback in residential districts shall be the greatest of: The platted building line; The setback for the applicable zoning district; or the setback of the nearest building on either side that is the closest to the street, up to a maximum

Planning Development Department



Residential New Building Permit Plan Review Comments

setback of 50 feet, provided that said setback is not the result of a variance granted by the Board of Adjustment)

Front: 20' – Provided: 20'

Interior Side Yard: 5' – Provided: L) 5.17' R) 5.17'

Rear: 5' – Provided: 36.5'

Monotony: other lots vacant in 6 lot pattern

Infill Trees: 2

No attached garage facing a public or private street may project greater than eight (8) feet in front of the front wall of the house in all Single-Family Districts.

No. of bedrooms: 3

Parking spaces required: 2

Parking spaces provided: 2

Section 4.705.D.2 Single Family Home: Two (2) spaces located behind the front building wall for dwelling units with three (3) or fewer bedrooms, plus one (1) space located behind the front building wall or in the driveway for each bedroom above three (3). Required parking spaces must be hard surface and dust free (asphalt or concrete). All maneuvering space must be located off of the public right of way.

Additional Comments:

SINGLE FAMILY HOME: DWELLING UNIT: A building, or any portion thereof, containing a complete set of independent living facilities for occupancy and use by one family, including permanent provisions for living, sleeping, eating, sanitation and cooking within a kitchen for the exclusive use of the occupants whose intent is to inhabit the dwelling unit.

Sec. 22-176. Curb cuts and laid-down curb permit procedures.

The location of ingress and egress driveways shall be subject to approval of the city traffic engineer under curb cut or laid-down curb permit procedures. Driveways shall not exceed sixty-five (65) per cent of the property frontage. There shall be a minimum of twenty (20) feet of curb along the street between driveways where there is more than one driveway on property under unified ownership or control and used as one premise. The decision of the city traffic engineer may be appealed to the city council.

(Code 1964, § 26-102.3; Ord. No. 8288, § 1, 3-10-81)

COOKING EQUIPMENT: A stove, range or other such appliances, which requires a 220V or gas connection that is used, designed, or intended to be used for the cook and preparing of food.

Any detached single family residential dwelling constructed after the effective date of this ordinance April 26, 2007 shall be required to conform to the following architectural and tree planting requirements:

The same elevation shall not be permitted within a six lot pattern, on an adjacent lot or on a lot directly across the street as depicted in the diagram below.

No attached garage facing a public or private street may project greater than eight (8) feet in front of the front wall of the house in all Single-Family Districts.

An infill house shall be required to have a minimum 3" caliper front yard tree of choice, and one minimum 3" caliper street parkway tree as approved by the City Forester. In all instances, a minimum of 40% canopy cover per lot must be achieved in accordance with Section 6.302.D.

Planning Development Department



Residential New Building Permit Plan Review Comments

"A permit will not be issued until the Urban Forestry installation." Please contact the Urban Forestry Compliance staff to get the requirements to submit a UFC plan for review or to provide the UFC number for the Urban Forestry release of the building permit. These may be submitted to <http://fortworthtexas.gov/planninganddevelopment/urbanforestry/>

If your construction project includes alley access or paving in public right of way please email or call WPD@fortworthtexas.gov, 817-392-8428, so that the Water Department can determine if any public water or sewer mains will be paved over. Any identified public mains that the Water Department determines need to be replaced will be scheduled for rehab by the Water Dept. before paving activity can commence. This time line varies so it is critical that the assessment occurs as soon as possible to avoid delaying your project. Any paving over public water or sewer mains will require a review by the Water Department to identify conflicts or encroachments. Exhibits must be drawn to scale, show cross streets, lot boundaries, address and legal description, easements, dimensioning and profile.

Alley will need to be paved from the farthest property line to the nearest street or existing alley paving if it is to be used as access.

A parkway permit is required for all new construction projects for sidewalk(s), if not currently existing.

Zoning Plan Review Performed on: 9/18/2025

By: Cynthia Flores-Frausto – 817 392 7867 – Cynthia.Flores-Frausto@fortworthtexas.gov

Permit #: PB25-12828

Physical Address: 4120 Joshua Springs Cir.

Legal Description: Garden Springs Addition, Block 5, Lot 16

Scope of project: New single-family residence

HOLD NOTES: All items labeled "HOLD" must be addressed. Additional HOLDS may be placed upon review of revisions.

Zoning district: A-5- Type of layout: Single family

Building Square Footage: 1,489 SF

Height: 35' maximum – Provided: 17.59'

Lot Width: 50' minimum at building line = 50'

Lot Coverage: 50% maximum – Provided 29.8%

Front yard driveway coverage: 50% maximum - Provided 20%

Setback restrictions: (The front yard setback in residential districts shall be the greatest of:

Planning Development Department



Residential New Building Permit Plan Review Comments

The platted building line; The setback for the applicable zoning district; or the setback of the nearest building on either side that is the closest to the street, up to a maximum setback of 50 feet, provided that said setback is not the result of a variance granted by the Board of Adjustment)

Front: 20' – Provided: 20'

Interior Side Yard: 5' – Provided: L) 5.17' R) 5.17'

Rear: 5' – Provided: 36.5'

Monotony: other lots vacant in 6 lot pattern

Infill Trees: Hold

No attached garage facing a public or private street may project greater than eight (8) feet in front of the front wall of the house in all Single-Family Districts.

No. of bedrooms: 3

Parking spaces required: 2

Parking spaces provided: 2

Section 4.705.D.2 Single Family Home: Two (2) spaces located behind the front building wall for dwelling units with three (3) or fewer bedrooms, plus one (1) space located behind the front building wall or in the driveway for each bedroom above three (3). Required parking spaces must be hard surface and dust free (asphalt or concrete). All maneuvering space must be located off of the public right of way.

Additional Comments:

SINGLE FAMILY HOME: DWELLING UNIT: A building, or any portion thereof, containing a complete set of independent living facilities for occupancy and use by one family, including permanent provisions for living, sleeping, eating, sanitation and cooking within a kitchen for the exclusive use of the occupants whose intent is to inhabit the dwelling unit.

Sec. 22-176. Curb cuts and laid-down curb permit procedures.

The location of ingress and egress driveways shall be subject to approval of the city traffic engineer under curb cut or laid-down curb permit procedures. Driveways shall not exceed sixty-five (65) per cent of the property frontage. There shall be a minimum of twenty (20) feet of curb along the street between driveways where there is more than one driveway on property under unified ownership or control and used as one premise. The decision of the city traffic engineer may be appealed to the city council.

(Code 1964, § 26-102.3; Ord. No. 8288, § 1, 3-10-81)

COOKING EQUIPMENT: A stove, range or other such appliances, which requires a 220V or gas connection that is used, designed, or intended to be used for the cook and preparing of food.

Any detached single family residential dwelling constructed after the effective date of this ordinance April 26, 2007 shall be required to conform to the following architectural and tree planting requirements:

The same elevation shall not be permitted within a six lot pattern, on an adjacent lot or on a lot directly across the street as depicted in the diagram below.

No attached garage facing a public or private street may project greater than eight (8) feet in front of the front wall of the house in all Single-Family Districts.

An infill house shall be required to have a minimum 3" caliper front yard tree of choice, and one minimum 3" caliper street parkway tree as approved by the City Forester. In all

Planning Development Department

instances, a minimum of 40% canopy cover per lot must be achieved in accordance with Section 6.302.D.

"A permit will not be issued until the Urban Forestry installation." Please contact the Urban Forestry Compliance staff to get the requirements to submit a UFC plan for review or to provide the UFC number for the Urban Forestry release of the building permit. These may be submitted to <http://fortworthtexas.gov/planninganddevelopment/urbanforestry/>

If your construction project includes alley access or paving in public right of way please email or call WPD@fortworthtexas.gov, 817-392-8428, so that the Water Department can determine if any public water or sewer mains will be paved over. Any identified public mains that the Water Department determines need to be replaced will be scheduled for rehab by the Water Dept. before paving activity can commence. This time line varies so it is critical that the assessment occurs as soon as possible to avoid delaying your project. Any paving over public water or sewer mains will require a review by the Water Department to identify conflicts or encroachments. Exhibits must be drawn to scale, show cross streets, lot boundaries, address and legal description, easements, dimensioning and profile.

Alley will need to be paved from the farthest property line to the nearest street or existing alley paving if it is to be used as access.

A parkway permit is required for all new construction projects for sidewalk(s), if not currently existing.

Planning Development Department