



Residential New Building Permit Plan Review Comments

Application: PB25-15374

Date Submitted: 11/04/2025

Status: Issued

Date Issued: 12/09/2025

Address: 4224 WOODHILL BEND DR

Parcel: 1575599

Zoning: A-5

Subdivision: HAMPTON TRACT

Lot/Block: 58/A

Description of Work: Construction of new single-family residence
3rd Party Plan Review & Inspections
North Texas Inspection Services

ADA TDLR:

Energy Code Compliant:

Applicant: Stacie Hamby

Owner: D R HORTON - TEXAS LTD

8220 Clifford St

6751 N FRWY

White Settlement, TX 76108

FORT WORTH,, TX 76131

8172467780

Building Classification:

| Occ Class | Const Type | Square Feet | Occ Load | Use Description |
|-----------|------------|-------------|----------|-----------------|
| R-3 | VB | 1434 | | Living Area |
| U | VB | 428 | | Garage/Porch |

Sprinkler Sys Req:

Comment: Signs, Retaining Walls over 4', Fences, Dumpster Enclosures over 6', and Parkway Approaches and Sidewalks require separate permits and reviews.

Required Corrections:

Building

Reviewer: Stacie Hamby

Email: stacie@ntispros.com

Phone: (817) 246-7780

1.

Planning Development Department



Residential New Building Permit Plan Review Comments

Water

Reviewer: Ibeth Heatley

Email: Ibeth.Heatley@fortworthtexas.gov

Phone:

1. 11/14/25 -- CORRECTIONS REQUIRED -- Fees Due.

Water/sewer impact + reducer fees due. Contact Water Applications at 817-392-8250 or WaterApps@fortworthtexas.gov to provide proposed water meter and sewer information in addition to customer billing information.

NOTE

It is the responsibility of the builder to uncover the water and sewer services. Water service must be exposed before meter can be set.

Approval Table:

| Task Name | Task Status | Completed Date | Task Rev Name |
|------------------------------|------------------------------|----------------|-----------------|
| Application Submittal | Routed for Electronic Review | 11/05/2025 | Jasmine Lujan |
| Water Development Review | Approved | 12/08/2025 | Ibeth Heatley |
| Transportation Impact Review | Approved | 11/07/2025 | Lamonica Smith |
| Urban Forestry Review | Approved | 11/05/2025 | David Parker |
| Zoning Review | Approved | 11/05/2025 | David Parker |
| PARD Review | Not Required | 11/05/2025 | Germaine Joseph |
| Building Plan Review | Approved | 11/05/2025 | 3PTY METRO CODE |
| Issue Permit | Issued | 12/09/2025 | Paula Fukuhara |
| Inspections | | | |
| Mechanical Plan Review | Approved | 11/05/2025 | Jasmine Lujan |
| Plumbing Plan Review | Approved | 11/05/2025 | Jasmine Lujan |
| Electrical Plan Review | Approved | 11/05/2025 | Jasmine Lujan |
| Plan Distribution | Routed for Electronic Review | 12/08/2025 | Ibeth Heatley |
| Plans Coordination | Approved | 12/08/2025 | David Parker |
| TPW CFRA Review | Not Required | 11/14/2025 | Robin Stevens |

General Comments and Additional Permit Information:

Planning Development Department



Residential New Building Permit Plan Review Comments

Reviewer: David Parker
Email: David.Parker@fortworthtexas.gov
Phone: 817-392-2657

3 Zoning Plans Exam

Residential Zoning Review Notes PB25-15374 | 4224 Woodhill Bend Dr | Plan# T30C R H
Planning and Development Department
Zoning Review Notes: All reviews are pending stakeout inspection
CFW Zoning Ordinance # 13896-19602

Permit data confirmed on: 11/5/2025
By: David Parker [817-392-2657]

Scope of project: Single-Family Residence

HOLD NOTES: All items labeled "HOLD" must be addressed

SUMMARY: Permit meets minimum standards Y
Holds: ____

Zoning district: "A-5" to "A-5" Type of layout: Single-Family Residence

Official Plat: Attached to plans lot 58 / block A number verified Y
Kirk Tract – FP-24-007 - Filling date 9/16/2024

Building Square footage: R-3: 1434 U: 428
Slab SF: 1862
Lot Area: 5449

Lot coverage: 50% maximum, including all structures (Provided 34.00%)

Height: 35' maximum (Provided 15.75')

Lot Width: 50' minimum at building line (Provided 50.00')

Front yard driveway coverage: 50% maximum (Provided 36.00%)

Setback restrictions: (The front yard setback in residential districts shall be the greatest of: The platted building line; The setback for the applicable zoning district; or the setback of the nearest building on either side that is the closest to the street, up to a maximum setback of 50 feet, provided that said setback is not the result of a variance granted by the Board of Adjustment)

Front: 20' minimum (Provided 20.00')
Houses on either side: (Left: DNO / Right: 20.00')

Sides: 5' minimum (Provided Left: 10.04' / Right: 10.00')

Planning Development Department



Residential New Building Permit Plan Review Comments

Rear: 5' minimum (Provided 23.83')

Note: As applicable, any fence located within an easement will require permission of the easement holder(s) to encroach.

Parking spaces:

Ord. 21528 Single Family Home: Two spaces located behind the front building wall for dwelling units with three or fewer bedrooms, plus one space located behind the front building wall or in the driveway for each bedroom above three.

Bedrooms: 3 Parking spaces required 2 provided 4

Required parking spaces must be hard surface and dust free (asphalt or concrete). All maneuvering space must be located off of the public right of way.

Urban Forestry: property is vested, infill or UFC: (letter or UFC # provided Y – UFC22-0116

Planting Requirements: 1 large canopy and 1 small canopy tree per residential lot

An infill house shall be required to have a minimum 3" caliper front yard tree of choice, and one minimum 3" caliper street parkway tree as approved by the City Forester.

Single Family Design Standards:

The same elevation shall not be permitted within a six-lot pattern, on an adjacent lot or on a lot directly across the street.

Exterior walls shall consist of a minimum of 50% masonry. Exposures to a minor arterial or wider street shall require 100% masonry construction except where such building face is obscured by a minimum six (6) foot masonry wall. "Masonry" shall include brick, stone, cementitious fiber concrete products or stucco. Similar products made from such materials and/or durable recycled material shall be allowed as approved by the Building Official.

No attached garage facing a public or private street may project greater than eight (8) feet in front of the front wall of the house in all Single-Family Districts.

Additional Comments:

Sec. 22-176. Curb cuts and laid-down curb permit procedures.

The location of ingress and egress driveways shall be subject to approval of the city traffic engineer under curb cut or laid-down curb permit procedures. Driveways shall not exceed sixty-five (65) per cent of the property frontage. There shall be a minimum of twenty (20) feet of curb along the street between driveways where there is more than one driveway on property under unified ownership or control and used as one premise. The decision of the city traffic engineer may be appealed to the city council. (Code 1964, § 26-102.3; Ord. No.

Planning Development Department

8288, § 1, 3-10-81)

SINGLE FAMILY HOME: DWELLING UNIT: A building, or any portion thereof, containing a complete set of independent living facilities for occupancy and use by one family, including permanent provisions for living, sleeping, eating, sanitation, and cooking within a kitchen for the exclusive use of the occupants whose intent is to inhabit the dwelling unit.

COOKING EQUIPMENT: A stove, range or other such appliances, which requires a 220V or gas connection that is used, designed, or intended to be used for the cook and preparing of food.

A sidewalk is required for all frontages facing a street
<http://fortworthtexas.gov/planninganddevelopment/permits/streets/>

Reviewer: Ibeth Heatley
Email: Ibeth.Heatley@fortworthtexas.gov
Phone:

1 WATER APPLICATIONS

*** IMPORTANT*** PLEASE READ WATER AND SEWER SERVICE LOCATION REQUIREMENTS ***

Sec 5.18.2.1 Meter boxes can only be installed in non-paved areas. Water service and meter box must be installed 1-foot offset from the property line in the parkway and have a 9-foot horizontal separation from the sewer service. The normal location for meter boxes is 2.5 feet behind the back of curb.

In no case shall the water meter box (and meter) be outside of the public right-of-way or water easement.

Sec 6.4.1.3 Wastewater service should avoid placement in driveways and have a 9-foot horizontal separation from the water service.
Service should be installed South or West of the proposed driveway location.

To prevent delays for a meter set, ensure the following criteria is met:

- Address must be clearly posted, i.e., visible and big enough to see
- No debris or material over the meter box
- Meter box must be in the ground to grade per city specification

Reviewer: Lamonica Smith
Email: Lamonica.Smith@fortworthtexas.gov
Phone:

2 *****Transportation Impact Fees*****

2025 rate with no adequate facilities discount. Fees covered by CA-24-005.

Planning Development Department