



## Residential New Building Permit Plan Review Comments

**Application:** PB25-14861

**Date Submitted:** 10/23/2025

**Status:** Issued

**Date Issued:** 12/11/2025

**Address:** 901 S AYERS AVE

**Parcel:** 122147

**Zoning:** A-5

**Subdivision:** CLAIREMONT PLACE

**Lot/Block:** 7/16

**Description of Work:** NEW CONSTRUCTION SFR/ 3RD PTY PLAN REVIEW AND INSPECTIONS - ROSS INSPECTIONS

**ADA TDLR:**

**Energy Code Compliant:**

**Applicant:** Diana Carter

**Owner:** QUINTERO, JESUS

10401 Prairie Heights Ct

903 S AYERS AVE

Fort Worth, TX 76108

FORT WORTH,, TX 76103

6823092189

**Building Classification:**

Occ Class	Const Type	Square Feet	Occ Load	Use Description
R-3	VB	1690		
U	VB	490		

**Sprinkler Sys Req:**

**Comment:** Signs, Retaining Walls over 4', Fences, Dumpster Enclosures over 6', and Parkway Approaches and Sidewalks require separate permits and reviews.

**Required Corrections:**

Planning Development Department



## Residential New Building Permit Plan Review Comments

### **PARD**

**Reviewer: Germaine Joseph**

**Email: Germaine.Joseph@fortworthtexas.gov**

**Phone:**

1. PARD/PDP: This development is within the boundaries of Park Planning District 4; the Neighborhood & Community Park Dedication Policy applies. There is a required \$1,393.58 due for each single-family residential unit or duplex on an undeveloped lot. On a lot with a teardown, there is a required \$1,393.58 due for each additional residential unit (duplex). Please upload the demolition/razing permit. Tear down and replace in-kind, no PARD-PDP fee is due. Call Development Services @ 817-392-2222, if you need assistance on making a payment. Call Lori Gordon @ 817-392-5743 for information regarding the fee and to what it is applied. All fees must be paid in full for single-family residential or duplex, at or before building permit issue. No city permits will be issued until the PDP fees have been paid. Starting Oct 1, 2025, customers who choose to pay by Credit Card or Debit Card will incur a service fee of 2.5%. There is no service fee to pay by check, ACH, cash, or money order.

### **Water**

**Reviewer: Shundalyn Evans**

**Email:**

**Phone:**

1. 11/04/25 - CORRECTIONS REQUIRED - Fees Due. Water/sewer impact + reducer fees due. Contact Water Applications at 817-392-8250 or WaterApps@fortworthtexas.gov to provide proposed water meter and sewer information.  
  
\*\*Please note fees will not be invoiced until all other holds are cleared
2. 11/04/25 - CORRECTIONS REQUIRED - Fees Due. Water/sewer tap fees due. Contact Water Applications at 817-392-8250 or WaterApps@fortworthtexas.gov to provide proposed water meter and sewer information.

\*\*Please note fees will not be invoiced until all other holds are cleared

### **Approval Table:**

Task Name	Task Status	Completed Date	Task Rev Name
Application Submittal	Routed for Electronic Review	10/24/2025	Andre Duncan
Water Development Review	Approved	12/11/2025	Morris Peyton
NEZ Certification Review	Opt-Out	10/24/2025	Andre Duncan
Transportation Impact Review	Not Required	10/24/2025	Lamonica Smith
Urban Forestry Review	Approved	10/27/2025	Jesus Olmos
Zoning Review	Approved	10/27/2025	Jesus Olmos

Planning Development Department



## Residential New Building Permit Plan Review Comments

PARD Review	Approved	10/24/2025	Germaine Joseph
Building Plan Review	Approved	10/27/2025	3PTY ROSS INSPECTION SERVICES
Issue Permit	Issued	12/11/2025	Rae'Miah James
Inspections			
Mechanical Plan Review	Approved	10/24/2025	Andre Duncan
Plumbing Plan Review	Approved	10/24/2025	Andre Duncan
Electrical Plan Review	Approved	10/24/2025	Andre Duncan
Plan Distribution	Routed for Electronic Review	12/11/2025	Morris Peyton
Plans Coordination	Approved	12/11/2025	Jesus Olmos
NEZ Strategic Guidelines Review	Not Required	10/27/2025	Jesus Olmos
NEZ Design Guidelines Review	Not Required	10/27/2025	Jesus Olmos

### General Comments and Additional Permit Information:

**Reviewer: Jesus Olmos**

**Email: Jesus.Olmos@fortworthtexas.gov**

**Phone:**

#### 2 Zoning Plans Exam

Residential Zoning Review Notes PB25-14861 – 901 S Ayers Ave.  
Planning and Development Department Plan #: Custom Home  
Zoning Review Notes: All reviews are pending stakeout inspection  
CFW Zoning Ordinance # 13896-22519

Permit data confirmed on: 10/27/2025

By: Jesus Olmos Jr. [817-392-7858]

Scope of project: New Single Family Home

HOLD NOTES: All items labeled "HOLD" must be addressed

SUMMARY: Permit meets minimum standards Y

Holds: \_\_\_\_

Zoning district: "A-5" Type of layout: Single-Family Residence

Official Plat: Attached to plans lot/block number verified Y (Clairemont Place, Blk 16 Lot 7)  
Vol 922 PG 457 approved/filed December 1928

Planning Development Department



## Residential New Building Permit Plan Review Comments

Building Square footage: R-3: 1690 U: 490  
Slab SF: 2180  
Lot Area: 9600

Lot coverage: 50% maximum, including all structures (Provided \_23%)

Height: 35' maximum (Provided \_20' 2" \_)

Lot Width: 50' minimum at building line (Provided approx. \_50' \_)

Front yard driveway coverage: 50% maximum (Provided \_36%)

Setback restrictions: (The front yard setback in residential districts shall be the greatest of: The platted building line; The setback for the applicable zoning district; or the setback of the nearest building on either side that is the closest to the street, up to a maximum setback of 50 feet, provided that said setback is not the result of a variance granted by the Board of Adjustment)

Front: front yard setback 20' minimum (Provided \_25')  
Houses on either side: \_Vacant\_ / \_ 25' \_ per 3rd party site plan (verify on aerial photo)

Sides: 5' minimum (Provided \_14' 10" & 5' 0" \_)

Rear: 5' minimum (Provided \_93' 4" \_)

Note: As applicable, any fence located within an easement will require permission of the easement holder(s) to encroach.

### Parking spaces:

Ord. 21528 Single Family Home: Two spaces located behind the front building wall for dwelling units with three or fewer bedrooms, plus one space located behind the front building wall or in the driveway for each bedroom above three. # Bedrooms: \_4\_ Parking spaces required \_3\_ provided \_4\_

Required parking spaces must be hard surface and dust free (asphalt or concrete). All maneuvering space must be located off of the public right of way.

Urban Forestry: infill

### Single Family Design Standards:

The same elevation shall not be permitted within a six-lot pattern, on an adjacent lot or on a lot directly across the street.

No attached garage facing a public or private street may project greater than eight (8) feet in front of the front wall of the house in all Single-Family Districts.

Additional Comments:

Planning Development Department



## Residential New Building Permit Plan Review Comments

Sec. 22-176. Curb cuts and laid-down curb permit procedures.

The location of ingress and egress driveways shall be subject to approval of the city traffic engineer under curb cut or laid-down curb permit procedures. Driveways shall not exceed sixty-five (65) per cent of the property frontage. There shall be a minimum of twenty (20) feet of curb along the street between driveways where there is more than one driveway on property under unified ownership or control and used as one premise. The decision of the city traffic engineer may be appealed to the city council. (Code 1964, § 26-102.3; Ord. No. 8288, § 1, 3-10-81)

**SINGLE FAMILY HOME: DWELLING UNIT:** A building, or any portion thereof, containing a complete set of independent living facilities for occupancy and use by one family, including permanent provisions for living, sleeping, eating, sanitation, and cooking within a kitchen for the exclusive use of the occupants whose intent is to inhabit the dwelling unit.

**COOKING EQUIPMENT:** A stove, range or other such appliances, which requires a 220V or gas connection that is used, designed, or intended to be used for the cook and preparing of food.

A sidewalk is required for all frontages facing a street  
<http://fortworthtexas.gov/planninganddevelopment/permits/streets/> .

**Reviewer: Tina Green**  
**Email: Tina.Green@fortworthtexas.gov**  
**Phone: 817-392-2222**

1 12/10/2025

Fee waived, previous structure PV25-00180.

**Reviewer: Christina Parra**  
**Email: inspections@rossdfw.com**  
**Phone: 817-716-9532**

- 3 BUILDING - SHALL COMPLY WITH THE CITY'S CURRENT ADOPTION OF THE 2021 IRC INCLUDING BUT NOT LIMITED TO:
- Address shall be posted and visible at all times from street. SEC.R319
  - Steel lintels or engineer's design required for low eyebrow arches, refer to City of Fort Worth lintel schedule. SEC606.9
  - New construction and additions greater than 500 square feet must have engineered foundation plans
  - 5/8" gypsum board required for storage under stairs. SEC. R302.7
  - Bedroom fire egress window/ door 5.7 SQFT minimum openable space (grade floor openings 5 sq ft) SEC. R310
  - A flight of stairs shall not have a vertical rise greater than 147 in. between floor levels or landings SEC. R311.7.3

Planning Development Department



## Residential New Building Permit Plan Review Comments

- All staircases need to meet the requirements set forth in SEC. R311
- Attic access required with minimum dimension of 22" by 30" SEC.R807.1
- Garage/Dwelling separation shall comply with Table R302.6
- Doors separating garage and dwelling must comply with R302.5.1. (equipped with a self-closing device)
- Driveway approach (es) shall meet City of Fort Worth standard drawings and separate permit from T&PW construction division required. Regardless of whether the approach and/or sidewalks will be new or not T&PW will still need to be contacted for a site inspection
- Window sills located greater than 72" above the outside grade must be a minimum 24" above the finished floor level or have an approved child safety lock that comply with ASTM-F2090. R312.2.1.
- Lots shall be graded to drain away from foundations at a min. 6" in the first 10'. (slope must be 1:20) SEC R401.3
- Termite control: foundations must be exposed a minimum 6" for siding and 4" for brick veneer with brick ledge
- Doors between the garage and residence shall be equipped with solid wood doors not less than 1-3/8 inches (35 mm) in thickness, solid or honeycomb core steel doors not less than 1-3/8 inches (35 mm) thick, or 20-minute fire-rated doors, equipped with a self-closing or automatic-closing device per R302.5
- ELECTRICAL - SHALL COMPLY WITH THE CITY'S CURRENT ADOPTION OF THE 2023 NEC INCLUDING BUT NOT LIMITED TO:
  - Receptacles serving kitchen islands and peninsulas can not be mounted below the countertop work surface. Receptacles serving island and peninsulas countertops is optional, however if installed must be installed accordance to the rules in Section 210.52(C)(3)
  - Emergency disconnects required per 2023 NEC Article 230.85
  - Surge protection devices (SPD) required for all services supplying dwellings units per 2023 NEC Article 230.67. Minimum Type 1 or Type2
  - Requires GFCI protection to include all kitchen 120 volt & 240 volt receptacles and service receptacles in the attic NEC 210.8(E)
  - Requires GFCI protection including all appliances such as ranges, wall ovens, counter mounted cooktops and microwave ovens whether hardwired or cord and plug connected NEC 210.8(D)
  - Requires GFCI protection to all receptacles in the laundry rooms including 240 volt dryer receptacles NEC 210.8

Planning Development Department



## Residential New Building Permit Plan Review Comments

- Requires GFCI protection for all exterior outlets for 125 volt through 250 volt excluding AC condensers and hardwired lighting NEC 210.8(F)
- All receptacles installed in bathrooms, garages, outdoors, crawl spaces, basements, kitchen countertops, within 6' of a sink, within 6' of a bathtub or shower stall, laundry areas and indoor damp and wet locations. Exterior receptacles to be GFCI & weather protected 2023 NEC, Article 210.8 (A)
- Carbon monoxide detector locations required per SEC R315.3
- Smoke detector locations required per SEC.R314.3. Smoke detectors required hard-wired w/battery backup per SEC.R314.6
- Hydro massage bathtub, spa and hot tub locations must be GFCI protected 2023 NEC, Article 680.43(A)
- Service outlets required within 25 feet of mechanical equipment in the attic per 2023 NEC, Article 210.63
- Electrical panels labeled and marked for use per 2023 NEC, Article 408.58
- Branch circuits to AC condensing units shall be minimum of 10 AWG copper conductors. 2023 NEC, Article 440.6 see FWEC Ordinance No. 18358-11-2008
- Receptacles shall be properly spaced per 2023 NEC Article 201.50
- Tamper resistance rec. req. per 2023 NEC 406.12
- At least one receptacle outlet shall be installed in each vehicle bay and not more than 5.5' above floor per 2023 NEC 210.52 (G)(1)
- MECHANICAL: SHALL COMPLY WITH THE CITY'S CURRENT ADOPTION OF THE 2021 IMC INCLUDING BUT NOT LIMITED TO
  - Attics containing appliances require one of three access entrances 1) permanent stair, 2)300 lb pull down stair, 3) access door from an upper floor level. SEC M1305.1.3 amendments. - Mechanical equipment in garage area must be 18" above finished floor. SEC.2408.2
  - A level service space not less than 30" deep by 30" wide shall be placed on the service side of the mechanical units placed in attics. SEC.M1305.1
  - A 125-volt receptacle shall be located within 25' of mechanical equipment in the attic for service and maintenance. SEC.E3901.12
- PLUMBING: SHALL COMPLY WITH THE CITY'S CURRENT ADOPTION OF THE 2021 IPC INCLUDING BUT NOT LIMITED TO
  - Water heaters in garage required 18" above finish floor. SEC.G2408.2 (305.2)
  - Water heater not allowed in attic-single family, duplex or multi-family. SEC. M1305.1.3 (EXCEPTION: Tankless water heaters)
  - Vacuum breaker required on all hose bibs. SEC.P2903.8.5
  - When water pressure exceeds 80 psi, pressure reducing valve is required.

Planning Development Department

SEC.P2903.3.1

-Full-open shut-off valves to be installed at the home and a second water shut-off valve near the water meter per 2021 IPC 606.1

ENERGY: SHALL COMPLY WITH THE CITY'S CURRENT ADOPTION OF THE 2015 IECC INCLUDING BUT

NOT LIMITED TO:

-Energy shall comply with the compliance path as the proposed energy report submitted for the building permit

-A fresh air intake system shall be installed on homes equipped with gas furnaces and the fresh air intake system shall be filtered before air is entered the home through the supply duct plenum

-High efficiency furnaces (min 90%) shall be installed in sealed foamed attics and with the combustible air taken from the exterior of the home