



## Residential New Building Permit Plan Review Comments

**Application:** PB25-11848

**Date Submitted:** 08/21/2025

**Status:** Issued

**Date Issued:** 09/02/2025

**Address:** 7852 SWITCHWOOD LN

**Parcel:** 1556400

**Zoning:** PD

**Subdivision:** TAVOLO PARK PHASE 5

**Lot/Block:** 14/32

**Description of Work:** New Single Family Residence w/3rd Party Review and Inspections

**ADA TDLR:**

**Energy Code Compliant:**

**Applicant:** Adriana Perez

**Owner:** CND-TAVOLO LLC

100 E 15th St 100

1111 N POST OAK RD

Fort Worth, TX 76102

HOUSTON,, TX 77055

9722446925

**Building Classification:**

Occ Class	Const Type	Square Feet	Occ Load	Use Description
R-3	VB	2142		Living Space
U	VB	711		Utilities

**Sprinkler Sys Req:**

**Comment:** Signs, Retaining Walls over 4', Fences, Dumpster Enclosures over 6', and Parkway Approaches and Sidewalks require separate permits and reviews.

**Required Corrections:**

Planning Development Department



## Residential New Building Permit Plan Review Comments

### **Building**

**Reviewer: Adriana Perez**

**Email: Adriana.A.Perez@BureauVeritas.com**

**Phone: 682-227-7436**

**1. Bureau Veritas Zoning Notes:**

Address: 7852 Switchwood Ln

Lot coverage: 43.09% (not over 60%)

Height: 29'-9"

Lot width at build line over 50': 51'-11 ¼"

Verified driveway does not exceed more than 50% of front  
yard: 34.74%

(Measured from front wall of house to front property line)

Provided front yard setback: 20'

Provided side yard setback L: 7'-1" R: 5'-1"

Provided rear yard setback: 23'-8 ½"

Number of bedrooms: 3

Parking spaces (9' x18') provided: 3 in Garage, 2 Driveway

(Requirements: 3 bdrms=2; 4 bdrms=3; 5 bdrms= 4; 6 bdrms=5)

Houses on either side: Left: 20'-1" Right: vacant

Masonry Requirements:

(Masonry is considered brick, stone, cementitious fiber concrete products or stucco)

Over 50% on all sides? yes

Trees shown on plot plan: 2

### **Approval Table:**

Task Name	Task Status	Completed Date	Task Rev Name
Application Submittal	Routed for Electronic Review	08/21/2025	Latrica Jelks
Water Development Review	Approved	08/29/2025	Elizabeth Armendariz
Transportation Impact Review	Approved	08/27/2025	Lamonica Smith
Urban Forestry Review	Approved	08/29/2025	Minden Ritz
Zoning Review	Approved	08/29/2025	Minden Ritz
PARD Review	Not Required	08/22/2025	Germaine Joseph
Building Plan Review	Approved	08/29/2025	3PTY BUREAU VERITAS
Issue Permit	Issued	09/02/2025	Patricia Martinez
Inspections			
Mechanical Plan Review	Approved	08/21/2025	Latrica Jelks
Plumbing Plan Review	Approved	08/21/2025	Latrica Jelks

Planning Development Department



## Residential New Building Permit Plan Review Comments

Electrical Plan Review	Approved	08/21/2025	Latrica Jelks
Plans Coordination	Approved	09/02/2025	Minden Ritz
TPW CFRA Review	Not Required	08/29/2025	Robin Stevens

### General Comments and Additional Permit Information:

**Reviewer:** Minden Ritz  
**Email:** [Minden.Ritz@fortworthtexas.gov](mailto:Minden.Ritz@fortworthtexas.gov)  
**Phone:**

#### 1 Zoning Plans Exam

Residential Zoning Review Notes PB25-11848 | 7852 Switchwood Ln.  
Planning and Development Department Plan # T003-C  
Zoning Review Notes: All reviews are pending stakeout inspection  
CFW Zoning Ordinance # 13896-19602

Permit data confirmed on: 8/6/2025  
By: Minden Ritz [817-392-2322]

Scope of project: Single-Family Residence

HOLD NOTES: All items labeled "HOLD" must be addressed

SUMMARY: Permit meets minimum standards Y  
Holds: \_\_\_\_

Zoning district: "PD1273 to A-5" Type of layout: Single-Family Residence

Official Plat: Attached to plans Block 32 / Lot 14 number verified Y  
Tavolo Park Phase 5 – FP-23-156 - Filing date: 06/18/2024

Building Square footage: R-3: 2142 U: 711  
Slab SF: 3432  
Lot Area: 6639

Lot coverage: 60% maximum, including all structures (Provided 43.09%)

Height: 35' maximum (Provided 29'9")

Lot Width: 50' minimum at building line (Provided 51'11")

Front yard driveway coverage: 50% maximum (Provided 34.74%)

Setback restrictions: (The front yard setback in residential districts shall be the greatest of:  
The platted building line; The setback for the applicable zoning district; or the setback of  
the nearest building on either side that is the closest to the street, up to a maximum

Planning Development Department



## Residential New Building Permit Plan Review Comments

setback of 50 feet, provided that said setback is not the result of a variance granted by the Board of Adjustment)

Front: 20' minimum (Provided 20.00') Per Zoning You are allowed up to 5 foot porch encroachment

Houses on either side: Left: 21' / Right: Vacant

Sides: 5' minimum (Provided Left: 7'1" / Right: 5'1")

Rear: 5' minimum (Provided 23'8")

Note: As applicable, any fence located within an easement will require permission of the easement holder(s) to encroach.

### Parking spaces:

Ord. 21528 Single Family Home: Two spaces located behind the front building wall for dwelling units with three or fewer bedrooms, plus one space located behind the front building wall or in the driveway for each bedroom above three.

# Bedrooms: 3 Parking spaces required 2 provided 4

Required parking spaces must be hard surface and dust free (asphalt or concrete). All maneuvering space must be located off of the public right of way.

Urban Forestry: property is vested, infill or UFC: (UFC23-0132) 1 large - canopy tree and 1 small canopy tree to be planted per residential lot up to 10,000sf – 1 large canopy tree and 2 small canopy trees for lots between 10,001 and 15,000sf. - provided Y)

An infill house shall be required to have a minimum 3" caliper front yard tree of choice, and one minimum 3" caliper street parkway tree as approved by the City Forester.

### Single Family Design Standards:

The same elevation shall not be permitted within a six-lot pattern, on an adjacent lot or on a lot directly across the street.

Exterior walls shall consist of a minimum of 50% masonry. Exposures to a minor arterial or wider street shall require 100% masonry construction except where such building face is obscured by a minimum six (6) foot masonry wall. "Masonry" shall include brick, stone, cementitious fiber concrete products or stucco. Similar products made from such materials and/or durable recycled material shall be allowed as approved by the Building Official.

No attached garage facing a public or private street may project greater than eight (8) feet in front of the front wall of the house in all Single-Family Districts.

Planning Development Department

Additional Comments:

Sec. 22-176. Curb cuts and laid-down curb permit procedures.

The location of ingress and egress driveways shall be subject to approval of the city traffic engineer under curb cut or laid-down curb permit procedures. Driveways shall not exceed sixty-five (65) per cent of the property frontage. There shall be a minimum of twenty (20) feet of curb along the street between driveways where there is more than one driveway on property under unified ownership or control and used as one premise. The decision of the city traffic engineer may be appealed to the city council. (Code 1964, § 26-102.3; Ord. No. 8288, § 1, 3-10-81)

**SINGLE FAMILY HOME: DWELLING UNIT:** A building, or any portion thereof, containing a complete set of independent living facilities for occupancy and use by one family, including permanent provisions for living, sleeping, eating, sanitation, and cooking within a kitchen for the exclusive use of the occupants whose intent is to inhabit the dwelling unit.

**COOKING EQUIPMENT:** A stove, range or other such appliances, which requires a 220V or gas connection that is used, designed, or intended to be used for the cook and preparing of food.

A sidewalk is required for all frontages facing a street  
<http://fortworthtexas.gov/planninganddevelopment/permits/streets/>

**Reviewer: Lamonica Smith**

**Email: Lamonica.Smith@fortworthtexas.gov**

**Phone:**

2 \*\*\*\*Transportation Impact Fees\*\*\*\*

2025 rate with no adequate facilities discount.

Planning Development Department