



## Residential New Building Permit Plan Review Comments

**Application:** PB25-10002

**Date Submitted:** 07/14/2025

**Status:** Issued

**Date Issued:** 08/26/2025

**Address:** 1732 GILLEN'S AVE

**Parcel:** 1619651

**Zoning:** A-5

**Subdivision:** SOUTH OAK GROVE

**Lot/Block:** 27/3

**Description of Work:** Construction of new single-family residence  
3rd Party Plan Review & Inspections  
North Texas Inspection Services

**ADA TDLR:**

**Energy Code Compliant:**

**Applicant:** Stacie Hamby

**Owner:** FORESTAR (USA) REAL ESTATE GRO

8220 Clifford St

2221 E LAMAR BLVD STE 790

White Settlement, TX 76108

ARLINGTON,, TX 76006

8172467780

**Building Classification:**

Occ Class	Const Type	Square Feet	Occ Load	Use Description
R-3	VB	2173		Living Area
U	VB	537		Garage/Porch/Patio

**Sprinkler Sys Req:**

**Comment:** Signs, Retaining Walls over 4', Fences, Dumpster Enclosures over 6', and Parkway Approaches and Sidewalks require separate permits and reviews.

**Required Corrections:**

**Building**

**Reviewer:** Stacie Hamby

**Email:** stacie@ntispros.com

**Phone:** (817) 246-7780

1.

Planning Development Department



## Residential New Building Permit Plan Review Comments

### Water

**Reviewer:** Shundalyn Evans

**Email:**

**Phone:**

1. 07/23/25 --CORRECTIONS REQUIRED-- Fees Due.

Water/sewer impact + reducer fees due ONCE SERVICE REPORT HAS BEEN APPROVED.  
Contact Water Applications at 817-392-8250 or WaterApps@fortworthtexas.gov to provide  
proposed water meter and sewer information.

**\*\*\*NOTE\*\*\***

It is the responsibility of the builder to uncover the water and sewer services. Water service must  
be exposed before meter can be set.

### Approval Table:

Task Name	Task Status	Completed Date	Task Rev Name
Application Submittal	Routed for Electronic Review	07/15/2025	Jasmine Lujan
Water Development Review	Approved	08/25/2025	Elizabeth Armendariz
Transportation Impact Review	Approved	07/17/2025	Lamonica Smith
Urban Forestry Review	Approved	07/24/2025	Jesus Olmos
Zoning Review	Approved	07/24/2025	Jesus Olmos
PARD Review	Not Required	07/16/2025	Germaine Joseph
Building Plan Review	Approved	07/24/2025	3PTY NORTH TEXAS
Issue Permit	Issued	08/26/2025	Brittania Rosborough
Inspections			
Mechanical Plan Review	Approved	07/24/2025	3PTY NORTH TEXAS
Plumbing Plan Review	Approved	07/24/2025	3PTY NORTH TEXAS
Electrical Plan Review	Approved	07/24/2025	3PTY NORTH TEXAS
Plan Distribution	Routed for Electronic Review	08/25/2025	Elizabeth Armendariz
Plans Coordination	Approved	08/26/2025	Jesus Olmos
TPW CFRA Review	Not Required	07/24/2025	Robin Stevens

### General Comments and Additional Permit Information:

Planning Development Department



## Residential New Building Permit Plan Review Comments

**Reviewer: Jesus Olmos**

**Email: Jesus.Olmos@fortworthtexas.gov**

**Phone:**

### 1 Zoning Plans Exam

Residential Zoning Review Notes PB25-10002 – 1732 GILLEN'S AVE

Planning and Development Department Plan #: Midland A R

Zoning Review Notes: All reviews are pending stakeout inspection

CFW Zoning Ordinance # 13896-22519

Permit data confirmed on: 07/24/2025

By: Jesus Olmos Jr. [817-392-7858]

Scope of project: New Single Family Home

HOLD NOTES: All items labeled "HOLD" must be addressed

SUMMARY: Permit meets minimum standards Y

Holds: \_\_\_\_

Zoning district: "A-5" Type of layout: Single-Family Residence

Official Plat: Attached to plans lot/block number verified Y (SOUTH OAK GROVE  
BLOCK 3 LOT 27) FP-24-071 approved/filed 5/5/2025

Building Square footage: R-3: 2173 U: 537

Slab SF: 2089

Lot Area: 5350

Lot coverage: 50% maximum, including all structures (Provided \_39%)

Height: 35' maximum (Provided \_24.375' \_)

Lot Width: 50' minimum at building line (Provided approx. \_50' \_)

Front yard driveway coverage: 50% maximum (Provided \_36%)

Setback restrictions: (The front yard setback in residential districts shall be the greatest of:  
The platted building line; The setback for the applicable zoning district; or the setback of  
the nearest building on either side that is the closest to the street, up to a maximum  
setback of 50 feet, provided that said setback is not the result of a variance granted by the  
Board of Adjustment)

Front: front yard setback 20' minimum (Provided \_20' 1½")

Houses on either side: \_20' / \_ 20' \_ per 3rd party site plan (verify on aerial photo)

Sides: 5' minimum (Provided \_5' 0½" & 5' 0")

Planning Development Department



## Residential New Building Permit Plan Review Comments

Rear: 5' minimum (Provided \_31' 6")

Note: As applicable, any fence located within an easement will require permission of the easement holder(s) to encroach.

### Parking spaces:

Ord. 21528 Single Family Home: Two spaces located behind the front building wall for dwelling units with three or fewer bedrooms, plus one space located behind the front building wall or in the driveway for each bedroom above three. # Bedrooms: \_4\_ Parking spaces required \_3\_ provided \_4\_

Required parking spaces must be hard surface and dust free (asphalt or concrete). All maneuvering space must be located off of the public right of way.

Urban Forestry: property is vested, infill or UFC: UFC22-0262 – 2 Medium – canopy trees per residential lot up to 10,000 sq. ft. in the Urban Forestry map mark as (A); – 1 – Medium and 1 – Large canopy trees per residential lot up to 10,000 sq. ft. Urban Forestry map mark as (B); 1 – Small and 2 – Medium canopy trees per residential lot greater than 10,000 sq. ft. in the Urban Forestry map mark as (C) – provided Y)

### Single Family Design Standards:

The same elevation shall not be permitted within a six-lot pattern, on an adjacent lot or on a lot directly across the street.

No attached garage facing a public or private street may project greater than eight (8) feet in front of the front wall of the house in all Single-Family Districts.

### Additional Comments:

Sec. 22-176. Curb cuts and laid-down curb permit procedures.

The location of ingress and egress driveways shall be subject to approval of the city traffic engineer under curb cut or laid-down curb permit procedures. Driveways shall not exceed sixty-five (65) per cent of the property frontage. There shall be a minimum of twenty (20) feet of curb along the street between driveways where there is more than one driveway on property under unified ownership or control and used as one premise. The decision of the city traffic engineer may be appealed to the city council. (Code 1964, § 26-102.3; Ord. No. 8288, § 1, 3-10-81)

**SINGLE FAMILY HOME: DWELLING UNIT:** A building, or any portion thereof, containing a complete set of independent living facilities for occupancy and use by one family, including permanent provisions for living, sleeping, eating, sanitation, and cooking within a kitchen for the exclusive use of the occupants whose intent is to inhabit the dwelling unit.

**COOKING EQUIPMENT:** A stove, range or other such appliances, which requires a 220V or gas connection that is used, designed, or intended to be used for the cook and preparing of food.

Planning Development Department

A sidewalk is required for all frontages facing a street  
<http://fortworthtexas.gov/planninganddevelopment/permits/streets/> .

**Reviewer: Lamonica Smith**  
**Email: [Lamonica.Smith@fortworthtexas.gov](mailto:Lamonica.Smith@fortworthtexas.gov)**  
**Phone:**

2 \*\*\*\*Transportation Impact Fees\*\*\*\*

2025 rate with no adequate facilities discount. Fees covered by CA-24-003.

Planning Development Department

---

The City of Fort Worth \* 100 Fort Worth Trail \* Fort Worth, TX, 76102  
817-392-2222 \* Fax 817-392-8105