



Residential New Building Permit Plan Review Comments

Application: PB25-15265

Date Submitted: 10/31/2025

Status: Awaiting Client
Reply

Date Issued:

Address: 6721 SERENITY DR

Parcel: 1633563

Zoning: A-5

Subdivision: Meadow Lakes

Lot/Block: 19/7

Description of Work: Construction of new single-family residence

3rd Party Plan Review & Inspections

North Texas Inspection Services

ADA TDLR:

Energy Code Compliant:

Applicant: Stacie Hamby
8220 Clifford St
White Settlement, TX 76108
8172467780

Owner: ELITE DEVELOPMENT AND CONSTRUCTION LLC
1521 WAGONWHEEL TR
KELLER,, TX 76248

Building Classification:

Occ Class	Const Type	Square Feet	Occ Load	Use Description
R-3	VB	1957		Living Area
U	VB	575		Garage/Porch

Sprinkler Sys Req:

Comment: Signs, Retaining Walls over 4', Fences, Dumpster Enclosures over 6', and Parkway Approaches and Sidewalks require separate permits and reviews.

Required Corrections:

Building

Reviewer: Stacie Hamby
Email: stacie@ntispros.com
Phone: (817) 246-7780

1.

Planning Development Department

The City of Fort Worth * 100 Fort Worth Trail * Fort Worth, TX, 76102
817-392-2222 * Fax 817-392-8105



Residential New Building Permit Plan Review Comments

Water

Reviewer: Ibeth Heatley

Email: Ibeth.Heatley@fortworthtx.gov

Phone:

1. 12/03/25 -- INCOMPLETE
- 11/26/25 -- INCOMPLETE
- 11/12/25 -- CORRECTIONS REQUIRED -- Fees Due.

Water/sewer impact + reducer fees due. Contact Water Applications at 817-392-8250 or WaterApps@fortworthtx.gov to provide proposed water meter and sewer information in addition to customer billing information.

NOTE

It is the responsibility of the builder to uncover the water and sewer services. Water service must be exposed before meter can be set.

Zoning

Reviewer: David Parker

Email: David.Parker@fortworthtx.gov

Phone: 817-392-2657

1. 11/3/2025 -- CORRECTIONS REQUIRED -- Noise Contour check list. Ordinance 17680-08-2007 and 17681-08-2007 were added for sound construction.

Please attach Airport Sound Construction Checksheet for the 65db Contour.

Approval Table:

Task Name	Task Status	Completed Date	Task Rev Name
Application Submittal	Routed for Electronic Review	11/03/2025	Jasmine Lujan
Water Development Review	Corrections Required	12/03/2025	Ibeth Heatley
Transportation Impact Review	Approved	11/05/2025	Lamonica Smith
Urban Forestry Review	Approved	11/03/2025	David Parker
Zoning Review	Approved	11/19/2025	David Parker
PARD Review	Not Required	11/03/2025	Germaine Joseph
Building Plan Review	Approved	11/19/2025	3PTY NORTH TEXAS
Noise Contour Review	Approved	11/19/2025	David Parker
Mechanical Plan Review	Approved	11/03/2025	Jasmine Lujan
Plumbing Plan Review	Approved	11/03/2025	Jasmine Lujan

Planning Development Department

The City of Fort Worth * 100 Fort Worth Trail * Fort Worth, TX, 76102
817-392-2222 * Fax 817-392-8105



Residential New Building Permit Plan Review Comments

Electrical Plan Review	Approved	11/03/2025	Jasmine Lujan
Plan Distribution	Routed for Electronic Review	11/26/2025	David Parker
Plans Coordination	Corrections Required	12/04/2025	David Parker
TPW CFRA Review	Not Required	11/12/2025	Robin Stevens

General Comments and Additional Permit Information:

Reviewer: David Parker

Email: David.Parker@fortworthtexas.gov

Phone: 817-392-2657

3 Zoning Plans Exam

Residential Zoning Review Notes PB25-15265 – 6721 Serenity
Planning and Development Department Plan #: Hadley MF L H
Zoning Review Notes: All reviews are pending stakeout inspection
CFW Zoning Ordinance # 13896-22519

Permit data confirmed on: 11/03/2025

By: David Parker [817-392-2657]

Scope of project: New Single Family Home

HOLD NOTES: All items labeled "HOLD" must be addressed

SUMMARY: Permit meets minimum standards Y

Holds: _____

Zoning district: "A-5 to A-5" Type of layout: Single-Family Residence

Official Plat: Attached to plans Lot/block number verified Y (Meadow Lakes Block 7 Lot 19) FP-24-205 approved/filed 4/9/2025

Building Square footage: R-3: 1957 U: 575

Slab SF: 2532

Lot Area: 5129

Lot coverage: 45% maximum, including all structures (Provided _49.00%)

Height: 36' maximum (Provided _19.92')

Lot Width: 50' minimum at building line (Provided approx. _50.00')

Front yard driveway coverage: 50% maximum (Provided _36.00%)

Setback restrictions: (The front yard setback in residential districts shall be the greatest of:

Planning Development Department



Residential New Building Permit Plan Review Comments

The platted building line; The setback for the applicable zoning district; or the setback of the nearest building on either side that is the closest to the street, up to a maximum setback of 50 feet, provided that said setback is not the result of a variance granted by the Board of Adjustment)

Front: front yard setback 20' minimum (Provided _20.00')

Houses on either side: _DNO_ _20.00'_ per 3rd party site plan (verify on aerial photo)

Sides: 5' minimum (Provided _5.00' & 5.00')

Rear: 5' minimum (Provided _19.87')

Note: As applicable, any fence located within an easement will require permission of the easement holder(s) to encroach.

Parking spaces:

Ord. 21528 Single Family Home: Two spaces located behind the front building wall for dwelling units with three or fewer bedrooms, plus one space located behind the front building wall or in the driveway for each bedroom above three. # Bedrooms: _3_ Parking spaces required _2_ provided _4_

Required parking spaces must be hard surface and dust free (asphalt or concrete). All maneuvering space must be located off of the public right of way.

Urban Forestry: UFC23-0235 Approved Y

Single Family Design Standards:

The same elevation shall not be permitted within a six-lot pattern, on an adjacent lot or on a lot directly across the street.

No attached garage facing a public or private street may project greater than eight (8) feet in front of the front wall of the house in all Single-Family Districts.

Additional Comments:

Sec. 22-176. Curb cuts and laid-down curb permit procedures.

The location of ingress and egress driveways shall be subject to approval of the city traffic engineer under curb cut or laid-down curb permit procedures. Driveways shall not exceed sixty-five (65) per cent of the property frontage. There shall be a minimum of twenty (20) feet of curb along the street between driveways where there is more than one driveway on property under unified ownership or control and used as one premise. The decision of the city traffic engineer may be appealed to the city council. (Code 1964, § 26-102.3; Ord. No. 8288, § 1, 3-10-81)

SINGLE FAMILY HOME: DWELLING UNIT: A building, or any portion thereof, containing a complete set of independent living facilities for occupancy and use by one family, including permanent provisions for living, sleeping, eating, sanitation, and cooking within a kitchen for the exclusive use of the occupants whose intent is to habitat the dwelling unit.

Planning Development Department

The City of Fort Worth * 100 Fort Worth Trail * Fort Worth, TX, 76102
817-392-2222 * Fax 817-392-8105

COOKING EQUIPMENT: A stove, range or other such appliances, which requires a 220V or gas connection that is used, designed, or intended to be used for the cook and preparing of food.

A sidewalk is required for all frontages facing a street
<http://fortworthtexas.gov/planninganddevelopment/permits/streets/>.

Reviewer: Ibeth Heatley
Email: Ibeth.Heatley@fortworthtexas.gov
Phone:

1 WATER APPLICATIONS

***** IMPORTANT*** PLEASE READ WATER AND SEWER SERVICE LOCATION REQUIREMENTS *****

Sec 5.18.2.1 Meter boxes can only be installed in non-paved areas. Water service and meter box must be installed 1-foot offset from the property line in the parkway and have a 9-foot horizontal separation from the sewer service. The normal location for meter boxes is 2.5 feet behind the back of curb.

In no case shall the water meter box (and meter) be outside of the public right-of-way or water easement.

Sec 6.4.1.3 Wastewater service should avoid placement in driveways and have a 9-foot horizontal separation from the water service.

Service should be installed South or West of the proposed driveway location.

To prevent delays for a meter set, ensure the following criteria is met:

- Address must be clearly posted, i.e., visible and big enough to see
 - No debris or material over the meter box
 - Meter box must be in the ground to grade per city specification
-

Reviewer: Lamonica Smith
Email: Lamonica.Smith@fortworthtexas.gov
Phone:

2 ****Transportation Impact Fees****

2025 rate with no adequate facilities discount.