



Residential New Building Permit Plan Review Comments

Application: PB25-16508

Date Submitted: 12/01/2025

Status: Plan Review

Date Issued:

Address: 7636 TRAILRIDGE DR

Parcel: 402877

Zoning: A-5

Subdivision: HILLS OF LAKE COUNTRY

Lot/Block: 84/4

Description of Work: Single Family/Ground up Construction Original permit PB24- has expired need to reinstate to complete build.

Resubmittal of expired permit PB24-11602, which was a resubmittal of expired permit PB22-00996.

ADA TDLR:

Energy Code Compliant:

Applicant: Teresa Johnson

Owner: ZOOD LP

830 Taylot Street

PO BOX 1510

Fort Worth, TX 76102

FORT WORTH,, TX 76101

8177344174

Building Classification:

Occ Class	Const Type	Square Feet	Occ Load	Use Description
R-3	VB	2447		Living space
U	VB	1012		Garage/Porch/Patio/Storage

Sprinkler Sys Req: No

Comment: Signs, Retaining Walls over 4', Fences, Dumpster Enclosures over 6', and Parkway Approaches and Sidewalks require separate permits and reviews.

Required Corrections:

Approval Table:

Task Name	Task Status	Completed Date	Task Rev Name
Application Submittal	Routed for Electronic Review	12/02/2025	Latrica Jelks
Water Development Review	Corrections Required	12/10/2025	Michelle Canright
Transportation Impact Review	Approved	12/09/2025	Lamonica Smith
Urban Forestry Review	Approved	12/04/2025	Rosalee Rivera
Zoning Review	Approved	12/04/2025	Rosalee Rivera
PARD Review	Not Required	12/03/2025	Germaine Joseph

Planning Development Department



Residential New Building Permit Plan Review Comments

Building Plan Review	Approved	12/03/2025	Jesus Olmos
Mechanical Plan Review	Approved	12/03/2025	Jesus Olmos
Plumbing Plan Review	Approved	12/03/2025	Jesus Olmos
Electrical Plan Review	Approved	12/03/2025	Jesus Olmos
Plan Distribution	Routed for Electronic Review	12/11/2025	Jesus Olmos
Plans Coordination	Corrections Required	12/10/2025	Jesus Olmos

General Comments and Additional Permit Information:

Reviewer: Jesus Olmos

Email: Jesus.Olmos@fortworthtexas.gov

Phone:

3 ***** Residential Code Review Comments *****

City Plans Examiner: Jesus Olmos Jr.

Phone # (817) 392- 7858

Jesus.olmos@fortworthtexas.gov

Date 12/3/2025

Development Services

Residential Review Notes

IRC 2021 / CFW ORD. # 25383

Permit #: PB25-16508

Address: 7636 Trailridge Dr

Construction type: VB

Project Area:3497

Occupancy & Use: R-3 -2447; U -1012

Scope of Work: New Single Family Residential – resubmittal of PB24-11602, resubmittal of PB22-00996

Professional engineer certified foundation plans: Bill Graham PE #67899

Professional engineer who certified structural plans: Bill Graham PE #67899

Braced wall plans: Bill Graham PE #67899

WINDOWS

Max U-factor is 0.35

Max SHGC is 0.25

DOORS – U-factor

Uninsulated metal: 1.2

Insulated metal: 0.6

Planning Development Department



Residential New Building Permit Plan Review Comments

Wood: 0.5

Insulated, nonmetal edge, Max 45% glazing, any glazing double pane 0.35

INSULATION

R-13+5h or 20 insulation in exterior walls

R-38 insulation in the attic

R-19 insulation in the floor

** General Notes **

NOTE: The general notes listed below are an abbreviated version of the actual notes in the 2021 IRC and CFW Amendment. The builder is responsible for compliance with the full applicable IRC section and/or CFW Amendment.

This Plan is void without City Plan Review Notes.

1. See attached examiner's notes and City handouts as applicable to this permit.
2. See attached site and construction plans as applicable to permit.
3. All work shall conform to City of Fort Worth building code, energy code and zoning requirements.
4. SEPARATE PERMITS ARE REQUIRED for Electrical, Mechanical and Plumbing work.
5. R302.6 Dwelling/garage fire separation.

SEPARATION MATERIAL

From the residence and attics: Not less than 1/2-inch gypsum board or equivalent applied to the garage side

From all habitable rooms above the garage: Not less than 5/8-inch Type X gypsum board or equivalent

6. R302.11 Fireblocking.

In combustible construction, fireblocking shall be provided to cut off all concealed draft openings (both vertical and horizontal) and to form an effective fire barrier between stories, and between a top story and the roof space.

7. BATHROOMS – R303.3 Bathrooms, water closet compartments and other similar rooms shall be provided with aggregate glazing area in windows of not less than 3 square feet, one-half of which must be openable. Artificial light and mechanical ventilation may be provided.

8. EMERGENCY ESCAPE – R310 – basements, habitable attics and each sleeping room shall have at least one operable emergency and rescue opening.

R310.2.1 – All emergency escape and rescue openings shall have a minimum net clear opening of 5.7 sq.ft. Openings on grade shall be a minimum of 5 sq.ft. net clear opening.

Planning Development Department



Residential New Building Permit Plan Review Comments

R310.2.1 – Minimum opening height is 24"

R310.2.1 – Minimum opening width is 20"

R310.1.1 – Emergency escape and rescue openings shall be operational from the inside of the room without the use of keys, tools or special knowledge.

9. MEANS OF EGRESS – R311

R311.6 – Minimum hallway width shall not be less than 36"

R311.2 – Each dwelling unit shall have not less than one exit door

10. SECTION R315 CARBON MONOXIDE ALARMS

R315.2.1 Carbon monoxide alarms and R315.3 Location. For new construction, an approved carbon monoxide alarm shall be installed outside of each separate sleeping area in the immediate vicinity of the bedrooms in dwelling units within which fuel-fired appliances are installed and in dwelling units that have attached garages.

11. WATER HEATERS: M2005.2 – Fuel fired water heaters shall not be installed in a room used as a storage closet.

12. CLOTHES DRYER EXHAUST: 2021 IRC M1502 – Dryer exhaust systems shall be independent of all other systems, and shall terminate on the outside of the building. Exhaust ducts shall be equipped with a backdraft damper.

13. M1502.4.5.1 SPECIFIED LENGTH – The maximum length of a clothes dryer exhaust duct shall not exceed 35 feet from the connection to the transition duct from the dryer to the outlet terminal.- The maximum length of the duct shall be reduced 2.5 feet for every 45 degree bend and 5 feet for each 90 degree bend.

1 & 2 FAMILY ELECTRICAL

14. RECEPTACLE OUTLETS – Receptacles shall be installed so that no point measured horizontally along the floor line in any wall space is more than 6 feet from a receptacle outlet (E3901.2.1).

15. COUNTERTOP RECEPTACLES - E3901.4.1 Wall countertop space. A receptacle outlet shall be installed at each wall countertop space 12 inches (305 mm) or wider. Receptacle outlets shall be installed so that no point along the wall line is more than 24 inches (610 mm), measured horizontally from a receptacle outlet in that space.

16. E3901.4.2 Island countertop spaces. At least one receptacle outlet shall be installed at each island countertop space.

17. E3901.4.3 Peninsular countertop space. At least one receptacle outlet shall be installed at each peninsular countertop.

18. E3901.4.4 Separate spaces. Countertop spaces separated by range tops,

Planning Development Department



Residential New Building Permit Plan Review Comments

refrigerators, or sinks shall be considered as separate countertop spaces

19. GFI CIRCUITS –2020 NEC 210.8 Ground Fault Interrupter Circuits shall be installed in dwelling units in the following locations:

210.8 (A)(1) - Bathrooms

210.8 (A)(2) - Garages and accessory buildings that have a floor at or below grade level

210.8 (A)(3) - Outdoor receptacles

210.8 (A)(6) - Kitchens where receptacles are installed to serve the countertop surfaces

210.8 (A)(7) - Laundry, utility and wet bar sink – where the receptacles are installed within 6 ft. of the outside edge of the sink

20. 210.52 (G) At least one receptacle outlet, in addition to those for specific equipment, shall be installed in each basement, in each attached garage, and in each detached garage with electric power.

21. Arc-Fault Circuit Interrupter Protection 2020 NEC 210.12(A)

All 120 volt, single phase, 15 and 20 ampere branch circuits supplying outlets installed in dwelling unit family rooms, dining rooms, living rooms, parlors, libraries, dens, bedrooms, sunrooms, recreation rooms, closets, hallways or similar rooms or areas shall be protected by a listed arc-fault circuit interrupter, combination type, installed to provide protection of the branch circuit.

22. Heating, Air-Conditioning and Refrigeration Equipment Outlet – 2020 NEC 210.63

A 125-volt, single-phase, 15 or 20 ampere rated receptacle outlet shall be installed at an accessible location for the servicing of heating, air-conditioning and refrigeration equipment. The receptacle shall be located on the same level and within 25 feet of the heating, air-conditioning and refrigeration equipment.+

23. Luminaries in Clothes Closet: Luminary Types and location must comply with 2020 NEC 410.16

24. Electricity will not be released until Transportation & Public Works (TPW) has approved sidewalk and drive approach inspections

Reviewer: Lamonica Smith

Email: Lamonica.Smith@fortworthtexas.gov

Phone:

1 ****Transportation Impact Fees****

2025 rate with no adequate facilities discount.

Reviewer: Rosalee Rivera

Email: Rosalee.Rivera@fortworthtexas.gov

Phone: 817-392-2222

2 Zoning Plan Review Performed On: 12/04/2025

By: Rosalee Rivera — rosalee.rivera@fortworthtexas.gov

Planning Development Department



Residential New Building Permit Plan Review Comments

Zoning Review Notes: All reviews are pending stakeout inspection

Permit #: PB25-16508

Expired - PB24-11602 // Original submittal PB22-00996

Physical Address: 7636 Trailridge Dr

Legal Description: HILLS OF LAKE COUNTRY – Block 4 – Lot 84

Plat: HILLS OF LAKE COUNTRY // FP-005-119

Zoning district: A-5

Scope of project: Single Family Residence // Resubmittal of expired permit PB24-11602, which was a resubmittal of expired permit PB22-00996.

HOLD NOTES: All items labeled “HOLD” must be addressed. Additional HOLDS may be placed upon review of revisions.

***Please do not upload revised combined plans until the permit is in (Awaiting Client Reply)

Overlays: N/A

Minimum Lot Size 5000 sq ft: Provided: 12,382

Building Square Footage: 3459 sf.

Maximum Height 35': Provided: 24.9'

Lot Width: 50' minimum / Provided: 58.84 sf.

Lot Coverage: 50% maximum; Provided: 28%

Front yard driveway coverage: 50% maximum; Provided: 20%

4.705(e)(7) ONE-FAMILY (“A-5”) DISTRICT.
(Table)

(7) No parking for one- and two-family uses shall be permitted within the front yard, as measured between the front property line and the closest location on the structure, other than as provided on the driveway. Driveway coverage, including ribbon drives, shall not exceed 50% of the front yard, and any additional parking on the property shall be provided on the driveway. Circular drives shall not exceed 65% maximum coverage. Parking pads are permitted if they are attached to the primary driveway and constructed of the same material and shall be included in the calculation of driveway coverage.

Planning Development Department



Residential New Building Permit Plan Review Comments

Monotony: Custom home unique to the block

Trees: Provided tree location in front yard

Setback restrictions: (The front yard setback in residential districts shall be the greatest of: The platted building line; The setback for the applicable zoning district; or the setback of the nearest building on either side that is the closest to the street, up to a maximum setback of 50 feet, provided that said setback is not the result of a variance granted by the Board of Adjustment)

Front: 20' minimum – Provided: 20' per plat build line

Interior Side Yard: 5' minimum – Provided: 7.3'L, 8.11'R

Rear: 5' minimum – Provided: More than the minimum

Established Setbacks Provided: Block face built out to 20'

No. of bedrooms: 3

Parking spaces required: 2

Parking spaces provided: 2

*Side entry garage

Additional Comments:

6.507.2 (c) ONE-FAMILY DWELLING UNIT DESIGN STANDARDS.

One-family dwellings must comply with the following standards.

Parking. Section 4.705.D.2 Single Family Home: (2) Parking. Two spaces located behind the front building wall for dwelling units with three or fewer bedrooms, plus one space located behind the front building wall or in the driveway for each bedroom above three. Required parking spaces must be hard surface and dust free (asphalt or concrete). All maneuvering space must be located off of the public right of way.

(a) Elevation. The intent of this subsection is to promote the health, safety, and general welfare of the City of Fort Worth and its citizens through the adoption and enforcement of

Planning Development Department

one-family dwelling unit design standards that limit the effects of repetition and uniformity by requiring substantive variation and diversity in front elevations within a certain lot pattern. The elevations for one-family dwelling units within a six (6) lot pattern must be sufficiently differentiated from each other and from any one-family dwelling unit that is two (2) lots removed on either side of the subject property on the same side of the street, as generally depicted below and otherwise set forth herein.

(c) Attached garages. No attached garage facing a public or private street may project greater than eight feet in front of the front wall of the house in all single-family districts.

(7) Garage/carport. No more than one garage and one carport or porte cochere shall be allowed per residential unit on a single residential lot, unless the additional garages or porte cocheres are an integral part of the main residential structure with the same roofline and driveway as the residential structure.

(8) Side and rear yard setbacks. The side and rear yard setback for detached garages located behind the rear wall of the house may be reduced to three feet. The side yard of an attached garage may be located within three feet of the property line when located a minimum of 18 feet back of the front wall of the house.

6.302(1) URBAN FORESTRY.

(1) One- and two-family residential land uses.

a. Minimum retained or planted canopy coverage shall be 40%.

(d) Infill house. An infill house shall be required to have one minimum three-inch caliper front yard tree of choice, and one minimum three-foot caliper street parkway tree as approved by the city forester. In all instances, a minimum of 40% canopy cover per lot must be achieved in accordance with § 6.302.

***** end ZONING PLANS EXAM COMMENTS *****

Planning Development Department

The City of Fort Worth * 100 Fort Worth Trail * Fort Worth, TX, 76102
817-392-2222 * Fax 817-392-8105