



Residential New Building Permit Plan Review Comments

Application: PB25-10063

Date Submitted: 07/15/2025

Status: Awaiting Client
Reply

Date Issued:

Address: 1021 WINNIE ST

Parcel: 127999

Zoning: A-5

Subdivision: GRANDE VISTA HEIGHTS ADDITION

Lot/Block: A/B

Description of Work: NEW SFR/ 3RD PTY PLAN REVIEW AND INSPECTION -ROSS INSPECTIONS

ADA TDLR:

Applicant: Diana Carter

10401 Prairie Heights Ct

Fort Worth, TX 76108

6823092189

Energy Code Compliant:

Owner: HANEY, MISTY EST

1021 WINNIE ST

FORT WORTH,, TX 76112

Building Classification:

Occ Class	Const Type	Square Feet	Occ Load	Use Description
R-3	VB	1529		
U	VB	176		

Sprinkler Sys Req:

Comment: Signs, Retaining Walls over 4', Fences, Dumpster Enclosures over 6', and Parkway Approaches and Sidewalks require separate permits and reviews.

Required Corrections:

Planning Development Department



Residential New Building Permit Plan Review Comments

PARD

Reviewer: Germaine Joseph

Email: Germaine.Joseph@fortworthtexas.gov

Phone:

1. PARD/PDP: This development is within the boundaries of Park Planning District 4; the Neighborhood & Community Park Dedication Policy applies.
There is a required \$1,393.58 due for each single-family residential unit or duplex on an undeveloped lot.
On a lot with a teardown, there is a required \$1,393.58 due for each additional residential unit (duplex). Please upload the demolition/razing permit. Tear down and replace in kind, no PARD-PDP fee is due.
Call Development Services @ 817-392-2222, if you need assistance on making a payment.
Call Lori Gordon @ 817-392-5743 for information regarding the fee and to what it is applied.
All fees must be paid in full for single family residential or duplex, at or before building permit issue. No city permits will be issued until the PDP fees have been paid.

Water

Reviewer: Elizabeth Armendariz

Email: WaterApps@FortWorthTexas.gov

Phone: 817-392-8250

1. 07.25.25 - CORRECTIONS REQUIRED - Need a picture of the inside of the water meter to verify if branch service still exist. If there is a branch service, there will be a fee of \$85.00 for removal.
2. 07.25.25 - CORRECTIONS REQUIRED - Need customer billing information:
 1. Customer Name (for the account)
 2. Customer's Mailing Address
 3. Customer's Tax ID Number
 4. Contact Name (if different from customer name)
 5. Customer's Phone number
 6. Customer's Email address

Please provided customer billing information.

WaterApps@FortWorthTexas.Gov and be sure to add the permit number and address in the subject title.

3. 07.25.25 - CORRECTIONS REQUIRED - Pending sewer investigation to ensure there is a sewer tap for this lot.

Zoning

Reviewer: Scott Edwardson

Email: Scott.Edwardson@fortworthtexas.gov

Phone: (817) 392-6288

1. 7/25/2025--Accessory--The two Accessories were never permitted. You will need to get two accessory permits for the two accessories before this permit can be approved

Planning Development Department



Residential New Building Permit Plan Review Comments

2. 7/25/2025--Size--§ 5.301 ACCESSORY USES ON RESIDENTIAL LOTS-- a. Allowable square footage.

1. Non-habitable accessory buildings shall not exceed the maximum square footage for each residential lot size as depicted in the following table:

10,000 to 21,779 square feet 400 square feet

2. The maximum square footage limits shown above shall be cumulative of all non-habitable accessory structures for each lot excluding private garages, private carports and private porte cocheres. Private garages, private carports and private porte cocheres shall not be included for the purpose of determining allowable square footage of non-habitable accessory structures on a residential lot.

The lot is 21076 sf and you are allowed 400sf total of all accessories, there are 1630sf of accessories.. You will need to go before the Board of Adjustment and seek a Variance.

Residential BOA: 817-392-2733 BoardOfAdjustment@fortworthtexas.gov

Approval Table:

Task Name	Task Status	Completed Date	Task Rev Name
Application Submittal	Routed for Electronic Review	07/16/2025	Latrica Jelks
Water Development Review	Corrections Required	07/25/2025	Elizabeth Armendariz
NEZ Certification Review	Opt-Out	07/16/2025	Latrica Jelks
Transportation Impact Review	Not Required	07/21/2025	Lamonica Smith
Urban Forestry Review	Approved	07/25/2025	Scott Edwardson
Zoning Review	Corrections Required	07/25/2025	Scott Edwardson
PARD Review	Approved	07/17/2025	Germaine Joseph
Building Plan Review	Approved	07/25/2025	3PTY ROSS INSPECTION SERVICES
Mechanical Plan Review	Approved	07/25/2025	3PTY ROSS INSPECTION SERVICES
Plumbing Plan Review	Approved	07/25/2025	3PTY ROSS INSPECTION SERVICES
Electrical Plan Review	Approved	07/25/2025	3PTY ROSS INSPECTION SERVICES
Plan Distribution			
Plans Coordination	Corrections Required	07/25/2025	Scott Edwardson
NEZ Design Guidelines Review	Not Required	07/25/2025	Scott Edwardson

General Comments and Additional Permit Information:

Planning Development Department



Residential New Building Permit Plan Review Comments

Reviewer: Scott Edwardson
Email: Scott.Edwardson@fortworthtexas.gov
Phone: (817) 392-6288

1 Zoning Plans Exam
Residential Zoning Review Notes PB25-10063 – 1021 Winnie St.
Planning and Development Department PLAN #: Custom
Zoning Review Notes: All reviews are pending stakeout inspection
CFW Zoning Ordinance # 13896-22519

Permit data confirmed on: 07/25/2025

By: Scott Edwardson [817-392-6288]

Scope of project: New SFR

HOLD NOTES: All items labeled "HOLD" must be addressed

Hold for BOA

Hold for Permits

SUMMARY: Permit meets minimum standards Y

Holds: ____

Razing Permit #: PV15-00266, 67, 68 AND 69

Zoning district: "A-5" Type of layout: Single Family Residence

Official Plat: Attached to plans lot/block number verified Y (Grande Vista Heights Blk B Lt AR)

FS-24-171

Building Square footage: R-3: 1529 U: 176

Slab SF: 1705

Lot Area: 18,955

Lot coverage: 50% maximum, including all structures (Provided _17.59)

Height: 35' maximum (Provided _19.58')

Lot Width: 50' minimum at building line (Provided 95.24')

Front yard driveway coverage: 50% maximum (Provided 18.89%)

Setback restrictions: (The front yard setback in residential districts shall be the greatest of: The platted building line; The setback for the applicable zoning district; or the setback of the nearest building on either side that is the closest to the street, up to a maximum setback of 50 feet, provided that said setback is not the result of a variance granted by the Board of Adjustment)

Front: 25' minimum (provided _50.00')

Houses on either side: __ L – _50.00' / _R – _69.00' per 3rd party site plan (verify on photo)

Planning Development Department



Residential New Building Permit Plan Review Comments

Sides: 5' minimum (Provided _10.00 & 47.25')

Rear: 5' minimum (Provided _87.25')

Note: As applicable, any fence located within an easement will require permission of the easement holder(s) to encroach.

Parking spaces:

Ord. 21528 Single Family Home: Two spaces located behind the front building wall for dwelling units with three or fewer bedrooms, plus one space located behind the front building wall or in the driveway for each bedroom above three.

Bedrooms: _3_ Parking spaces required _2_ provided _2+_.

Required parking spaces must be hard surface and dust free (asphalt or concrete). All maneuvering space must be located off of the public right of way.

Urban Forestry: property is vested, infill, or has approved UFC permit: (Infill).

An infill house shall be required to have a minimum 3" caliper front yard tree of choice, and one minimum 3" caliper street parkway tree as approved by the City Forester.

Single Family Design Standards:

The same elevation shall not be permitted within an eight-lot pattern, on an adjacent lot or on a lot directly across the street.

No attached garage facing a public or private street may project greater than eight (8) feet in front of the front wall of the house in all Single-Family Districts.

Additional Comments:

Sec. 22-176. Curb cuts and laid-down curb permit procedures.

The location of ingress and egress driveways shall be subject to approval of the city traffic engineer under curb cut or laid-down curb permit procedures. Driveways shall not exceed sixty-five (65) per cent of the property frontage. There shall be a minimum of twenty (20) feet of curb along the street between driveways where there is more than one driveway on property under unified ownership or control and used as one premise. The decision of the city traffic engineer may be appealed to the city council. (Code 1964, § 26-102.3; Ord. No. 8288, § 1, 3-10-81)

SINGLE FAMILY HOME: DWELLING UNIT: A building, or any portion thereof, containing a complete set of independent living facilities for occupancy and use by one family, including permanent provisions for living, sleeping, eating, sanitation, and cooking within a kitchen for the exclusive use of the occupants whose intent is to inhabit the dwelling unit.

COOKING EQUIPMENT: A stove, range or other such appliances, which requires a 220V or gas connection that is used, designed, or intended to be used for the cook and preparing of food.

A sidewalk is required for all frontages facing a street

Planning Development Department



Residential New Building Permit Plan Review Comments

<http://fortworthtexas.gov/planninganddevelopment/permits/streets/> .

Reviewer: Elizabeth Armendariz
Email: WaterApps@FortWorthTexas.gov
Phone: 817-392-8250

2 WATER APPLICATIONS

*** IMPORTANT*** PLEASE READ WATER AND SEWER SERVICE LOCATION REQUIREMENTS ***

Sec 5.18.2.1 Meter boxes can only be installed in non-paved areas. Water service and meter box must be installed 1-foot offset from the property line in the parkway and have a 9-foot horizontal separation from the sewer service. The normal location for meter boxes is 2.5 feet behind the back of curb.

In no case shall the water meter box (and meter) be outside of the public right-of-way or water easement.

Sec 6.4.1.3 Wastewater service should avoid placement in driveways and have a 9-foot horizontal separation from the water service.

Service should be installed South or West of the proposed driveway location.

To prevent delays for a meter set, ensure the following criteria is met:

- Address must be clearly posted, i.e., visible and big enough to see
- No debris or material over the meter box
- Meter box must be in the ground to grade per city specification

EXISTING SERVICE LOCATIONS

Water Tap – 27' North of South property line – See water service requirements listed above

Sewer tap – Pending sewer investigation – See water service requirements listed above

Reviewer: Diana Carter
Email: Diana.Carter@fortworthtexas.gov
Phone: (817) 713-8619

3 BUILDING - SHALL COMPLY WITH THE CITY'S CURRENT ADOPTION OF THE 2021 IRC INCLUDING BUT NOT LIMITED TO:

- Address shall be posted and visible at all times from street. SEC.R319
- Steel lintels or engineer's design required for low eyebrow arches, refer to City of Fort Worth lintel schedule. SEC606.9
- New construction and additions greater than 500 square feet must have engineered foundation plans

Planning Development Department



Residential New Building Permit Plan Review Comments

- 5/8" gypsum board required for storage under stairs. SEC. R302.7
- Bedroom fire egress window/ door 5.7 SQFT minimum openable space (grade floor openings 5 sq ft) SEC. R310
- A flight of stairs shall not have a vertical rise greater than 147 in. between floor levels or landings
SEC. R311.7.3
- All staircases need to meet the requirements set forth in SEC. R311
- Attic access required with minimum dimension of 22" by 30" SEC. R807.1
- Garage/Dwelling separation shall comply with Table R302.6
- Doors separating garage and dwelling must comply with R302.5.1. (equipped with a self-closing device)
- Driveway approach (es) shall meet City of Fort Worth standard drawings and separate permit from T&PW construction division required. Regardless of whether the approach and/or sidewalks will be new or not T&PW will still need to be contacted for a site inspection
- Window sills located greater than 72" above the outside grade must be a minimum 24" above the finished floor level or have an approved child safety lock that comply with ASTM-F2090. R312.2.1.
- Lots shall be graded to drain away from foundations at a min. 6" in the first 10'. (slope must be 1:20) SEC R401.3
- Termite control: foundations must be exposed a minimum 6" for siding and 4" for brick veneer with brick ledge
- Doors between the garage and residence shall be equipped with solid wood doors not less than 1-3/8 inches (35 mm) in thickness, solid or honeycomb core steel doors not less than 1-3/8 inches (35 mm) thick, or 20-minute fire-rated doors, equipped with a self-closing or automatic-closing device per R302.5
- ELECTRICAL - SHALL COMPLY WITH THE CITY'S CURRENT ADOPTION OF THE 2023 NEC INCLUDING BUT NOT LIMITED TO:
 - Receptacles serving kitchen islands and peninsulas can not be mounted below the countertop work surface. Receptacles serving island and peninsulas countertops is optional, however if installed must be installed accordance to the rules in Section 210.52(C)(3)
 - Emergency disconnects required per 2023 NEC Article 230.85
 - Surge protection devices (SPD) required for all services supplying dwellings units per 2023 NEC Article 230.67. Minimum Type 1 or Type2
 - Requires GFCI protection to include all kitchen 120 volt & 240 volt receptacles and service

Planning Development Department



Residential New Building Permit Plan Review Comments

receptacles in the attic NEC 210.8(E)

- Requires GFCI protection including all appliances such as ranges, wall ovens, counter mounted

cooktops and microwave ovens whether hardwired or cord and plug connected NEC 210.8(D)

- Requires GFCI protection to all receptacles in the laundry rooms including 240 volt dryer receptacles NEC 210.8

- Requires GFCI protection for all exterior outlets for 125 volt through 250 volt excluding AC condensers and hardwired lighting NEC 210.8(F)

- All receptacles installed in bathrooms, garages, outdoors, crawl spaces, basements, kitchen

countertops, within 6' of a sink, within 6' of a bathtub or shower stall, laundry areas and indoor

damp and wet locations. Exterior receptacles to be GFCI & weather protected 2023 NEC, Article

210.8 (A)

- Carbon monoxide detector locations required per SEC R315.3

- Smoke detector locations required per SEC.R314.3. Smoke detectors required hard-wired w/battery backup per SEC.R314.6

- Hydro massage bathtub, spa and hot tub locations must be GFCI protected 2023 NEC, Article

680.43(A)

- Service outlets required within 25 feet of mechanical equipment in the attic per 2023 NEC, Article

210.63

- Electrical panels labeled and marked for use per 2023 NEC, Article 408.58

- Branch circuits to AC condensing units shall be minimum of 10 AWG copper conductors. 2023 NEC,

Article 440.6 see FWEC Ordinance No. 18358-11-2008

- Receptacles shall be properly spaced per 2023 NEC Article 201.50

- Tamper resistance rec. req. per 2023 NEC 406.12

- At least one receptacle outlet shall be installed in each vehicle bay and not more than 5.5' above

floor per 2023 NEC 210.52 (G)(1)

MECHANICAL: SHALL COMPLY WITH THE CITY'S CURRENT ADOPTION OF THE 2021 IMC

INCLUDING BUT NOT LIMITED TO

- Attics containing appliances require one of three access entrances 1) permanent stair, 2)300 lb pull

down stair, 3) access door from an upper floor level. SEC M1305.1.3 amendments. - Mechanical

equipment in garage area must be 18" above finished floor. SEC.2408.2

- A level service space not less than 30" deep by 30" wide shall be placed on the service side of the

mechanical units placed in attics. SEC.M1305.1

- A 125-volt receptacle shall be located within 25' of mechanical equipment in the attic for service

and maintenance. SEC.E3901.12

PLUMBING: SHALL COMPLY WITH THE CITY'S CURRENT ADOPTION OF THE 2021

Planning Development Department

IPC INCLUDING

BUT NOT LIMITED TO

- Water heaters in garage required 18" above finish floor. SEC.G2408.2 (305.2)
- Water heater not allowed in attic-single family, duplex or multi-family. SEC. M1305.1.3 (EXCEPTION: Tankless water heaters)
- Vacuum breaker required on all hose bibs. SEC.P2903.8.5
- When water pressure exceeds 80 psi, pressure reducing valve is required. SEC.P2903.3.1

-Full-open shut-off valves to be installed at the home and a second water shut-off valve near the water meter per 2021 IPC 606.1

ENERGY: SHALL COMPLY WITH THE CITY'S CURRENT ADOPTION OF THE 2015 IECC INCLUDING BUT NOT LIMITED TO:

- Energy shall comply with the compliance path as the proposed energy report submitted for the building permit
- A fresh air intake system shall be installed on homes equipped with gas furnaces and the fresh air intake system shall be filtered before air is entered the home through the supply duct plenum
- High efficiency furnaces (min 90%) shall be installed in sealed foamed attics and with the combustible air taken from the exterior of the home

Planning Development Department