



STEEL AUTHORITY OF INDIA LIMITED
HISCO STEEL PLANT
BURNPUR - 713325, WEST BENGAL, INDIA
(Registered Office: Ispat Bhawan, Lodi Road, New Delhi - 110003)
TEST CERTIFICATE FOR HOT ROLLED MEDIUM AND HIGH TENSILE STRUCTURAL STEEL

PRODUCT: NARROW PARALLEL FLANGE BEAMS

TEST CERTIFICATE NO. : TC_8000362448 **TC DATE** : 18.10.2025 **Page No. : 1 of 3**
SHIPPING ADVISE NO. : 8000362448 **SHIPPING DATE** : 18.10.2025

CONSIGNEE NAME & ADDRESS : WHM GHAZIABAD
NEAR GULDHAR RAILWAY GHAZIABAD-201001, UTTAR PRADESH **WAGON/TRAILER NO. : SEC21141069732**

It is certified that the material described below fully conforms to IS 2062 : 2011. Chemical composition and Mechanical properties of the product, as tested in accordance with the Scheme of Inspection and Testing contained in the BIS Certification Marks License No.CM/L-0063630 are as indicated below against each Order/Cast No.
(Please refer to IS 2062 : 2011 for details of specification requirements)

TEST RESULTS

Designation: NPB 450 X 190 X 77.58 **Order / MP No. & Date** : 1500242117 (16.10.2025) **Total weight:** 55.100 MT
Mode of De-oxidation: Si-Killed **Supply Condition:** As rolled

Cast No.	No. Of Pcs	Section (nominal Size)			Chemical Composition																		
		Depth (mm)	X Fl width (mm)	X Fl Thk (mm)	X Sectional Weight (Kg/m)	Length (m)	Qty in MT	C%	Mn%	P%	S%	Si%	Al%	Cu%	Nb%	V%	Ti%	Cr%	Mo%	Ni%	B%	N ₂ (ppm)	CE%
		Specification																					
						Min	-	-	-	-	0.10	-	-	-	-	-	-	-	-	-	-	-	-
						Max	0.22	1.50	0.045	0.045	0.40	-	-	-	-	-	-	-	-	-	-	90	0.41
12406196	16	450 X 190 X 14.6 X 9.4 X 77.58			12	13.535	0.16	0.70	0.021	0.024	0.19	0.002	0.01	0.001	0.001	0.001	0.01	Tr	0.01	0.0004		64	0.28

Cast No.	Mechanical Properties			Bend	Impact (J) Avg.	Grade
	Yield Strength, MPa	Tensile Strength, MPa	% Elongation Gauge Length = 5.65 * sqrt (So)			
Specification	250 min	410 min	23 min	2t min		
12406196	278	333	488	OK	OK	IS 2062 : 2011 E250BR

Dimensions conform to IS 808 and tolerances to IS 12779. M/s. **RAJASTHAN STEEL**
Chemical Composition reported is Ladle Analysis

Remarks : TC as per EN 10204 Inspection Certificate type **Dated 31.08.2026**

Niherika Logistics Pvt. Ltd.

Consignment Handling Agency

Legend (where applicable) :
CE = Carbon Equivalent = C + Mn/6 + (Cr + Mo + V)/5 + (Cu + Ni)/10
NS = Not Specified, Tr = Traces, Thk = Thickness, Fl = Flange



Process Route: BF-BOF-LF-CC-UNIVERSAL STRUCTURAL MILL

AUTHORISED SIGNATORY

H. K. CHOWDHARY
GM (R&C)A6



STEEL AUTHORITY OF INDIA LIMITED
ISCO STEEL PLANT
BURNPUR - 713325, WEST BENGAL, INDIA
(Registered Office: Ispat Bhawan, Lodi Road, New Delhi - 110003)
TEST CERTIFICATE FOR HOT ROLLED MEDIUM AND HIGH TENSILE STRUCTURAL STEEL

PRODUCT: NARROW PARALLEL FLANGE BEAMS

TEST CERTIFICATE NO. : TC_8000362448 TC DATE : 18.10.2025 Page No. : 2 of 3
SHIPPING ADVISE NO. : 8000362448 SHIPPING DATE : 18.10.2025
CONSIGNEE NAME & ADDRESS : WHM GHAZIABAD
NEAR GULDHAR RAILWAY GHAZIABAD-201001, UTTAR PRADESH
WAGON/TRAILER NO. : SECR21141069732

It is certified that the material described below fully conforms to IS 2062 : 2011. Chemical composition and Mechanical properties of the product, as tested in accordance with the Scheme of Inspection and Testing contained in the BIS Certification Marks License No. CM/L-0063630 are as indicated below against each Order/Cast No.
(Please refer to IS 2062 : 2011 for details of specification requirements)

TEST RESULTS

Designation: NPB 450 X 190 X 77.58 Order / MP No. & Date : 1500242117 (16.10.2025) Total weight: 55.100 MT
Mode of De-oxidation: Si-Killed Supply Condition: As rolled

Cast No.	No. Of Pcs	Section (nominal Size)			Qty in MT	Chemical Composition																
		Depth (mm) X Fl width (mm) X Fl Thk (mm) X Sectional Weight (Kg/m)	Length (m)			C%	Mn%	P%	S%	Si%	Al%	Cu%	Nb%	V%	Ti%	Cr%	Mo%	Ni%	B%	N ₂ (ppm)	CE%	
Specification																						
					Min	-	-	-	-	0.10	-	-	-	-	-	-	-	-	-	-	-	
					Max	0.22	1.50	0.045	0.045	0.40	-	-	-	-	-	-	-	-	-	90	0.41	
22505224	22	450 X 190 X 14.6 X 9.4 X 77.58			12	19.144	0.19	0.76	0.022	0.020	0.22	0.002	0.01	0.000	0.001	0.002	0.01	Tr	0.01	0.0004	65	0.32

Cast No.	Mechanical Properties				Bend	Impact (J) Avg.	Grade
	Yield Strength, MPa	Tensile Strength, MPa	% Elongation Gauge Length = 5.65 * sqrt (So)	% Elongation 23 min			
Specification	250 min	410 min	23 min	27	2t min	OK	IS 2062 : 2011 E250ER
22505224	329	334	483	489	OK	OK	NS

Dimensions conform to IS 808 and tolerances to IS 12779.
Chemical Composition reported is Ladle Analysis
Remarks : TC as per EN 10204 Inspection Certificate type 3.1.
LEGEND (where applicable):
CE = Carbon Equivalent = C + Mn/6 + (Cr + Mo + V)/5 + (Cu + Ni)/15
NS = Not Specified, Tr = Traces; J = Joules, Thk = Thickness, Fl = Flange
H. K. CHOWDHARY
GM (R&C LAB)
AUTHORISED SIGNATORY
Process Route: BF-BOF-LF-CC-UNIVERSAL STRUCTURAL MILL
Logistics Agency
Quality: Satisfactory
Date: 18/10/2025
Signature: [Signature]
QR Code: [QR Code]



STEEL AUTHORITY OF INDIA LIMITED

HISCO STEEL PLANT

BURNPUR - 713325, WEST BENGAL, INDIA

(Registered Office: Ispat Bhawan, Lodi Road, New Delhi - 110003)

TEST CERTIFICATE FOR HOT ROLLED MEDIUM AND HIGH TENSILE STRUCTURAL STEEL

CM/L-0063630

PRODUCT: NARROW PARALLEL FLANGE BEAMS

Page No. : 3 of 3

TEST CERTIFICATE NO. : TC_8000362448

SHIPPING ADVISE NO. : 8000362448

WAGON/TRAILER NO. : SEC21141069732

CONSIGNEE NAME & ADDRESS : WHM GHAZIABAD

NEAR GULDHAR RAILWAY GHAZIABAD-201001, UTTAR PRADESH

It is certified that the material described below fully conforms to IS 2062 : 2011. Chemical composition and Mechanical properties of the product, as tested in accordance with the Scheme of Inspection and Testing contained in the BIS Certification Marks License No.CM/L-0063630 are as indicated below against each Order/Cast No.
(Please refer to IS 2062 : 2011 for details of specification requirements)

TEST RESULTS

Designation: NPB 450 X 190 X 77.58

Order / MP No. & Date : 1500242117 (16.10.2025)

Total weight: 55.100 MT

Supply Condition: As rolled

Cast No.	No. Of Pcs	Section (nominal Size)		Qty in MT	Chemical Composition														
		Depth (mm) X Fl width (mm) X Fl Thk (mm) X Sectional Weight (Kg/m)	Length (m)		C%	Mn%	P%	S%	Si%	Al%	Cr%	Nb%	V%	Ti%	Cr%	Mo%	Ni%	B%	N ₂ (ppm)
Specification																			
				Min	-	-	-	-	0.10	-	-	-	-	-	-	-	-	-	-
				Max	0.22	1.50	0.045	0.045	0.40	-	-	-	-	-	-	-	-	-	90
32506410	26	450 X 190 X 14.6 X 9.4 X 77.58	12	22.421	0.20	0.72	0.030	0.014	0.18	0.003	0.01	0.002	0.002	0.002	0.01	Tr	0.01	0.0004	66
																			0.32

Cast No.	Mechanical Properties			Bend	Impact (J) Avg.	Grade
	Yield Strength, MPa	Tensile Strength, MPa	% Elongation Gauge Length = 5.65 * sqrt (So)			
Specification	250 min	410 min	23 min	2t min		
32506410	307	309	432	436	26	26
					OK	OK
					NS	IS 2062 : 2011 E250BR

This Test Certificate is Valid

Dimensions conform to IS 808 and tolerances to IS 12779.
Chemical Composition reported is Ladle Analysis

Remarks : TC as per EN 10204 Inspection Certificate type 3.1.

LEGEND (where applicable) :

CE = Carbon Equivalent = C + Mn/6 + (Cr + Mo + V)/5 + (Cu + Ni)/10
NS = Not Specified, Tr = Traces; J = Joules, Thk = Thickness, Fl = Flange

For Surface, Material & Dimensions
M/s.
Dated
Niherika Logistics Pvt. Ltd.
Assignment Handling Agency
Of Steel Authority of India Limited, Ghaziabad



Process Route: BF-BOF-LF-CC-UNIVERSAL STRUCTURAL MILL.

AUTHORISED SIGNATORY

H. K. CHOWDHARY
GM (R&C LAB)