

8	TDCG	1478.0	ppm	Condition 2	
9	TDCG Rate	0.72	ppm/day	Slow (less than 10 ppm)	
10	O2/N2 ratio	0.322			
11	Transformer Age	26.381	years		
12	Hydrogen rate	48.939	ppm/year		DGA Status 3
13	Methane rate	34.371	ppm/year		DGA Status 3
14	Ethane rate	13.043	ppm/year		DGA Status 3
15	Ethylene rate	59.41	ppm/year		DGA Status 3
16	Acetylene rate	1.047	ppm/year		DGA Status 2
17	Carbonmonoxide rate	149.095	ppm/year		DGA Status 3
18	Carbondioxide rate	896.847	ppm/year		DGA Status 2
19	Keygas Analysis			Cellulose Thermal Decomposition	Cellulose Thermal Decomposition
20	Rogers Ratio			Low Temperature Thermal	Low Temperature Thermal
21	Doernenburg Ratio			No Condition	No Condition
22	Duval Triangle 1			T3 (Thermal Fault T>700 Deg C)	T3 (Thermal Fault T>700 Deg C)
23	Duval Triangle 4			S (Stray Gassing)	S (Stray Gassing)
24	Duval Triangle 5			C (Carbonisation)	C (Carbonisation)
25	Duval Pentagon 1			T3 (Thermal Faults > 700°C)	T3 (Thermal Faults > 700°C)
26	Duval Pentagon 2			T3-H (High Temperature Fault Occuring in Oil)	T3-H (High Temperature Fault Occuring in Oil)

Recommendation :

1. IEEE C37.104 2008 : Exercise caution. Analyse individual gas to find cause. Determine load dependence. Quarterly oil sampling interval
2. IEEE C37.104 2019 : Perform Fault Identification and Transformer Assesment. Take Appropriate Action based on Transformer Assesment Result and Company Policy

Disclaimer:

The information presented in this Dissolved Gas Analysis (DGA) report is intended solely for informational and diagnostic purposes. While Power Prognosis has made every effort to ensure the accuracy and reliability of the data and interpretations provided herein, the results are based on the input data, analytical methods, and models available at the time of analysis. This report does not constitute a guarantee, warranty, or certification of the condition, safety, or performance of the electrical equipment analyzed. Any decisions regarding equipment maintenance, operation, or replacement should be made in consultation with qualified technical personnel and based on a combination of condition monitoring methods, engineering judgment, and operational priorities. Power Prognosis assumes no liability for any loss, damage, or injury resulting from the use or interpretation of this report.

PRINT

POWER PROGNOSIS



Power Prognosis is a digital media and knowledge hub dedicated to diagnostics, condition monitoring, and predictive analytics for electrical machines and power systems.

KNOW MORE

RELATED DGA RESOURCES

- 

Complete Guide to Transformer Dissolved Gas Analysis (DGA) Methods, Standards, Interpretation, and Practical Limitations
- 

IEEE C57.104-2019 vs 2008: What Changed, Why It Matters for Transformer DGA
- 

How to Use the Duval Triangle Method for Transformer DGA (With Examples)
- 

Duval Pentagon: Advanced DGA for Transformer Fault Detection

INFORMATION

- About Us
- AI Usage Disclaimer
- Contributor Agreement
- Contact Us
- Cookies Policy
- Copyright & Intellectual Property
- Frequently Asked Questions
- Plagiarism Disclaimer
- Privacy Policy
- Sitemap
- Term of Use

GET IN TOUCH

Got questions, ideas, or want to contribute?

Website & Tools Support: support@powerprognosis.com

Submit an Article: editor@powerprognosis.com

Media & Partnerships: media@powerprognosis.com

