

# Fire Alarm and Life Safety System Inspection Certificate

*For*

Client Name  
12533 Miami Way  
Miami, FL, FL 33016

Tested to NFPA 72 Standards

*This Inspection was performed in accordance with applicable NFPA Standards. The subsequent pages of this report provide performance measurements, listed ranges of acceptable results, and complete documentation of the inspection. Whenever discrepancies exist between acceptable performance standards and actual test results, notes and/or recommended solutions have been proposed or provided for immediate review and approval.*

*Inspection Date*  
*Jun 19, 2010*

Building: Client Name  
Contact: Client Contact  
Title: Building Manager

Company: Integrated Security Systems  
Contact: Derek J. Klein  
Title: Fire Alarm Systems Inspector

# Executive Summary

Generated by: BuildingReports.com

<b>Building Information</b>								
<b>Building:</b> Client Name			<b>Contact:</b> Client Contact					
<b>Address:</b> 12533 Miami Way			<b>Phone:</b> 305-822-3130					
<b>Address:</b>			<b>Fax:</b>					
<b>City/State/Zip:</b> Miami, FL, FL 33016			<b>Mobile:</b> 305-822-3130					
<b>Country:</b> United States of America			<b>Email:</b>					
<b>Inspection Performed By</b>								
<b>Company:</b> Integrated Security Systems			<b>Inspector:</b> Derek J. Klein					
<b>Address:</b> 1876 N.W. 7th Street			<b>Phone:</b> 305-341-4607					
<b>Address:</b>			<b>Fax:</b> 305-324-0008					
<b>City/State/Zip:</b> Miami, FL 33125			<b>Mobile:</b> 305.222.3333					
<b>Country:</b> United States of America			<b>Email:</b> Service@TeamISS.com					
<b>System Control Unit</b>								
<b>Manufacturer:</b> EST			<b>Inspection Date:</b> 06/19/2010			<b>IDC Style:</b> B		
<b>Model Number:</b> EST3			<b>Install Date:</b> 06/02/2009			<b>SLC Style:</b> 4		
<b>Software Version:</b> 03.60.00			<b>Version Date:</b> 11/14/2005			<b>NAC Style:</b> Y		
<b>Location:</b> 1st Front Lobby Area			<b>Current Protection:</b> Breaker					
<b>Monitoring</b>								
<b>Type:</b> Digital Communicator			<b>Mfg:</b> EST			<b>Model #:</b> EST3		
<b>Test Time/Date:</b> 6/19/10 10:03:58 AM			<b>Restore Time:</b>					
<b>Inspection Summary</b>								
Category	Total Items		Serviced		Passed		Failed/Other	
	Qty	%	Qty	%	Qty	%	Qty	%
Supervisory	16	11.35%	16	100.00%	16	100.00%	0	0%
Monitor	1	0.71%	1	100.00%	1	100.00%	0	0%
Auxiliary	3	2.13%	3	100.00%	3	100.00%	0	0%
Initiating	98	69.50%	98	100.00%	98	100.00%	0	0%
Indicating	11	7.80%	11	100.00%	11	100.00%	0	0%
Control	12	8.51%	12	100.00%	12	100.00%	0	0%
<b>Totals</b>	<b>141</b>	<b>100%</b>	<b>141</b>	<b>100.00%</b>	<b>141</b>	<b>100.00%</b>	<b>0</b>	<b>0%</b>
<b>Certification</b>								
Building: Client Name			Company: Integrated Security Systems					
Contact: Client Contact			Inspector: Derek J. Klein					
Signed:			Signed:					

# Inspection & Testing

Generated by: BuildingReports.com

Building: Client Name		Control Panel: 1 - EST   EST3		
<i>The Inspection &amp; Testing section lists all of the items inspected in your building.   Items are grouped by Passed or Failed/Other. Items are listed by Category. Each item includes the services performed, and the time &amp; date at which testing occurred.</i>				
Device Type	Location	Service	Time	Date
Passed				
Auxiliary				
Programmable Relay	1st Inside Elevator Machine Room	Tested	2:51:08 PM	06/19/2010
Programmable Relay	1st Inside Elevator Machine Room	Tested	2:51:12 PM	06/19/2010
Programmable Relay	1st Inside Elevator Machine Room	Tested	2:51:17 PM	06/19/2010
Control				
Battery	1st Front Electrical Room	Tested	9:30:39 AM	06/19/2010
Battery	1st Front Electrical Room	Tested	9:39:01 AM	06/19/2010
Battery	1st Front Electrical Room	Tested	9:43:02 AM	06/19/2010
Battery	1st Front Lobby Area	Tested	10:04:10 AM	06/19/2010
Communication Line	1st Front Electrical Room	Tested	9:55:56 AM	06/19/2010
Communication Line	1st Front Electrical Room		9:56:09 AM	06/19/2010
Communicator	1st Front Lobby Area	Tested	10:03:58 AM	06/19/2010
Control Panel	1st Front Lobby Area	Tested	10:04:50 AM	06/19/2010
Disconnect	1st Front Electrical Room	Tested	10:02:08 AM	06/19/2010
Power Supply	1st Front Electrical Room	Tested	9:26:31 AM	06/19/2010
Power Supply	1st Front Electrical Room	Tested	9:40:58 AM	06/19/2010
Power Supply	1st Front Electrical Room	Tested	9:45:06 AM	06/19/2010
Indicating				
Bell	1st Outside Pump Room	Tested	10:07:44 AM	06/19/2010
Horn/Strobe	1st Front Electrical Room	Tested	9:56:40 AM	06/19/2010
Horn/Strobe	1st Front Electrical Room	Tested	9:56:50 AM	06/19/2010
Horn/Strobe	1st Front Electrical Room	Tested	9:56:51 AM	06/19/2010
Horn/Strobe	1st Front Electrical Room	Tested	9:56:52 AM	06/19/2010
Horn/Strobe	1st Front Electrical Room	Tested	9:58:08 AM	06/19/2010
Horn/Strobe	1st Front Electrical Room	Tested	9:58:23 AM	06/19/2010
Horn/Strobe	1st Front Electrical Room	Tested	9:58:32 AM	06/19/2010
Horn/Strobe	1st Front Electrical Room	Tested	9:58:49 AM	06/19/2010
Horn/Strobe	1st Front Electrical Room	Tested	9:58:59 AM	06/19/2010
Horn/Strobe	1st Front Electrical Room	Tested	9:59:07 AM	06/19/2010
Initiating				
Heat Detector	1st West Laundry Room	Tested	10:13:27 AM	06/19/2010
Heat Detector	1st West Compactor Room	Tested	2:59:53 PM	06/19/2010
Pull Station	1st West Lobby Entrance	Tested	10:21:22 AM	06/19/2010
Pull Station	1st Southwest Hallway Exit	Tested	10:29:43 AM	06/19/2010
Pull Station	1st Southeast Hallway Exit	Tested	10:34:54 AM	06/19/2010
Pull Station	1st Southeast Activity Rm Exit	Tested	10:35:40 AM	06/19/2010
Pull Station	1st Northeast Activity Rm Exit	Tested	10:41:23 AM	06/19/2010
Pull Station	1st Northeast Hallway Exit	Tested	10:44:12 AM	06/19/2010

Device Type	Location	Service	Time	Date
Pull Station	1st Inside Pump Room Exit	Tested	2:49:31 PM	06/19/2010
Pull Station	1st compactor room Entrance	Tested	2:53:04 PM	06/19/2010
Pull Station	2nd Northeast Hallway Exit	Tested	2:34:01 PM	06/19/2010
Pull Station	2nd Inside Elevator Lobby	Tested	2:36:37 PM	06/19/2010
Pull Station	2nd Southwest Hallway Exit	Tested	2:38:58 PM	06/19/2010
Pull Station	3rd Southwest Hallway Exit	Tested	2:24:16 PM	06/19/2010
Pull Station	3rd At Elevator Lobby	Tested	2:26:37 PM	06/19/2010
Pull Station	3rd Northeast Hallway Exit	Tested	2:28:42 PM	06/19/2010
Pull Station	4th North Hallway Exit	Tested	2:04:56 PM	06/19/2010
Pull Station	4th West Elevator Lobby	Tested	2:14:16 PM	06/19/2010
Pull Station	4th South Hallway Exit	Tested	2:19:38 PM	06/19/2010
Pull Station	5th South Hallway Exit	Tested	11:44:12 AM	06/19/2010
Pull Station	5th Northwest Hallway Exit	Tested	11:45:44 AM	06/19/2010
Pull Station	5th North Hallway Exit	Tested	1:58:23 PM	06/19/2010
Smoke Detector	1st Above Electrical Room	Tested/Cleaned	10:14:51 AM	06/19/2010
Smoke Detector	1st Front Lobby Area	Tested/Cleaned	10:23:00 AM	06/19/2010
Smoke Detector	1st South Hallway Entrance	Tested/Cleaned	10:25:18 AM	06/19/2010
Smoke Detector	1st South Hallway	Tested/Cleaned	10:26:12 AM	06/19/2010
Smoke Detector	1st South Hallway	Tested/Cleaned	10:28:00 AM	06/19/2010
Smoke Detector	1st South Hallway	Tested/Cleaned	10:28:42 AM	06/19/2010
Smoke Detector	1st South Hallway Exit	Tested/Cleaned	10:29:08 AM	06/19/2010
Smoke Detector	1st Southeast Activity Room 2	Tested/Cleaned	10:36:06 AM	06/19/2010
Smoke Detector	1st Southeast Elevator Lobby	Tested/Cleaned	10:37:03 AM	06/19/2010
Smoke Detector	1st Northeast Elevator Lobby	Tested/Cleaned	10:37:54 AM	06/19/2010
Smoke Detector	1st Northeast Activity Room	Tested/Cleaned	10:38:28 AM	06/19/2010
Smoke Detector	1st North Hallway	Tested/Cleaned	10:41:57 AM	06/19/2010
Smoke Detector	1st North Hallway	Tested/Cleaned	10:43:02 AM	06/19/2010
Smoke Detector	1st North Hallway Exit	Tested/Cleaned	10:43:49 AM	06/19/2010
Smoke Detector	1st Southeast Pump Room	Tested/Cleaned	2:48:25 PM	06/19/2010
Smoke Detector	1st Inside Elevator Machine Room	Tested/Cleaned	2:51:03 PM	06/19/2010
Smoke Detector	1st Above Store Room	Tested/Cleaned	3:02:43 PM	06/19/2010
Smoke Detector	1st Inside Main Office	Tested/Cleaned	3:02:52 PM	06/19/2010
Smoke Detector	1st Elevator Lobby	Tested/Cleaned	3:02:55 PM	06/19/2010
Smoke Detector	2nd Northeast Hallway Exit	Tested/Cleaned	2:34:19 PM	06/19/2010
Smoke Detector	2nd Northeast Hallway	Tested/Cleaned	2:34:37 PM	06/19/2010
Smoke Detector	2nd Northwest Hallway	Tested/Cleaned	2:35:02 PM	06/19/2010
Smoke Detector	2nd Northwest Hallway	Tested/Cleaned	2:35:16 PM	06/19/2010
Smoke Detector	2nd Northwest Hallway Entrance	Tested/Cleaned	2:35:31 PM	06/19/2010
Smoke Detector	2nd At Elevator Lobby	Tested/Cleaned	2:35:56 PM	06/19/2010
Smoke Detector	2nd Southwest Hallway Entrance	Tested/Cleaned	2:36:54 PM	06/19/2010
Smoke Detector	2nd Southwest Hallway	Tested/Cleaned	2:37:10 PM	06/19/2010
Smoke Detector	2nd Southwest Hallway	Tested/Cleaned	2:37:27 PM	06/19/2010
Smoke Detector	2nd Southwest Hallway	Tested/Cleaned	2:37:41 PM	06/19/2010
Smoke Detector	2nd Southwest Hallway Exit	Tested/Cleaned	2:37:59 PM	06/19/2010
Smoke Detector	3rd Southwest Hallway Exit	Tested/Cleaned	2:24:39 PM	06/19/2010
Smoke Detector	3rd Southwest Hallway	Tested/Cleaned	2:25:10 PM	06/19/2010
Smoke Detector	3rd Southwest Hallway	Tested/Cleaned	2:25:22 PM	06/19/2010
Smoke Detector	3rd Southwest Hallway	Tested/Cleaned	2:25:38 PM	06/19/2010
Smoke Detector	3rd Southwest Hallway Entrance	Tested/Cleaned	2:25:54 PM	06/19/2010
Smoke Detector	3rd At Elevator Lobby	Tested/Cleaned	2:27:17 PM	06/19/2010
Smoke Detector	3rd Northeast Hallway Entrance	Tested/Cleaned	2:27:31 PM	06/19/2010
Smoke Detector	3rd Northeast Hallway	Tested/Cleaned	2:27:46 PM	06/19/2010

Device Type	Location	Service	Time	Date
Smoke Detector	3rd Northeast Hallway	Tested/Cleaned	2:28:00 PM	06/19/2010
Smoke Detector	3rd Northeast Hallway	Tested/Cleaned	2:28:13 PM	06/19/2010
Smoke Detector	3rd Northeast Hallway Exit	Tested/Cleaned	2:28:30 PM	06/19/2010
Smoke Detector	4th East Corridor	Tested/Cleaned	2:06:28 PM	06/19/2010
Smoke Detector	4th East Corridor	Tested/Cleaned	2:07:22 PM	06/19/2010
Smoke Detector	4th East Corridor	Tested/Cleaned	2:08:32 PM	06/19/2010
Smoke Detector	4th East Corridor	Tested/Cleaned	2:09:32 PM	06/19/2010
Smoke Detector	4th East Corridor	Tested/Cleaned	2:10:08 PM	06/19/2010
Smoke Detector	4th Above Elevator Lobby	Tested/Cleaned	2:11:19 PM	06/19/2010
Smoke Detector	4th West Corridor	Tested/Cleaned	2:16:43 PM	06/19/2010
Smoke Detector	4th West Corridor	Tested/Cleaned	2:17:22 PM	06/19/2010
Smoke Detector	4th West Corridor	Tested/Cleaned	2:17:44 PM	06/19/2010
Smoke Detector	4th West Corridor	Tested/Cleaned	2:18:08 PM	06/19/2010
Smoke Detector	4th West Corridor	Tested/Cleaned	2:18:57 PM	06/19/2010
Smoke Detector	5th West Hallway	Tested/Cleaned	11:28:15 AM	06/19/2010
Smoke Detector	5th West Hallway	Tested/Cleaned	11:30:08 AM	06/19/2010
Smoke Detector	5th West Hallway	Tested/Cleaned	11:33:43 AM	06/19/2010
Smoke Detector	5th West Hallway	Tested/Cleaned	11:34:28 AM	06/19/2010
Smoke Detector	5th West Hallway	Tested/Cleaned	11:35:28 AM	06/19/2010
Smoke Detector	5th Above Elevator Lobby	Tested/Cleaned	1:48:01 PM	06/19/2010
Smoke Detector	5th West Corridor	Tested/Cleaned	1:51:43 PM	06/19/2010
Smoke Detector	5th West Corridor	Tested/Cleaned	1:52:57 PM	06/19/2010
Smoke Detector	5th West Corridor	Tested/Cleaned	1:54:09 PM	06/19/2010
Smoke Detector	5th West Corridor	Tested/Cleaned	1:54:41 PM	06/19/2010
Smoke Detector	5th West Corridor	Tested/Cleaned	1:56:52 PM	06/19/2010
Waterflow Switch	1st North Stairwell Exit	Tested	10:45:31 AM	06/19/2010
Waterflow Switch	1st South Stairwell	Tested	2:43:02 PM	06/19/2010
Waterflow Switch	1st Inside Pump Room	Tested	2:49:17 PM	06/19/2010
Waterflow Switch	1st West Compactor Room	Tested	2:58:04 PM	06/19/2010
Waterflow Switch	1st Inside Pump Room	Tested	3:03:02 PM	06/19/2010
Waterflow Switch	2nd North Stairwell	Tested	2:32:51 PM	06/19/2010
Waterflow Switch	2nd South Stairwell	Tested	2:39:58 PM	06/19/2010
Waterflow Switch	3rd South Stairwell	Tested	2:23:16 PM	06/19/2010
Waterflow Switch	3rd North Stairwell	Tested	2:30:27 PM	06/19/2010
Waterflow Switch	4th North Stairwell	Tested	2:03:57 PM	06/19/2010
Waterflow Switch	4th South Stairwell	Tested	2:20:55 PM	06/19/2010
Waterflow Switch	5th South Stairwell	Tested	11:38:25 AM	06/19/2010
Waterflow Switch	5th North Stairwell	Tested	1:59:59 PM	06/19/2010
<b>Monitor</b>				
Monitoring	1st Front Lobby Area	Tested	10:04:28 AM	06/19/2010
<b>Supervisory</b>				
Tamper Switch	1st North Stairwell Exit	Tested	10:54:16 AM	06/19/2010
Tamper Switch	1st Southwest Stairwell Exit	Tested	2:42:27 PM	06/19/2010
Tamper Switch	1st Inside Pump Room	Tested	2:48:59 PM	06/19/2010
Tamper Switch	1st Inside Pump Room	Tested	2:49:07 PM	06/19/2010
Tamper Switch	1st Inside compactor room Room	Tested	2:57:53 PM	06/19/2010
Tamper Switch	1st Inside compactor room Room	Tested	3:03:00 PM	06/19/2010
Tamper Switch	1st Inside Pump Room	Tested	3:03:04 PM	06/19/2010
Tamper Switch	2nd North Stairwell	Tested	2:32:06 PM	06/19/2010
Tamper Switch	2nd South Stairwell	Tested	2:41:11 PM	06/19/2010
Tamper Switch	3rd South Stairwell	Tested	2:22:44 PM	06/19/2010

Device Type	Location	Service	Time	Date
Tamper Switch	3rd North Stairwell	Tested	2:30:56 PM	06/19/2010
Tamper Switch	4th North Stairwell	Tested	2:03:23 PM	06/19/2010
Tamper Switch	4th South Stairwell	Tested	2:21:28 PM	06/19/2010
Tamper Switch	5th South Stairwell	Tested	11:42:09 AM	06/19/2010
Tamper Switch	5th North Stairwell	Tested	2:00:30 PM	06/19/2010
Tamper Switch	Ground Behind Building	Tested	3:01:13 PM	06/19/2010

# Auxiliary Functions Testing

Generated by: BuildingReports.com

Building: Client Name		Control Panel: 1 - EST   EST3		
<i>The Auxiliary Functions Testing section lists each of the ancillary items, systems, and emergency equipment that are controlled by the system control unit. Items are grouped by Passed or Failed/Other. The items are listed by device type, and a check box is provided to indicate if the test conducted was simulated.</i>				
Type	Location	Comment	ScanID	Simulated
Passed				
Programmable Relay				
Warning Light	1st Inside Elevator Machine Room	Passed	04853879	<input type="checkbox"/>
Primary Recall	1st Inside Elevator Machine Room	Passed	04853880	<input type="checkbox"/>
Alternate Recall	1st Inside Elevator Machine Room	Passed	04853881	<input type="checkbox"/>
Smoke Detector				
Elevator Recall	1st Elevator Lobby	Passed	04853853	<input type="checkbox"/>
Elevator Recall	2nd At Elevator Lobby	Passed	3933944519	<input type="checkbox"/>
Elevator Recall	3rd At Elevator Lobby	Passed	3933934008	<input type="checkbox"/>



# Sensitivity Testing

Generated by: BuildingReports.com

Building: Client Name			Control Panel: 1 - EST    EST3		
<i>The Sensitivity Testing section details the sensitivity test ranges and acceptable readings for each type of device.  Items are grouped by Passed or Failed/Other. Normally, Devices that perform outside the acceptable range of sensitivity are listed in Failed/Other.</i>					
Location	Address	Model #	Range	%	ScanID
<i>Passed</i>					
Smoke Detector					
1st Above Electrical Room	D 112	SIGA-PS	0.67 – 3.77	< 20%	3933944571
1st Front Lobby Area	D 110	SIGA-PS	0.67 – 3.77	< 20%	04853851
1st South Hallway Entrance	D 114	SIGA-PS	0.67 – 3.77	< 20%	04853852
1st South Hallway	D 117	SIGA-PS	0.67 – 3.77	< 20%	04853862
1st South Hallway	D 119	SIGA-PS	0.67 – 3.77	< 20%	04853861
1st South Hallway	D 120	SIGA-PS	0.67 – 3.77	< 20%	04853860
1st South Hallway Exit	D 121	SIGA-PS	0.67 – 3.77	< 20%	04853859
1st Southeast Activity Room 2	D 106	SIGA-PS	0.67 – 3.77	< 20%	04853857
1st Southeast Elevator Lobby	D 107	SIGA-PS	0.67 – 3.77	< 20%	04853854
1st Northeast Elevator Lobby	D 104	SIGA-PS	0.67 – 3.77	< 20%	04853855
1st Northeast Activity Room	D 105	SIGA-PS	0.67 – 3.77	< 20%	04853856
1st North Hallway	D 103	SIGA-PS	0.67 – 3.77	< 20%	04853865
1st North Hallway	D 102	SIGA-PS	0.67 – 3.77	< 20%	04853864
1st North Hallway Exit	D 101	SIGA-PS	0.67 – 3.77	< 20%	04853863
1st Southeast Pump Room	D 118	SIGA-PS	0.67 – 3.77	< 20%	3933978231
1st Inside Elevator Machine Room	D 116	SIGA-PS	0.67 – 3.77	< 20%	3933995153
1st Above Store Room	D 111	SIGA-PS	0.67 – 3.77	< 20%	3934050530
1st Inside Main Office	D 109	SIGA-PS	0.67 – 3.77	< 20%	04853858
1st Elevator Lobby	D 115	SIGA-PS	0.67 – 3.77	< 20%	04853853
2nd Northeast Hallway Exit	D 201	SIGA-PS	0.67 – 3.77	< 20%	3933987486
2nd Northeast Hallway	D 202	SIGA-PS	0.67 – 3.77	< 20%	3934052435
2nd Northwest Hallway	D 203	SIGA-PS	0.67 – 3.77	< 20%	3934052411
2nd Northwest Hallway	D 204	SIGA-PS	0.67 – 3.77	< 20%	3933934329
2nd Northwest Hallway Entrance	D 205	SIGA-PS	0.67 – 3.77	< 20%	3933934084
2nd At Elevator Lobby	D 206	SIGA-PS	0.67 – 3.77	< 20%	3933944519
2nd Southwest Hallway Entrance	D 207	SIGA-PS	0.67 – 3.77	< 20%	3934052459
2nd Southwest Hallway	D 208	SIGA-PS	0.67 – 3.77	< 20%	3933873970
2nd Southwest Hallway	D 209	SIGA-PS	0.67 – 3.77	< 20%	3933937726
2nd Southwest Hallway	D 210	SIGA-PS	0.67 – 3.77	< 20%	3933951531
2nd Southwest Hallway Exit	D 211	SIGA-PS	0.67 – 3.77	< 20%	3933943758
3rd Southwest Hallway Exit	D 311	SIGA-PS	0.67 – 3.77	< 20%	3933934251
3rd Southwest Hallway	D 310	SIGA-PS	0.67 – 3.77	< 20%	3933934534
3rd Southwest Hallway	D 309	SIGA-PS	0.67 – 3.77	< 20%	3933934503
3rd Southwest Hallway	D 308	SIGA-PS	0.67 – 3.77	< 20%	3934022865
3rd Southwest Hallway Entrance	D 307	SIGA-PS	0.67 – 3.77	< 20%	3933951593
3rd At Elevator Lobby	D 306	SIGA-PS	0.67 – 3.77	< 20%	3933934008
3rd Northeast Hallway Entrance	D 305	SIGA-PS	0.67 – 3.77	< 20%	04853866
3rd Northeast Hallway	D 304	SIGA-PS	0.67 – 3.77	< 20%	3933934022
3rd Northeast Hallway	D 303	SIGA-PS	0.67 – 3.77	< 20%	3933934626



3rd Northeast Hallway	D 302	SIGA-PS	0.67 – 3.77	< 20%	3933913874
3rd Northeast Hallway Exit	D 301	SIGA-PS	0.67 – 3.77	< 20%	3933949774
4th East Corridor	D 401	SIGA-PS	0.67 – 3.77	.<20%	3933916790
4th East Corridor	D 402	SIGA-PS	0.67 – 3.77	.<20%	3933946193
4th East Corridor	D 403	SIGA-PS	0.67 – 3.77	.<20%	3933945813
4th East Corridor	D 404	SIGA-PS	0.67 – 3.77	.<20%	3934020526
4th East Corridor	D 405	SIGA-PS	0.67 – 3.77	.<20%	3934022872
4th Above Elevator Lobby	D 406	SIGA-PS	0.67 – 3.77	.<20%	3934026672
4th West Corridor	D 407	SIGA-PS	0.67 – 3.77	.<20%	3934024029
4th West Corridor	D 408	SIGA-PS	0.67 – 3.77	.<20%	3933873895
4th West Corridor	D 409	SIGA-PS	0.67 – 3.77	.<20%	3934024609
4th West Corridor	D 410	SIGA-PS	0.67 – 3.77	.<20%	3934023947
4th West Corridor	D 411	SIGA-PS	0.67 – 3.77	.<20%	3933951555
5th West Hallway	D 507	SIGA-PS	0.67 – 3.77	.<20%	3933949729
5th West Hallway	D 508	SIGA-PS	0.67 – 3.77	.<20%	3934020519
5th West Hallway	D 509	SIGA-PS	0.67 – 3.77	.<20%	3933934510
5th West Hallway	D 510	SIGA-PS	0.67 – 3.77	.<20%	3934024630
5th West Hallway	D 511	SIGA-PS	0.67 – 3.77	.<20%	3933916844
5th Above Elevator Lobby	D 506	SIGA-PS	0.67 – 3.77	.<20%	3933935906
5th West Corridor	D 505	SIGA-PS	0.67 – 3.77	.<20%	3933938754
5th West Corridor	D 504	SIGA-PS	0.67 – 3.77	.<20%	3933915670
5th West Corridor	D 502	SIGA-PS	0.67 – 3.77	.<20%	3933932370
5th West Corridor	D 503	SIGA-PS	0.67 – 3.77	.<20%	3933946223
5th West Corridor	D 501	SIGA-PS	0.67 – 3.77	.<20%	3933916882

# Battery & Power Supply Testing

Generated by: BuildingReports.com

Building: Client Name			Control Panel: 1 - EST   EST3			
<i>The Control &amp; Power Testing section details the readings and measurements of batteries and power supplies used to provide power to the fire alarm and life safety systems. Items are grouped by Passed or Failed/Other.</i>						
Type	Location	Comment	Amps	Volts	Pre Test	Post Test
Passed						
Battery						
Sealed Lead Acid	1st Front Electrical Room	Passed	7ah	12v x2	26.4	25.7
Sealed Lead Acid	1st Front Electrical Room	Passed	7ah	12v x2	26.6	25.5
Sealed Lead Acid	1st Front Electrical Room	Passed	7ah	12v x2	26.6	25.6
Sealed Lead Acid	1st Front Lobby Area	Passed	18ah	12v x2	26.6	
Power Supply						
	1st Front Electrical Room	Passed	10	120		
	1st Front Electrical Room	Passed	10	120		
	1st Front Electrical Room	Passed	10	120		

# Inventory & Warranty Report

Generated by: BuildingReports.com

Building: Client Name			Control Panel: 1 - EST   EST3		
<i>The Inventory &amp; Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided.   Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.</i>					
Device or Item		Category		% of Inventory	Quantity
Power Supply		Control		2.13%	3
Battery		Control		2.84%	4
Communication Line		Control		1.42%	2
Horn/Strobe		Indicating		7.09%	10
Disconnect		Control		0.71%	1
Communicator		Control		0.71%	1
Monitoring		Monitor		0.71%	1
Control Panel		Control		0.71%	1
Bell		Indicating		0.71%	1
Heat Detector		Initiating		1.42%	2
Smoke Detector		Initiating		44.68%	63
Pull Station		Initiating		14.18%	20
Waterflow Switch		Initiating		9.22%	13
Tamper Switch		Supervisory		11.35%	16
Programmable Relay		Auxiliary		2.13%	3
Type	Qty	Model #	Description		Install Date
In Service - 1 Year to 2 Years					
Battery	3	12v7ah	Sealed Lead Acid		06/02/2009
Bell	1				06/02/2009
Communication Line	2	RJ45			06/02/2009
COPS					
Monitoring	1	387-8012	Central Station		06/02/2009
EST					
Communicator	1	EST3	Digital Communicator		06/02/2009
Control Panel	1	EST3			06/02/2009
Heat Detector	1	SIGA-HRS			06/02/2009
Heat Detector	1	SIGA-HRS	Rate-of-Rise		06/02/2009
Horn/Strobe	1				06/02/2009
Horn/Strobe	9	G1			06/02/2009
Power Supply	3	.BPS-10			06/02/2009
Programmable Relay	1	SIGA-CR	Alternate Recall		06/02/2009
Programmable Relay	1	SIGA-CR	Primary Recall		06/02/2009
Programmable Relay	1	SIGA-CR	Warning Light		06/02/2009
Pull Station	20	SIGA-273	Single Action		06/02/2009
Smoke Detector	61	SIGA-PS	Photoelectric		06/02/2009
Tamper Switch	1	PCVS-2			06/02/2009
Tamper Switch	1	SC502			06/02/2009
Waterflow Switch	1	SIGA-			06/02/2009
Milwaukee					

Tamper Switch	8	BB-SCSO2		06/02/2009
Tamper Switch	1	so2		06/02/2009
<b>Notifier</b>				
Waterflow Switch	1	WFD 2		06/02/2009
Waterflow Switch	9	WFD-2		06/02/2009
<b>Potter Electric</b>				
Tamper Switch	5	OSYS-U		06/02/2009
Waterflow Switch	2	PIVS-U		06/02/2009
<b>Square D</b>				
Disconnect	1	20 Amps	Breaker	06/02/2009
<i><b>In Service - 3 Years to 5 Years</b></i>				
<b>EST</b>				
Smoke Detector	2	SIGA-PS	Photoelectric	05/01/2006
<b>GenSpec</b>				
Battery	1	GR 12v18	Sealed Lead Acid	05/01/2006

# Zone Address Report

Generated by: BuildingReports.com

Building: Client Name			Control Panel: 1 - EST   EST3	
<i>The Zone Address Report lists all of the devices and items that have an individual address, or are grouped together under a common zone.   The device type, location, and description are included for your reference.</i>				
Address	Device Type	Location	Description	ScanID
101	Programmable Relay	1st Inside Elevator Machine Room	Warning Light	04853879
102	Programmable Relay	1st Inside Elevator Machine Room	Primary Recall	04853880
103	Programmable Relay	1st Inside Elevator Machine Room	Alternate Recall	04853881
Phone Line 1	Communication Line	1st Front Electrical Room		04853834
Phone Line 2	Communication Line	1st Front Electrical Room		04853835
Zone/Circuit: BPS 1				
Batteries	Power Supply	1st Front Electrical Room		11053734
	Battery	1st Front Electrical Room	Sealed Lead Acid	11053735
	NAC 3	Horn/Strobe		04853841
	NAC 4	Horn/Strobe		04853842
Zone/Circuit: BPS 2				
Batteries	Power Supply	1st Front Electrical Room		11053730
	Battery	1st Front Electrical Room	Sealed Lead Acid	11053731
	NAC 1	Horn/Strobe		04853843
	NAC 2	Horn/Strobe		04853845
	NAC 3	Horn/Strobe		04853844
	NAC 4	Horn/Strobe		04853846
	Zone/Circuit: BPS 3			
Batteries	Power Supply	1st Front Electrical Room		11053732
	Battery	1st Front Electrical Room	Sealed Lead Acid	11053733
	NAC 1	Horn/Strobe		04853847
	NAC 2	Horn/Strobe		04853849
	NAC 3	Horn/Strobe		04853848
	NAC 4	Horn/Strobe		04853850
	Zone/Circuit: D			
101	Smoke Detector	1st North Hallway Exit	Photoelectric	04853863
102	Smoke Detector	1st North Hallway	Photoelectric	04853864
103	Smoke Detector	1st North Hallway	Photoelectric	04853865
104	Smoke Detector	1st Northeast Elevator Lobby	Photoelectric	04853855
105	Smoke Detector	1st Northeast Activity Room	Photoelectric	04853856
106	Smoke Detector	1st Southeast Activity Room 2	Photoelectric	04853857
107	Smoke Detector	1st Southeast Elevator Lobby	Photoelectric	04853854
109	Smoke Detector	1st Inside Main Office	Photoelectric	04853858
110	Smoke Detector	1st Front Lobby Area	Photoelectric	04853851
111	Smoke Detector	1st Above Store Room	Photoelectric	3934050530
112	Smoke Detector	1st Above Electrical Room	Photoelectric	3933944571
113	Heat Detector	1st West Laundry Room	Rate-of-Rise	3809816766
114	Smoke Detector	1st South Hallway Entrance	Photoelectric	04853852
115	Smoke Detector	1st Elevator Lobby	Photoelectric	04853853

116	Smoke Detector	1st Inside Elevator Machine Room	Photoelectric	3933995153
117	Smoke Detector	1st South Hallway	Photoelectric	04853862
118	Smoke Detector	1st Southeast Pump Room	Photoelectric	3933978231
119	Smoke Detector	1st South Hallway	Photoelectric	04853861
120	Smoke Detector	1st South Hallway	Photoelectric	04853860
121	Smoke Detector	1st South Hallway Exit	Photoelectric	04853859
201	Smoke Detector	2nd Northeast Hallway Exit	Photoelectric	3933987486
202	Smoke Detector	2nd Northeast Hallway	Photoelectric	3934052435
203	Smoke Detector	2nd Northwest Hallway	Photoelectric	3934052411
204	Smoke Detector	2nd Northwest Hallway	Photoelectric	3933934329
205	Smoke Detector	2nd Northwest Hallway Entrance	Photoelectric	3933934084
206	Smoke Detector	2nd At Elevator Lobby	Photoelectric	3933944519
207	Smoke Detector	2nd Southwest Hallway Entrance	Photoelectric	3934052459
208	Smoke Detector	2nd Southwest Hallway	Photoelectric	3933873970
209	Smoke Detector	2nd Southwest Hallway	Photoelectric	3933937726
210	Smoke Detector	2nd Southwest Hallway	Photoelectric	3933951531
211	Smoke Detector	2nd Southwest Hallway Exit	Photoelectric	3933943758
301	Smoke Detector	3rd Northeast Hallway Exit	Photoelectric	3933949774
302	Smoke Detector	3rd Northeast Hallway	Photoelectric	3933913874
303	Smoke Detector	3rd Northeast Hallway	Photoelectric	3933934626
304	Smoke Detector	3rd Northeast Hallway	Photoelectric	3933934022
305	Smoke Detector	3rd Northeast Hallway Entrance	Photoelectric	04853866
306	Smoke Detector	3rd At Elevator Lobby	Photoelectric	3933934008
307	Smoke Detector	3rd Southwest Hallway Entrance	Photoelectric	3933951593
308	Smoke Detector	3rd Southwest Hallway	Photoelectric	3934022865
309	Smoke Detector	3rd Southwest Hallway	Photoelectric	3933934503
310	Smoke Detector	3rd Southwest Hallway	Photoelectric	3933934534
311	Smoke Detector	3rd Southwest Hallway Exit	Photoelectric	3933934251
401	Smoke Detector	4th East Corridor	Photoelectric	3933916790
402	Smoke Detector	4th East Corridor	Photoelectric	3933946193
403	Smoke Detector	4th East Corridor	Photoelectric	3933945813
404	Smoke Detector	4th East Corridor	Photoelectric	3934020526
405	Smoke Detector	4th East Corridor	Photoelectric	3934022872
406	Smoke Detector	4th Above Elevator Lobby	Photoelectric	3934026672
407	Smoke Detector	4th West Corridor	Photoelectric	3934024029
408	Smoke Detector	4th West Corridor	Photoelectric	3933873895
409	Smoke Detector	4th West Corridor	Photoelectric	3934024609
410	Smoke Detector	4th West Corridor	Photoelectric	3934023947
411	Smoke Detector	4th West Corridor	Photoelectric	3933951555
501	Smoke Detector	5th West Corridor	Photoelectric	3933916882
502	Smoke Detector	5th West Corridor	Photoelectric	3933932370
503	Smoke Detector	5th West Corridor	Photoelectric	3933946223
504	Smoke Detector	5th West Corridor	Photoelectric	3933915670
505	Smoke Detector	5th West Corridor	Photoelectric	3933938754
506	Smoke Detector	5th Above Elevator Lobby	Photoelectric	3933935906
507	Smoke Detector	5th West Hallway	Photoelectric	3933949729
508	Smoke Detector	5th West Hallway	Photoelectric	3934020519
509	Smoke Detector	5th West Hallway	Photoelectric	3933934510
510	Smoke Detector	5th West Hallway	Photoelectric	3934024630
511	Smoke Detector	5th West Hallway	Photoelectric	3933916844
<b>Zone/Circuit: FACP</b>				
	Bell	1st Outside Pump Room		04853882
	Communicator	1st Front Lobby Area	Digital Communicator	04853837

	Control Panel	1st Front Lobby Area		04853836
	Monitoring	1st Front Lobby Area	Central Station	04853838
Batteries	Battery	1st Front Lobby Area	Sealed Lead Acid	04853840
<b>Zone/Circuit: M</b>				
007	Heat Detector	1st West Compactor Room		3805835501
007	Waterflow Switch	1st West Compactor Room		04853883
101	Tamper Switch	1st North Stairwell Exit		02763096
101	Waterflow Switch	1st North Stairwell Exit		02763095
102	Tamper Switch	1st Southwest Stairwell Exit		02763073
1s	Waterflow Switch	1st South Stairwell		02763074
2s	Tamper Switch	2nd North Stairwell		02763062
2s	Tamper Switch	2nd South Stairwell		02763072
2s	Waterflow Switch	2nd North Stairwell		02763063
2s	Waterflow Switch	2nd South Stairwell		02763071
3s	Tamper Switch	3rd South Stairwell		02763052
3s	Tamper Switch	3rd North Stairwell		02763060
3s	Waterflow Switch	3rd North Stairwell		02763061
3s	Waterflow Switch	3rd South Stairwell		02763051
4s	Tamper Switch	4th North Stairwell		02763040
4s	Tamper Switch	4th South Stairwell		02763049
4s	Waterflow Switch	4th South Stairwell		02763050
4s	Waterflow Switch	4th North Stairwell		11053739
5s	Tamper Switch	5th South Stairwell		02763033
5s	Tamper Switch	5th North Stairwell		02763038
5s	Waterflow Switch	5th North Stairwell		02763039
5s	Waterflow Switch	5th South Stairwell		02763032
<b>Zone/Circuit: P</b>				
101	Pull Station	1st Northeast Hallway Exit	Single Action	04853871
102	Pull Station	1st West Lobby Entrance	Single Action	04853872
103	Pull Station	1st Southwest Hallway Exit	Single Action	04853867
104	Pull Station	1st Northeast Activity Rm Exit	Single Action	04853870
105	Pull Station	1st Southeast Activity Rm Exit	Single Action	04853869
106	Pull Station	1st Southeast Hallway Exit	Single Action	04853868
107	Pull Station	1st compactor room Entrance	Single Action	4884110503
108	Pull Station	1st Inside Pump Room Exit	Single Action	4884094704
201	Pull Station	2nd Northeast Hallway Exit	Single Action	04853873
202	Pull Station	2nd Inside Elevator Lobby	Single Action	04853874
203	Pull Station	2nd Southwest Hallway Exit	Single Action	04853875
301	Pull Station	3rd Northeast Hallway Exit	Single Action	04853878
302	Pull Station	3rd At Elevator Lobby	Single Action	04853877
303	Pull Station	3rd Southwest Hallway Exit	Single Action	04853876
401	Pull Station	4th North Hallway Exit	Single Action	11053740
402	Pull Station	4th West Elevator Lobby	Single Action	1105374%
403	Pull Station	4th South Hallway Exit	Single Action	11053742
501	Pull Station	5th North Hallway Exit	Single Action	11053738
502	Pull Station	5th Northwest Hallway Exit	Single Action	11053737
503	Pull Station	5th South Hallway Exit	Single Action	11053736
<b>Zone/Circuit: Panel "C"</b>				
Breaker #17	Disconnect	1st Front Electrical Room	Breaker	04853839