

PROPOSAL REPORT FOR:

Hillcrest East Building 20 Inc
 919 Hillcrest Drive
 Hollywood, FL 33021

Summary Details For RFP No.504519:

Reference Name: Generator Day Tank Addition
 Industry Solicited: Generator & Co-Generation Systems
 RFP Close Date & Time: 06-29-2012 15:00
 Location where work is to be performed: Other

Projected Contract Term: Single Service

Proposal Overview Details:

Proposals Submitted: **1**
 Alt.Proposals Submitted: **0**
 High Bid: **\$7,400.00**
 Low Bid: **\$7,400.00**
 Average Bid: **\$7,400.00**

VENDOR 1

Assurance Power Systems LLC
Vendor Apple Rating: 
1702 Costa del Sol, Boca Raton, Florida 33432
In-House Vendor? No
Company Phone: (561) 886-0470
Extension: 0
Alt.Phone: () -
Alt.Extension: 0
Year Business Established: 2005
Contact: William Ferrigno
will@assurancepower.com
Mobile Phone: () -
TOTAL AMOUNT PROPOSED
\$7,400.00*
Alternate Proposal Provided?
No
Alt.Price: N/A

*Designates exception for 1 or more line items. Please see vendor notes for details.

LINE ITEM #1: Generator Day Tank Addition.

The current diesel generator installation gets starved for fuel from the main tank. An engineer has recommended to us installing a "day tank" between the main tank and the generator, adjacent to the generator, to provide a better fuel feed.

Generator diesel tank is in back of building. Drive-up access is available at any time. Please quote:

1) Supply and install approved 25 Gallon Double-Walled Diesel "Day Tank".

2) Install on existing pad next to generator room and integrate between the existing tank and the generator. For generator room access, e-mail the property manager.

3) Test and verify that generator fuel feed is sufficient, and that the day tank is replenished by the existing main tank.

4) Please note any concerns or additional requirements.

5) If you have alternate recommendations, please put them in an Alternate Proposal: This option will be available as soon as you submit your Primary Proposal. Call CAMAssistant Support for help with this option.

Attachment for Line Item 1:None**VENDOR 1:****LINE ITEM PRICE: \$ 7,400.00**

NOTES:Double wall series day tanks - 25 gallon 1
 OP210 High/low combination fuel level alarm 1
 OP295 Leak detector for double wall tanks with 1
 pump and motor
 OP315SGL Fuel filter 1
 Single
 OP323A Vent kit, double wall, for PY5 - PY50
 2" NPT
 OP334-2 Day tank cover - NEMA-1 enclosure
 Duplex
 OP355A Check valve 1
 1/2", to 6 GPM
 OP360/120-A Solenoid valve, normally closed (n/c) 1
 120vac systems - 1/2", to 4 GPM pumps
 OP399 Reverse flow controller 1
 OP401 Pump, bronze - 4 GPM, 3/8" port 1
 OP414 1/3 HP motor 1
 A/C, 115 volt, 1PH, 60 HZ, standard motor
 UL 2016 N1 UL Requirements - NEMA 1
 Control Panel and Relay Box
 Includes all labor and materials to integrate and test day tank system.

EXCEPTION(S): N/A

VENDOR 1:

\$ 0.00

SPECIAL REQUIREMENTS -- Vendors meet the following requirements:

Licensed

Professional
Occupational

Insured

Worker's Comp
Worker's Comp. Exemptions Accepted
General Liability
Minimum Liability Insurance Amount Required: **\$500,000.00**
Property Association MUST Be Listed As An "Additional Insured"
Management Company MUST Be Listed As An "Additional Insured"

VENDOR 1:

Occupational License: [PBC_Occ_licenses_Receipts_15-Jun-12.pdf](#)
Professional License: [Electrical_Contractor_License_Assurance_15-Jun-12.pdf](#)
General Liability Insurance: [Assurance_Insurance_Cert_15-Jun-12.pdf](#)
Workers Comp Insurance: [Assurance_Insurance_Cert_15-Jun-12.pdf](#)
W-9: [W9-Assurance_15-Jun-12.pdf](#)
WARRANTY-INFO: No Files
Warranty: 1 year from workmanship defects.

NOTES:NONE

EXCEPTION(S):None