INTERNATIONAL STANDARD ISO 14644-1: Cleanrooms and associated controlled environments

Classification of air cleanliness by particle concentration for ISO Class 5 and Class 7

Maximum cumulative particle count for ISO Class 5: 3,520 particles per cubic meter >= 0.5 um

Maximum cumulative particle count for ISO Class 7: 352,000 particles per cubic meter >= 0.5 um

Laminar airflow requirement: unidirectional airflow velocity 0.35 to 0.45 m/s across work envelope

Differential pressure cascading: minimum +15 Pa between cleanroom pod and surrounding gowning z

HEPA filtration: minimum 99.99% particulate capture efficiency at 0.3 micron MPPS