



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 15/06/2025

Shift: B

Incharge(s): Saurabh Kumar Yadav, K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO32	CT NOT MOVING OPERATION CABIN SIDE LIMIT ACTED	RELEASED	19:15:00	19:30:00	
2	OHP	VF 23	MPCB TRIPPED	MADE ON	20:40:00	20:50:00	
3	OHP	CO 13(C)DRIVE	MPCB TRIPPED	MADE ON	16:00:00	16:10:00	
4	OHP	CO 78	NOT RUNNING IN HEALTHY ROUTE SELECTION PROBLEM	RECTIFIED	16:30:00	17:00:00	
5	OHP	BRC 1 ON CO 30	FROM CO30 TO CO8A	SHIFTING WAS DONE	15:00:00	17:30:00	
6	OHP	BRC ON CO8A	B/C TRIPPING ON OLR MECH PROBLEM	INFORMED TO MECH	17:30:00	19:00:00	
7	OHP	BRC ON CO 8A	B/C OLR ACTED	RESET	20:00:00	20:15:00	
8	CHP	COB 5 allen bradely	operator pc not working	pc restart than ok	19:00:00	19:10:00	
9	CHP	CC 223	not healthy, went to remote mode	power control power recycle done	19:30:00	19:40:00	
10	CHP	CC 42	E stop PB faulty	PB replaced	14:40:00	15:00:00	
11	CHP	CC 40 scr 6	luffing not working, wrong complaint, slew not working, slew limit acted due to jamming	inform operation	20:50:00	21:05:00	
12	CHP	cc 131	olr acted	reset it done	18:40:00	18:45:00	3 times
13	CHP	CC 103 TT	not moving, old joint of cable opened	cable jointed and proper insulation done	15:00:00	15:40:00	
14	CHP	CC 223	not healthy, c/s acted full jammed	informed operation for cleaning	21:30:00	21:45:00	