



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 21/01/2026

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CR 3	lub oil flow not ok,sensor problem	sensor open and fixed than ok	01:50:00	02:15:00	
2	OHP	cO 47	stopped in ZSS,probe problem	probe replaced	02:30:00	02:55:00	
3	OHP	CO 10 A	olr acted	reset	05:30:00	05:35:00	
4	OHP	TBS on CO 20	l/ luff not working,limit switch problem	limit switch bypassed	22:35:00	22:55:00	
5	OHP	CO 11(C)	olr acted	reset	23:00:00	23:10:00	
6	CHP	CC 28	OLR acted	reset	23:40:00	23:50:00	
7	CHP	CC 35 SCR3	slew not working,limit acted	jamming,informed operation	03:20:00	03:35:00	
8	CHP	CC 117	motor tripped ,olr acted	reset	23:30:00	23:45:00	
9	CHP	CC 58	olr acted	reset	04:05:00	04:20:00	
10	WT	CT 1	no movement,drive not healthy,brake mccb tripped,brake c2 contactor problem got welded,in rectifier ckt 2 number of metal diode got failed and mcb of brake panel also got damaged	drive reset,encoder and encoder card checked found ok,mccb made on,diode replaced from the spare panel and mcb replaced	01:25:00	03:05:00	c2 aux contractor to be replaced
11	WT	CO 3(B)	olr acted	reset	02:50:00	03:00:00	
12	WT	OC 1A	ZSS acted	probe ,module checked all ok	22:45:00	22:59:00	
13	IOSA	tbs	Left b/c olr acted	reset	02:30:00	02:40:00	full jamming