



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 20/05/2025

Area: IOSA

Equipment	Job
OTT-1A	CHUTE VIBRATOR B PHASE WIRE GOT CUT. RE-TERMINATED AND CHECKED.
BRC	FIELD DEVICES FEEDBACK AND PPM DONE.
PLC	PLC COMMUNICATION PROBLEM HAS COME. FOUND OM-1 RACK IS SHOWING FAULT. POWER RECYCLED FOR THAT RACK AND GIVEN CLEARANCE.
OC-11A	FIELD DEVICES FEEDBACK CHECKING DONE
OC-9A	FIELD DEVICES FEEDBACK CHECKING DONE.
TBS	TBS TO OC-11A GALLERY FAILED. CHECKED AT TBS RMU FOUND LOOSE CONTACT AT 240V/12V SMPS TB. TIGHTENED SAME AND GIVEN CLEARANCE.