



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 26/10/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO-8A	REPORTED B/W-1 STOPPING ON ZSS CHECKED AND FOUND ZSS PROBE DAMAGED	ZSS BYPASSED	07:20:00	07:35:00	DUE TO MECHANICAL PROBLEM
2	CHP	TT ON CC-102	REPORTED TT NOT MOVED CHECKED AND FOUND PCRD CABLE OLD JOINT GOT CUT	PCRD CABLE JOINT WAS DONE THAN OK	08:30:00	09:20:00	
3	CHP	CC-51	MPD TRIPPED ON OLR (3TIMES) DUE TO FEEDING CONVEYOR STOP	RESET DONE	13:00:00	13:25:00	
4	CHP	CC-54	TRIPPED ON OLR (3TIMES)	RESET DONE	09:15:00	11:00:00	
5	CHP	CC-58 TT	REPORTED NOT HEALTHY FESTOON CONTROL CABLE DAMAGED	RE-JOINT DONE THAN OK	10:30:00	10:50:00	
6	CHP	CC-51	TRIPPED ON OLR	RESET DONE	13:25:00	13:30:00	
7	CHP	CC-35 SCR-3	SLEW NOT WORKING CHECKED AND FOUND R/LIMIT ACTED DUE TO JAMMING	INFORMED TO OPERATION	10:30:00	10:40:00	
8	WT	OT-1	REPORTED NOT MOVE DRIVE -1 PGF-1 FAULT	RESET DONE	12:45:00	12:55:00	
9	WT	OC-1A	TRIPPED ON OLR	RESET DONE	08:45:00	09:00:00	
10	IOSA	WOBR	REPORTED LT NOT TAKING PLACE FOUND PCRD O/T ACTED	RELEASED THAN OK	12:30:00	12:40:00	