



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 05/12/2025

Incharge(s): Lal Singh,Lal Singh

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-25	TRIPPED ON OLR	RESET DONE	13:00:00 13:20:00	13:10:00 13:30:00	
2	OHP	TT-4	C/S SIGNAL NOT COMING ... FUSE BLOWN IN TT	FUSE REPLACED AND WIRE FIXED PROPERLY	07:15:00	07:30:00	
3	OHP	BRC ON CO-34	BW-2 OLR TRIPPED	RESET DONE	08:30:00	08:45:00	
4	CHP	CC-40 SCR-2	BW DRIVE TRIPPED	RESET DONE	13:05:00	13:15:00	
5	CHP	CC-51	MPD TRIPPED (13 TIMES)	RESET DONE	06:00:00	14:00:00	
6	CHP	CC-54	TRIPPED ON OLR (15 TIMES)	RESET DONE	06:00:00	14:00:00	
7	CHP	CC-28	TRIPPED ON OLR	RESET DONE	07:35:00	07:40:00	
8	CHP	CC-29	TRIPPED ON OLR	RESET DONE	09:00:00 10:05:00	09:05:00 10:10:00	
9	CHP	CC-112 SCR-8	LT NOT MOVING	PCRD NOT HEALTHY ... RESET	13:00:00	13:10:00	
10	WT	OP-9	NOT MOVING MIDDLE PAD DISTURBED	ADJUSTED	09:15:00	09:35:00	