



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 02/12/2025

Area: IOSA

| Equipment | Job |
|-------------------|---|
| OC-19A | HEAD END LIGHTING CIRCUIT DEFECTS RECTIFIED. SUFFICIENT LIGHTING ARRANGED. DEFECTIVE LIGHT FITTINGS REMOVED AND SHIFTED TO ELECTRICAL SHED. |
| OC-27A | GALLERY LIGHTING CIRCUIT DEFECTS RECTIFICATION IS IN PROGRESS. |
| OC-9A | GALLERY AND JUNCTION HOUSE LIGHTING CIRCUIT DEFECTS RECTIFICATION IS IN PROGRESS. |
| OC-11A | GALLERY AND JUNCTION HOUSE LIGHTING CIRCUIT DEFECTS RECTIFICATION IN PROGRESS |
| WOBR-FLS | TRIAL RUN TAKEN AND CHECKED ALL FUNCTIONS. |
| BLENDER RECLAIMER | BUCKET WHEEL -2 ZSS PROBE ADJUSTMENT DONE. |
| OC-18A | PPM DONE ON MOTOR AND FIELD DEVICES. |