



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 24/12/2025

Incharge(s): G Eswara Rao

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 67	tripped on olr	reset done	06:30:00	06:40:00	
2	CHP	scr 1 on cc34	It not taking place/m2 mpcb tripped	made on	08:20:00	08:30:00	
3	CHP	r1 on cc33	bc not running/interlock cage stuckup with material	cage made free.then ok	10:58:00	11:10:00	
4	CHP	s2 on cc36	slew not working/30degree limit acted	limit released then ok	11:30:00	11:40:00	
5	CHP	cc19	tripped on olr	reset done	10:20:00	10:30:00	
6	WT	op 5	not moving/ AL relay stuckup/made free	tested ok	11:30:00	11:40:00	