



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 13/08/2025

Shift: C

Incharge(s): Lal Singh, Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 29	OLR acted	reset done	04:50:00 22:45:00	05:00:00 22:55:00	
2	OHP	TT 4 on BPC 2	Indication problem	wire opened in fuse TB , connected	23:45:00	23:55:00	
3	OHP	WOBR on CO 29	Slew drive tripped on overload	reset done	22:20:00	22:30:00	
4	OHP	CO 26	OLR acted	reset done	02:45:00	03:00:00	
5	OHP	BRC on CO 28	LT not moving bcz of pcrd OT	tension released and informed mech for guide adjustment	03:15:00	03:35:00	
6	OHP	BRC on CO 28	BW 2 overload acted	reset done	05:10:00	05:25:00	
7	OHP	CO 28	Pull chord acted	reset done	02:00:00	02:20:00	
8	OHP	VF 20	motor mpcb tripped	made on	02:45:00	03:00:00	
9	CHP	CC 103 , CC 26	Healthy stopping	checked , no prblm found. Control terminals tightened	03:00:00	03:10:00	
10	CHP	CC 51	MPD tripped ( 5 times ) , feeding yard conveyor stopped	made on	23:45:00	04:05:00	
11	CHP	CC 39 , S 1	Luff not working	Air lock problem , informed to mechanical	00:15:00	00:30:00	
12	CHP	CC 34 , SCR 2	LT not working due to pcrd overtension	tension released	01:10:00	01:30:00	
13	WT	CP 3	Not moving , emergency acted	released	00:00:00	00:20:00	
14	WT	EOT crane	CT not moving ( east side)	contactor tips cleaned	02:00:00	02:30:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 13/08/2025

Shift: C

Incharge(s): Lal Singh, Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
15	IOSA	OC 37 A	stopping in zss, c clamp and cage hole enlarged	zss bypassed	01:15:00	02:15:00	