



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 29/07/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 25	OLR ACTED	RESET	07:45:00	07:55:00	
2	OHP	CO 12(C) DRIVE	OLR ACTED	RESET	09:45:00	10:00:00	
3	OHP	CO 10A	OLR ACTED	RESET	10:15:00	10:30:00	
4	OHP	CO 26	OLR ACTED	RESET	12:15:00	12:30:00	
5	CHP	CC 54	OLR ACTED	RESET	10:10:00 11:10:00 12:10:00	10:20:00 11:20:00 12:20:00	DUE TO OVER LOAD
6	CHP	CC15	OLR ACTED	RESET	13:25:00	13:30:00	
7	CHP	CC-31 S-3	SLEW NOT TAKING PLACE DRIVE TRIP	DRIVE FAULT RESET	08:35:00	08:50:00	
8	CHP	CC-38 SCR-3	LT NOT TAKING PLACE DRIVE(LVD) TRIP	DRIVE FAULT RESET	09:00:00	09:10:00	
9	CHP	CC 31 S3	LT NOT TAKING PLACE	WRONG COMPALAIN	13:10:00	13:20:00	
10	CHP	CC-131	OLR ACTED	RESET	07:40:00	07:50:00	
11	CHP	CC 39 SCR-6	B/W NOT RUNNING CHECKED OIL LOW LEVEL	INFORMED TO MECHANICAL	07:30:00	07:45:00	