



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 03/09/2025

Area: OHP

Equipment	Job
CO 6A	M5 MOTOR REMOVED
CO17	ALL FIELD DEVICES INSPECTION DONE
CO 8 9 10	LIGHTING PROBLEM RECTIFIED
CO 1A , CO 7	10 no 70 W LIGHTS GIVEN
RSCO 2A, RBF1A, 2A, 3A CO 16A 16B	MOTOR AND PANEL SIDE PPM DONE
CO 16A , CO 16 B	FIELD DEVICES AND HOIST PPM DONE
JH14, OM 24 LC 4 LC 3	SUMP PUMP WATER LEVEL CHECKING DONE
CO 68	TAIL END 70 W SV 6 no LAMPS GIVEN
OM 24, 15	CONTROL BUS BAR PPM DONE
co-26 jod	jod installed and kept in circuit.
wbr- 1 on co-26	pcrd motor is installed and cable winding is done