



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 26/01/2026

Incharge(s): Nagendra Midde

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	VS1A	OLR ACTED	RESET	20:30:00	20:40:00	
2	OHP	CO 16A	BRS MODULE PROBLEM	BYPASSED	16:30:00	17:00:00	
3	OHP	WBR ON CO 26	B/W MPCB TRIP	MADE IT ON	21:50:00	22:00:00	
4	CHP	CC 19	OLR ACTED	RESET	16:00:00	16:10:00	
5	CHP	CC 219 ZSS	MODULE PROBLEM	REPLACED	16:30:00	17:00:00	
6	CHP	CC 32	OLR ACTED	RESET	15:45:00	15:55:00	
7	CHP	SCR 4 ON CC 31 SLEW	OLR ACTED	RESET	15:55:00	16:10:00	
8	CHP	SCR 6 ON CC 39	B/C OLR ACTED	RESET	17:05:00	17:15:00	
9	CHP	CC 43	OLR ACTED	RESET	19:25:00	19:30:00	
10	CHP	CC 125	OLR ACTED	RESET	21:50:00	21:55:00	
11	WT	OP 10	DRIVE 6 TRIP	RESET	18:00:00	18:15:00	
12	WT	CP 1	C CLAMP DAMAGED	REPLACED	16:00:00	16:15:00	