



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 22/11/2025

Incharge(s): Nagendra Midde

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO 33M LT	EMERGENCY STOP ACTED	RELEASED	16:50:00	17:05:00	
2	OHP	BRC ON CO 8A	B/W 2 RUNNING WITH OUT LOAD BUT ZSS ACTING WHILE RUNNING ON LOAD	INFORMED TO MECH	21:15:00	21:30:00	
3	OHP	VF 21	OLR ACTED	RESET	18:45:00	18:55:00	
4	OHP	CO 30	c/s not acting,	SENSITIVITY ADJUSTED AS PER INSTRUMENTATION INSTRUCTION	21:30:00	21:50:00	
5	CHP	CC 51	OLR ACTED	RESET	16:00:00	20:45:00	3 TIMES
6	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	17:55:00	21:20:00	4 TIMES
7	CHP	R1 ON CC 32	LUFF OIL LEAKAGE	INFORMED TO MECH	17:00:00	17:20:00	
8	WT	OT1	DRIVE 1 TRIPPED ON PGF1 FAULT	RESET	15:20:00	15:30:00	